



**BUREAU  
VERITAS**

# Świadectwo zgodności

## Zgłaszający:

JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD  
No.90 ZiJin Rd., New District,  
Suzhou, 215011  
China

## Produkt:

Sieciowy falownik fotowoltaiczny (PV)

## Model:

GW4K-DT  
GW5K-DT  
GW6K-DT  
GW8K-DT  
GW10KT-DT  
GW12KT-DT  
GW15KT-DT

## Zastosowanie zgodnie z przepisami:

Automatyczne urządzenie wyłączające, monitorujące sieć trójfazową w systemach fotowoltaicznych z obwodem równoległym trójfazowym poprzez przetwornicę w publicznej sieci zasilania. Automatyczne urządzenie wyłączające stanowi część wyżej wymienionej przetwornicy.

## Zastosowane przepisy i normy:

**EN 50549-1:2019, PN-EN 50549-1:2019**

Wymagania dla instalacji generacyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych -- Część 1: Przyłączanie do sieci dystrybucyjnej nN -- Instalacje generacyjne aż do typu B i włącznie z nim

**EN 50438:2013, PN-EN 50438:2014**

Wymagania dla instalacji mikrogeneracyjnych przeznaczonych do równoległego przyłączenia do publicznych sieci dystrybucyjnych niskiego napięcia

**DIN V VDE V 0126-1-1:2006 (4.1 Bezpieczeństwo Funkcjonalne)**

Automatyczne urządzenie odłączające między generatorem a publiczną siecią niskiego napięcia

W momencie wydania niniejszego certyfikatu pojęcie zabezpieczenia interfejsu wyżej wymienionego, reprezentatywnego produktu spełnia wymagania bezpieczeństwa obowiązujące dla określonego zastosowania zgodnie z przepisami.

**Numer raportu:**

ZEM-ESH-P19112903

**Program certyfikacji:** NSOP-0032-DEU-ZE-V01

**Numer świadectwa:** U20-0207

**Data wydania:**

2020-03-31



Instytut certyfikacji Bureau Veritas Consumer Products Services Germany GmbH akredytowane zgodnie z normą DIN EN ISO/IEC-17065

Uma representação parcial do certificado requer a aprovação por escrito do Bureau Veritas Consumer Products Services

**Appendix**

Extract from test report according to EN 50549-1

Nr. ZEM-ESH-P19112903

**Type Approval and declaration of compliance with the requirements of EN 50549-1.**

**Manufacturer / applicant:**  
JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD  
No.90 Zijin Rd., New District,  
Suzhou, 215011  
China

**Micro-generator Type** Grid-tied photovoltaic inverter

	GW4K-DT	GW5K-DT	GW6K-DT	GW8K-DT
	180 - 850			
<b>MPP DC voltage range [V]</b>				
Input DC voltage range [V]	max. 1000	max. 1000	max. 1000	max. 1000
Input DC current [A]	12,5/12,5	12,5/12,5	12,5/12,5	12,5/12,5
Output AC voltage [V]	3/N/PE 400	3/N/PE 400	3/N/PE 400	3/N/PE 400
Output AC current [A]	6,4 * 3	8 * 3	9,6 * 3	12,8 * 3
Output power [W]	4000	5000	6000	8000
Output power [VA]	4400	5500	6600	8800

**MPP DC voltage range [V]**

	GW10KT-DT	GW12KT-DT	GW15KT-DT
	180 - 850		
Input DC voltage range [V]	max. 1000	max. 1000	max. 1000
Input DC current [A]	12,5/12,5	12,5/25	12,5/25
Output AC voltage [V]	3/N/PE 400	3/N/PE 400	3/N/PE 400
Output AC current [A]	16 * 3	20,3 * 3	24 * 3
Output power [W]	10000	12000	15000
Output power [VA]	11000	14000	16500

**Firmware version** V1.00.00.01

**Measurement period:** 2019-11-29 to 2020-03-10

**Description of the structure of the power generation unit:**

The power generation unit is equipped with a PV and line-side EMC filter. The power generation unit has no galvanic isolation between DC input and AC output. Output switch-off is performed with single-fault tolerance based on two series-connected relays in each line and neutral. This enables a safe disconnection of the power generation unit from the network in case of error.

**Appendix**

Extract from test report according to EN 50549-1

Nr. ZEM-ESH-P19112903

**Setting of the interface protection:**

Parameter	Max. disconnection time	Min. operate time	Trip value
Over voltage (stage 1) <sup>a</sup>	3s	-	230V +10% (253V)
Over voltage (stage 2)	0,2s	0,1s	230V +15% (264,5V)
Under voltage	1,5s	1,2s	230V -15% (195,5V)
Over frequency	0,5s	0,3s	50Hz +4% (52Hz)
Under frequency	0,5s	0,3s	50Hz -5% (47,5Hz)
Reconnection settings for voltage (normal operational startup)	0,85V <sub>n</sub> (195,5V) ≤ V ≤ 1,10V <sub>n</sub> (253V)		
Reconnection settings for frequency (normal operational startup)	49,5Hz ≤ f ≤ 50,1Hz		
Reconnection time (normal operational startup)	≥ 60 s		
Reconnection settings for voltage (automatic reconnection after tripping)	0,85V <sub>n</sub> (195,5V) ≤ V ≤ 1,10V <sub>n</sub> (253V)		
Reconnection settings for frequency (automatic reconnection after tripping)	49,5Hz ≤ f ≤ 50,1Hz		
Reconnection time (automatic reconnection after tripping)	≥ 60 s		
Active power gradient after reconnection	10% P <sub>E<sub>max</sub></sub> / per minute		
Active power delivery at under frequency	electronic inverter, no active power reduction		
Power response to over frequency (frequency / droop s)	50,2Hz / 5%		
Permanent DC-injection	0,5% of rated inverter output current or 20mA		
Rate of change of frequency (ROCOF)	2Hz/s		
Loss of mains according EN 62116 (LoM)	2,0s		

**Note:**

<sup>a</sup> Over voltage – stage1: 10 min-mean-value corresponding to EN 50160. Default interface setting according to EN 50438:2013 are used.

The settings of the interface protection are password protected adjustable.

In case the above stated generators are used with an external protection device, the protection settings of the inverters are to be adjusted according to the manufacturer's declaration.

The above stated generators are tested according to the requirements in the EN 50549-1:2019. Any modification that affects the stated tests must be named by the manufacturer/supplier of the product to ensure that the product meets all requirements of the EN 50549-1:2019.