


⚠ WARNING

The information in this quick guide is subject to change due to product updates or other reasons. This guide cannot replace the product labels or the safety precautions in the user manual unless otherwise specified. All descriptions in the manual are for guidance only.


01 Networking



Device	Model	Description
Inverter	GW6000-ET-20, GW8000-ET-20, GW9900-ET-20, GW10K-ET-20, GW12K-ET-20, GW15K-ET-20	A maximum of 4 inverters can be connected in a parallel system. Inverter firmware requirements for parallel connections: <ul style="list-style-type: none"> Consistent firmware version ARM version: 01.389 or above DSP version: 01.15 or above
Battery system	Lynx Home F G2 LX F9.6-H-20 LX F12.8-H-20 LX F16.0-H-20 LX F19.2-H-20 LX F22.4-H-20 LX F25.6-H-20 LX F28.8-H-20	Lynx Home F Plus+ LX F6.6-H LX F9.8-H LX F13.1-H LX F16.4-H
	Lynx Home D LX D5.0-10	<ul style="list-style-type: none"> A maximum of 8 battery systems can be clustered in a system. Do not mix connect battery systems of different versions.

Device	Model	Description
Smart Meter (Optional)	<ul style="list-style-type: none"> GM3000 GM330 	<ul style="list-style-type: none"> The inverter has a built-in smart meter, and CT cannot be changed. CT ratio: 90A/90mA GM3000: GM3000 and the CT, which cannot be replaced, are included in the inverter package. CT ratio: 120A/40mA. CM330: order the CT for GM330 from GoodWe or other suppliers. CT ratio: nA/5A. <ul style="list-style-type: none"> nA: CT primary input current, n ranges from 200 to 5000. 5A: CT Secondary input current.
Smart Dongle	<ul style="list-style-type: none"> WiFi/LAN Kit-20 Ezlink3000 	<ul style="list-style-type: none"> In single scenarios, please use WiFi/LAN Kit-20 modules. In parallel scenarios, the EzLink3000 must be connected to the master inverter. Do not connect any communication module to the slave inverters. The firmware version of EzLink should be 04 or above.

02 Power On/Off



Power on/off



④ : Install or not based on local laws and regulations.

03 Installations


Steps	1 Installation	2 PE	3 PV	4 Battery	5 AC	6 COM	7 Communication module	
Inverter							WiFi/LAN Kit-20	Ezlink3000
Tools	1 D: 80mm φ: 8mm 2 M5 1.2-2N·m	M5 1.5-2N·m	Recommend: PV-CZM-61100 	Recommend: VXC9 M5 1.5-2N·m	2 M5 1.5-2N·m Or	M4 1.5N·m		

Steps	1 Installation				2 PE	3 Battery				4 COM			
Battery	Lynx Home F G2	Lynx Home F	Lynx Home F Plus+	Lynx Home D	Lynx Home F	Lynx Home D	Lynx Home F G2	Lynx Home F	Lynx Home F Plus+	Lynx Home F	Lynx Home D	Lynx Home F	Lynx Home D
Tools	 1 Ground 2 Wall 2 D: 80mm φ: 10mm 3 ST5.5 4N·m 4 M5 4N·m				 M6 6-7N·m M5 4N·m	 Recommend: YQK-70		 Recommend: YQK-70		 Recommend: YQK-70		 Recommend: YQK-70	

Steps	1 Installation		2 Cable Connections		3 Power	4 Commissioning	
Smart meter	GM3000	GM330	GM3000	GM330	AC breaker	 SOLAR GO SolarGo APP	 SEMS SEMS Portal APP or SEMS Portal WEB


04 Wiring Diagram

ET G2 6-15kW (single) + Lynx Home F or Lynx Home D + WiFi/LAN





ET G2 6-15kW (parallel connected) + Ezlink3000


CAT 5E and higher categories
L ≤ 25m



ET1020NET0003







05 Equipment Commissioning



SolarGo app




SEMS Portal app

In parallel scenarios, the software version of SolarGo app should be 5.4.0 or above.
Follow the prompts to connect the device.


Quick Settings

Tap **Home** > **Settings** > **Quick Settings** to complete quick settings step by step.
Installer password: goodwe2010


Setting the Safety Code




Setting Inverter Quantity (Only For Parallel Connections)



Setting the BAT Connect Mode




Setting the Working Mode




Depth Of Discharge (On-Grid):
The maximum depth of discharge of the battery when the system is working on-grid.

Depth Of Discharge (Off-Grid):
The maximum depth of discharge of the battery when the system is working off-grid.



Setting Batteries Of Each Inverters (Only For Parallel Connections)


Follow the prompts to set the battery model and connection mode of each inverter.



Setting the Advanced Parameters


Tap Home > Settings > Advanced Settings to set the following functions.

Setting DRED/Remote Shutdown/RCR or Three-phase Unbalanced Output Function (Optional)



Enable **Three-phase Unbalanced Output** when the utility grid company adopts phase separate billing.


Setting the Power Limit Function



Configuring the Network


Tap Home > Settings > Communication Setting to set network parameters.

WiFi/LAN Kit-20 or Ezlink3000



Creating a Power Plant

Create power plants and add equipments via SEMS Portal app.



GoodWe Technologies Co., Ltd.
No. 90 Zijin Rd., New District,
Suzhou, 215011, China
www.goodwe.com
service@goodwe.com