

<b>Prüfbericht-Nr.:</b> <i>Test Report No.:</i>	CN224DKW 001	<b>Auftrags-Nr.:</b> <i>Order No.:</i>	168385936	Seite 1 von 9 Page 1 of 9	
<b>Kunden-Referenz-Nr.:</b> <i>Client Reference No.:</i>	1282992	<b>Auftragsdatum:</b> <i>Order date:</i>	2022.08.10		
<b>Auftraggeber:</b> <i>Client:</i>	<b>HUAWEI TECHNOLOGIES CO., LTD.</b> Administration Building, Headquarters of Huawei Technologies Co., Ltd. Bantian, Longgang District, Shenzhen, 518129 Guangdong, P.R. China				
<b>Prüfgegenstand:</b> <i>Test item:</i>	SOLAR INVERTER				
<b>Bezeichnung / Typ-Nr.:</b> <i>Identification / Type No.:</i>	SUN2000-100KTL-M2, SUN2000-115KTL-M2				
<b>Auftrags-Inhalt:</b> <i>Order content:</i>	A3 certificate				
<b>Prüfgrundlage:</b> <i>Test specification:</i>	<p>VDE-AR-N 4105/11.18 <i>Generators connected to the low-voltage distribution network – Technical requirements for the connection to and parallel operation with low-voltage distribution networks</i></p> <p>DIN VDE V 0124-100/06.20 <i>Grid integration of generator plants – Low-voltage – Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks</i></p>				
<b>Wareneingangsdatum:</b> <i>Date of receipt:</i>	2022.08.10				
<b>Prüfmuster-Nr.:</b> <i>Test sample No.:</i>	Engineering samples				
<b>Prüfzeitraum:</b> <i>Testing period:</i>	2022.08.10 – 2022.10.19				
<b>Ort der Prüfung:</b> <i>Place of testing:</i>	TÜV Rheinland (Shanghai) Co., Ltd.				
<b>Prüflaboratorium:</b> <i>Testing laboratory:</i>	TÜV Rheinland (Shanghai) Co., Ltd.				
<b>Prüfergebnis*:</b> <i>Test result*:</i>	Pass				
<b>erstellt von: / created by:</b>	<b>genehmigt von: / authorized by:</b>				
2022.11.01 Edward Li / PE	2022.11.01 Zhiwei Yan / Reviewer				
<b>Datum</b> <i>Date</i>	<b>Name / Stellung</b> <i>Name / Position</i>	<b>Unterschrift</b> <i>Signature</i>	<b>Datum</b> <i>Date</i>	<b>Name / Stellung</b> <i>Name / Position</i>	<b>Unterschrift</b> <i>Signature</i>
<b>Sonstiges / Other:</b> Test procedure complied with DIN VDE V 0124-100/06.20, see report CN224DKW 001 attachment 1 for detail.					
<b>Zustand des Prüfgegenstandes bei Anlieferung:</b> <i>Condition of the test item at delivery:</i>		Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>			
* Legende P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet * Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested					
<b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b> <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i>					

V05

**Liste der verwendeten Prüfmittel**  
**List of used test equipment**

Equip.	Description	Model	Manufacturer
9017073	Power Analyser(DEWETRON)	DEWE2-PA7	Austria, DEWETRON
9017074	Current Sensor(For WT3000)	IT 200-S	LEM
9017075	Current Sensor(For WT3000)	IT 200-S	LEM
9017076	Current Sensor(For WT3000)	IT 200-S	LEM
9017077	Current Sensor(For WT3000)	IT 200-S	LEM
9017078	Programmable AC Source(61860)	61860	Chroma ATE INC.
9017080	Oscilloscope	MDO3024	Tektronix
G1819265	ScopeCoder	DL850	JAPAN, Yokogawa
G1819266	Power Analyser(WT3000)	WT3000	JAPAN, Yokogawa
G1819267	T-Power Software	TP100-P-LVHA/STP	JAPAN, Yokogawa
G1819268	Anti-islanding test detection devices	ACLT-4830H	QUNLING Energy Resources
G1819269	Harmonic impedance analog flicker system	ACLT-6150	QUNLING Energy Resources
G1819277	PV array simulator	62150H-1000S	Chroma Co.
G1819278	PV array simulator	62150H-1000S	Chroma Co.
G1819279	PV array simulator	62150H-1000S	Chroma Co.
G1819280	PV array simulator	62150H-1000S	Chroma Co.

Prüfbericht-Nr.: CN224DKW 001  
Test Report No.:

Seite 3 von 9  
Page 3 of 9

**Produktbeschreibung**  
**Product description**

**1 Produktdetails**  
**Product details**

See below.

Copy of marking plate:



型号 Model: SUN2000-100KTL-M2  
名称 Name: 太阳能光伏逆变器  
SOLAR INVERTER

最大输入电压 d.c.Max.Input Voltage: 1100 Vd.c.  
最大输入电流 d.c.Max.Input Current: 10x30 A  
输入短路电流 Isc: 10x40 A  
MPPT电压范围 d.c. MPPT Range: 200 – 1000 Vd.c.  
输出电压 a.c. Output Nominal Voltage: 380/400 Va.c., 3(N)~ +⊕  
480 Va.c., 3~ +⊕

输出频率 a.c. Nominal Operating Frequency: 50/60 Hz  
额定输出功率 a.c. Output Rated Power: 100 kW  
最大视在功率 a.c. Max.Output Apparent Power: 110 kVA  
最大输出电流 a.c. Max.Output Current: 168.8 A; 380 Va.c.  
160.4 A; 400 Va.c.  
133.7 A; 480 Va.c.

功率因数 Power Factor: 0.8(lagging) - 0.8(leading)  
温度范围 Operating Temperature Range: - 25 – + 60 °C  
逆变器拓扑 Inverter Topology: Non - Isolation  
防护等级 Enclosure: IP66  
保护等级 Protection Class: I  
过电压类别 Overvoltage Category: II(DC)/III(AC)  
污染等级 Pollution Degree: III  
海拔 Altitude: 4000 m  
通讯方式 Communication: RS485  
电弧故障保护 AFCI: TYPE I





华为技术有限公司 HUAWEI TECHNOLOGIES CO., LTD. 中国制造 MADE IN CHINA  
HQ of Huawei, Bantian, Longgang District, Shenzhen, 518129, P.R.C



型号 Model: SUN2000-115KTL-M2  
名称 Name: 太阳能光伏逆变器  
SOLAR INVERTER

最大输入电压 d.c.Max.Input Voltage: 1100 Vd.c.  
最大输入电流 d.c.Max.Input Current: 10x30 A  
输入短路电流 Isc: 10x40 A  
MPPT电压范围 d.c. MPPT Range: 200 – 1000 Vd.c.  
输出电压 a.c. Output Nominal Voltage: 400 Va.c., 3(N)~ +⊕  
480 Va.c., 3~ +⊕

输出频率 a.c. Nominal Operating Frequency: 50/60 Hz  
额定输出功率 a.c. Output Rated Power: 115 kW  
最大视在功率 a.c. Max.Output Apparent Power: 125 kVA  
最大输出电流 a.c. Max.Output Current: 182.3 A; 400 Va.c.  
151.9 A; 480 Va.c.

功率因数 Power Factor: 0.8(lagging) - 0.8(leading)  
温度范围 Operating Temperature Range: - 25 – + 60 °C  
逆变器拓扑 Inverter Topology: Non - Isolation  
防护等级 Enclosure: IP66  
保护等级 Protection Class: I  
过电压类别 Overvoltage Category: II(DC)/III(AC)  
污染等级 Pollution Degree: III  
海拔 Altitude: 4000 m  
通讯方式 Communication: RS485





华为技术有限公司 HUAWEI TECHNOLOGIES CO., LTD. 中国制造 MADE IN CHINA  
HQ of Huawei, Bantian, Longgang District, Shenzhen, 518129, P.R.C

**Produktbeschreibung**  
**Product description**

**Product description:**

The equipment with model name SUN2000-100KTL-M2 and SUN2000-115KTL-M2 are three phase non-isolated type Solar Inverter which will be installed and connected to the grid network.


The equipment shall be fixed to suitable manner as specified in the installation instruction.

The EUTs contains filters for smoothing the output voltage and for EMC, switching and control circuits. Electronic circuits are mounted on a number of PCBs interconnected by appropriate connectors and wires. Power board including electronics components is mounted on the heat sink to earthing by metal screw and spring washer.

For all models the PV input combiner 10 string MPPT tracers, each MPPT tracer including 2 pair of PV input terminals. DC battery terminals connected to Battery. AC output direct connected to grid or load and protective Earthing are provided by dedicated earthing terminals. Grid is protected combination with a two series of relays as redundant build for ensure the inverter can independent disconnected from grid while a relay was fault.

During fault condition defined in this standard, after the DSP receives the abnormal signal from the relevant protective detection circuit, the relays will operate to disconnect the DC active lines from grid automatically.

The master DSP and slaver MCU have capacity independently to disconnect from grid, when any grid fault had happened.



Block Diagram

IS12P00001

**Model Difference:**

The models SUN2000-100KTL-M2 and SUN2000-115KTL-M2 are same as the construction, hardware and software, except the output power is different due to be adjusted by software.




**Produktbeschreibung**  
**Product description**

**Remote control and logical interface:**

Remote control and logical interface is through RS485/USB.

**PAVE monitoring device and scheme:**



The user can set the export limit(SmartLogger and Meter) through the monitoring platform of the PV inverter to control the power output from the inverter to the grid.

Export Restriction Control Procedures:

- 1.Select Export limitation setting
- 2.Enter password: XXX
- 3.Select setup type and enter the export limit value

SmartLogger and Meter:

Meter Model: DTSU666-HW

SmartLogger Model: SmartLogger3000

Model list:

MODELS LIST		SUN2000-100KTLM2	SUN2000-115KTLM2
PV INPUT	V <sub>MAX</sub> PV [Vdc]	1100	
	I <sub>SC</sub> PV [A]	40*10	
	MPPT Voltage Range V <sub>MPP</sub> [Vdc]	200-1000	
	Max. Input Current I <sub>MAX</sub> [A] (A/B) (each MPPT if more than 1)	30*10	
	MPPT Full Power Voltage Range [Vdc]	540-800	
	Number of MPPT	10	
	String per MPPT(+/-)	2/2	
	Backfeed Current [A]	0	
	Overvoltage Category (OVC)	II	

Prüfbericht-Nr.: CN224DKW 001  
Test Report No.:

Seite 6 von 9  
Page 6 of 9

**Produktbeschreibung**  
**Product description**

<b>AC Side(ON-Grid)</b>	Rated Output Voltage Ur [Vac]	3L/N/PE, 230/400	
	Rated Output Frequency F <sub>NETZ</sub> [Hz]	50/60	
	Rated Output Power P <sub>E</sub> [kW]	100	115
	Max. Output Power P <sub>E</sub> [kW]	110	125
	Max. Apparent power S <sub>E<sub>max</sub></sub> [kVA]	110	125
	Rated Output Current I <sub>r</sub> [A]	144.4	166.0
	Max. Output Current I <sub>max</sub> [A]	160.4	182.3
	Power Factor cosφ [λ]	0.8 leading ~0.8lagging	
	THD [V / I] (100% full power)	<3%	
	Overvoltage Category (OVC)	III	
<b>System parameters</b>	Type of inverter	Non-isolated	
	Firmware [Version]	V500R023	
	Software [Version]	V500R023C00SPC010	
	Type of NS Protection	Integrated	
	Separated by	Transformerless	
	Protective Class	Class I	
	Enclosure Protection (IP)	IP66	
	Operating Temperature Range [°C]	-25°C to +60°C	
	Pollution degree (PD)	PD3	
	Altitude [m]	4000m	
	Size(W*H*D) [mm]	1035*700*365	
	Weight [kg]	93	
Note:			

**Prüfbericht-Nr.:** CN224DKW 001  
*Test Report No.:*

Seite 7 von 9  
Page 7 of 9

**Produktbeschreibung**  
*Product description*

<b>2</b>	<b>Maße / Gewicht</b> <i>Dimensions / Weight</i>	See models list
<b>3</b>	<b>Bedienelemente</b> <i>Operating elements</i>	N/A
<b>4</b>	<b>Ausstattung / Zubehör</b> <i>Equipment / Accessories</i>	N/A
<b>5</b>	<b>Verwendete Materialien</b> <i>Used materials</i>	N/A
<b>6</b>	<b>Sonstiges</b> <i>Other</i>	N/A

**Prüfbericht-Nr.:** CN224DKW 001  
*Test Report No.:*

Seite 8 von 9  
Page 8 of 9

Absatz	Anforderungen - Prüfungen	Messergebnisse - Bemerkungen	Bewertung
Clause	Requirements - Tests	Measuring results - Remarks	Evaluation

<b>1</b>	<p><b>Anwendungsbereich</b> <b>Scope</b></p> <p>Details zur Ausgestaltung der messtechnischen Nachweise und zur Dokumentation der Messergebnisse sind in DIN VDE-V 0124-100 (VDE V 0124-100):2020-06 beschrieben.</p> <p><b><i>Details on the design of the measuring certificates and the documentation of the measurement results are described in DIN VDE-V 0124-100 (VDE V 0124-100):2020-06.</i></b></p>		
----------	---	--	--

**ANLAGE zum Prüfbericht-Nr.:** CN224DKW 001  
*APPENDIX to Test Report No.:*

Seite 9 von 9  
Page 9 of 9

**ZUSATZ-DOKUMENTATION**  
***ADDITIONAL DOCUMENTATION***

**List of Appendix :**

- CN224DKW 001 attachment 1–VDE V 0124-100: 2020 Test report
- CN224DKW 001 attachment 2– Photo documentation

-End of test report-



<b>Prüfbericht-Nr.:</b> <i>Test Report No.:</i>	See test report CN224DKW 001	<b>Auftrags-Nr.:</b> <i>Order No.:</i>	See test report CN224DKW 001	Seite 1 von 153 <i>Page 1 of 153</i>	
<b>Kunden-Referenz-Nr.:</b> <i>Client Reference No.:</i>	See test report CN224DKW 001	<b>Auftragsdatum:</b> <i>Order date:</i>	See test report CN224DKW 001		
<b>Auftraggeber:</b> <i>Client:</i>	See test report CN224DKW 001				
<b>Prüfgegenstand:</b> <i>Test item:</i>	See test report CN224DKW 001				
<b>Bezeichnung / Typ-Nr.:</b> <i>Identification / Type No.:</i>	See test report CN224DKW 001				
<b>Auftrags-Inhalt:</b> <i>Order content:</i>	A3 certificate				
<b>Prüfgrundlage:</b> <i>Test specification:</i>	DIN VDE V 0124-100/06.20  <i>Netzintegration von Erzeugungsanlagen –Niederspannung –Prüfanforderungen an Erzeugungseinheiten vorgesehen zum Anschluss und Parallelbetrieb am Niederspannungsnetz</i>  <i>Grid integration of generator plants – Low-voltage – Test requirements for generator units to be connected to and operated in parallel with low-voltage distribution networks</i>				
<b>Wareneingangsdatum:</b> <i>Date of receipt:</i>	See test report CN224DKW 001	See test report CN224DKW 001			
<b>Prüfmuster-Nr.:</b> <i>Test sample No.:</i>	See test report CN224DKW 001				
<b>Prüfzeitraum:</b> <i>Testing period:</i>	See test report CN224DKW 001				
<b>Ort der Prüfung:</b> <i>Place of testing:</i>	See test report CN224DKW 001				
<b>Prüflaboratorium:</b> <i>Testing laboratory:</i>	See test report CN224DKW 001				
<b>Prüfergebnis*:</b> <i>Test result*:</i>	Pass				
<b>erstellt von: / created by:</b>		<b>genehmigt von: / authorized by:</b>			
See test report CN224DKW 001		See test report CN224DKW 001			
<b>Datum</b> <i>Date</i>	<b>Name / Stellung</b> <i>Name / Position</i>	<b>Unterschrift</b> <i>Signature</i>	<b>Datum</b> <i>Date</i>	<b>Name / Stellung</b> <i>Name / Position</i>	<b>Unterschrift</b> <i>Signature</i>
<b>Sonstiges / Other:</b>					
<b>Zustand des Prüfgegenstandes bei Anlieferung:</b> <i>Condition of the test item at delivery:</i>			Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>		
* Legende P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet * Legend: P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested					
<b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b> <i>This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark.</i>					

**Prüfbericht-Nr.:** CN224DKW 001 Attachment 1  
*Test Report No.:*

Seite 2 von 153  
*Page 2 of 153*

**Liste der verwendeten Prüfmittel**  
***List of used test equipment***

See test report CN224DKW 001

**Prüfbericht-Nr.:** CN224DKW 001 Attachment 1  
*Test Report No.:*

Seite 3 von 153  
Page 3 of 153

**Produktbeschreibung**  
*Product description*

See test report CN224DKW 001

**Prüfbericht-Nr.:** CN224DKW 001 Attachment 1  
*Test Report No.:*

Seite 4 von 153  
Page 4 of 153

Absatz	Anforderungen-Prüfungen	Messergebnisse-Bemerkungen	Bewertung
Clause	Requirements-Tests	Measuring results-Remarks	Evaluation

<b>1</b>	<b>Anwendungsbereich</b> <b>Scope</b>		
	Diese DIN-VDE-Vornorm dient dem Nachweis der elektrischen Eigenschaften von Erzeugungseinheiten (EZE) nach der VDE-AR N 4105:2018-11 und gegebenenfalls anderen Netzanschlussbedingungen. <i>This DIN VDE preliminary standard serves to verify the electrical properties of power generation units (PGU) in accordance with VDE-AR N 4105:2018-11 and, if applicable, other grid connection conditions.</i>		
<b>5</b>	<b>Prüfungen</b> <b>Tests</b>		
<b>5.1</b>	<b>Allgemeines</b> <b>General information</b>		<b>P</b>
<b>5.2</b>	<b>Nachweis zulässiger Netzrückwirkungen</b> <b>Verification of permitted network reaction</b>		<b>P</b>
<b>5.3</b>	<b>Nachweis des Symmetrieverhaltens von Umrichtern</b> <b>Verification of symmetry behaviour of inverter</b>		<b>P</b>
<b>5.4</b>	<b>Nachweis des Verhaltens der Erzeugungseinheit am Netz</b> <b>Verification of behaviours of PGU on grid</b>		<b>P</b>
<b>5.5</b>	<b>Nachweis des NA-Schutzes</b> <b>Verification of NS-protections</b>		<b>P</b>
<b>5.6</b>	<b>Zuschaltbedingungen und Synchronisierung</b> <b>Connection conditions and synchronuzation</b>		<b>P</b>
<b>5.7</b>	<b>Nachweis der PAV,E-überwachung</b> <b>Verification of PAV,E-monitoring</b>		<b>P</b>
<b>5.8</b>	<b>Nachweis der dynamischen Netzstützung</b> <b>Verification of dynamic network support</b>		<b>P</b>

**Prüfbericht-Nr.:** CN224DKW 001 Attachment 1  
*Test Report No.:*

Seite 5 von 153  
*Page 5 of 153*

**ZUSATZ-DOKUMENTATION**  
***ADDITIONAL DOCUMENTATION***

See following pages for test data.



**Prüfbericht-Nr.:**  
 Test report no.:


**CN224DKW 001 Attachment 1**

 Seite 6 von 153  
 Page 6 of 153


Test Engineer:	See cover page	Reviewer:	See cover page
Signature:	See cover page	Signature:	See cover page

Testing Location: See cover page	
Name:	See cover page
Address:	See cover page

Test Sample No.:	See cover page
------------------	----------------

Test Condition:	Generator reference system applied in test: 
-----------------	---

Test Date:	See cover page
------------	----------------

Test bench diagram:  <p>A network model (grid impedance simulator) only connected in test bench in flicker test (&lt;75A condition), in the other tests the network model is bypassed.</p>
---

**Prüfbericht-Nr.:**  
Test report no.:

**CN224DKW 001 Attachment 1**

Seite 7 von 153  
Page 7 of 153

Test items	Remark
5.2 Verification of permitted network reaction	
5.2.2 Rapid voltage change (Kimax)	
5.2.3 Flicker	
5.2.4 Harmonics and Inter-harmonics (I inter, I higher)	
5.2.5 Commutation notches	
5.2.6 DC current feeding to network (Idc)	
5.3 Verification of symmetry behaviours of inverter	
5.3.2 Tests of three-phase inverter (Imbalance)	
5.3.3 Symmetry operation with a symmetry device	
5.4 Verification of behaviours of PGU on network	
5.4.2 Measurement of active- and reactive power ranges (P&Q range)	
5.4.3 Active power reduction through setting provision (P control)	
5.4.4 Active power output of PGU by over-frequency (LFSM-O)	
5.4.5 Active power output of ESS by over-frequency (LFSM-O)	
5.4.6 Active power output of PGU by under-frequency (LFSM-U)	
5.4.7 Active power output of ESS by under-frequency (LFSM-U)	
5.4.8.2 Tests of reactive power / displacement factor setting accuracy (Fixed $\cos\phi$ )	
5.4.8.3 Tests of displacement factor- / active power character curve ( $\cos\phi(P)$ )	
5.4.8.4 Tests of reactive power-voltage character curve (Q(U))	
5.5 Verification of NS-protection	
5.5.2 NS-protection	
5.5.3 Central NS-protecton	
5.5.4 Integrated NS-protection	
5.5.6 Interface switch (Functional safety)	
5.5.7 Protection devices and protection settings (OV/UV, OF/UF)	
5.5.9 Constructional features of NS protection	
5.5.10 Islanding detection	
5.6 Connection conditions and synchronization (Reconnection)	
5.7 Verification of $P_{AV,E}$ monitoring	
5.8 Verification of dynamic network supporting (FVRT)	

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 8 von 153  
 Page 8 of 153

5.2.2	TABLE: Rapid voltage change (Kimax)			P
Test Conditions	Measurements			Limit
	U [V]	I [A]	Ki	Ki
Starting to 50%Pn	230.41	83.27	1.003	≤ 1.2
Starting to 100% Pn	231.01	183.77	1.106	≤ 1.2
Stopping at 100% Pn	231.01	175.12	1.054	≤ 1.2
Note(s):				

5.2.3	TABLE: Flicker							P
SUN2000-115KTL-M2								
L1								
Test Condition	Measurement							
	30°		50°		70°		85°	
P/Pn [%]	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00057	0.00071	0.00053	0.00053	0.00050	0.00068	0.00049	0.00018
20	0.01612	0.02004	0.01518	0.01503	0.01437	0.01949	0.01408	0.00511
30	0.00058	0.00072	0.00055	0.00054	0.00052	0.00071	0.00051	0.00019
40	0.00057	0.00071	0.00054	0.00054	0.00052	0.00071	0.00052	0.00019
50	0.00058	0.00072	0.00056	0.00055	0.00054	0.00074	0.00053	0.00019
60	0.00059	0.00073	0.00056	0.00055	0.00054	0.00073	0.00053	0.00019
70	0.00058	0.00072	0.00056	0.00056	0.00055	0.00074	0.00054	0.00020
80	0.00078	0.00097	0.00070	0.00069	0.00061	0.00083	0.00058	0.00021
90	0.00076	0.00094	0.00069	0.00068	0.00062	0.00084	0.00060	0.00022
100	0.00080	0.00099	0.00073	0.00073	0.00067	0.00091	0.00066	0.00024
100	0.00075	0.00093	0.00070	0.00069	0.00065	0.00088	0.00064	0.00023
100	0.00074	0.00091	0.00069	0.00068	0.00066	0.00089	0.00066	0.00024
L2								
Test Condition	Measurement							
	30°		50°		70°		85°	
P/Pn [%]	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00058	0.00072	0.00054	0.00053	0.00051	0.00069	0.00050	0.00018
20	0.01632	0.02029	0.01532	0.01518	0.01448	0.01964	0.01418	0.00514
30	0.00058	0.00072	0.00055	0.00054	0.00052	0.00071	0.00051	0.00019
40	0.00058	0.00072	0.00055	0.00055	0.00053	0.00072	0.00052	0.00019
50	0.00057	0.00071	0.00056	0.00055	0.00054	0.00073	0.00053	0.00019
60	0.00060	0.00074	0.00057	0.00056	0.00054	0.00074	0.00053	0.00019
70	0.00059	0.00074	0.00057	0.00057	0.00056	0.00075	0.00055	0.00020
80	0.00077	0.00096	0.00068	0.00068	0.00060	0.00081	0.00057	0.00021
90	0.00077	0.00095	0.00070	0.00069	0.00063	0.00085	0.00061	0.00022
100	0.00082	0.00102	0.00074	0.00073	0.00066	0.00089	0.00064	0.00023
100	0.00071	0.00088	0.00066	0.00065	0.00063	0.00085	0.00062	0.00023
100	0.00076	0.00095	0.00069	0.00069	0.00064	0.00087	0.00063	0.00023
L3								
Test Condition	Measurement							

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 9 von 153  
 Page 9 of 153

P/Pn [%]	30°		50°		70°		85°	
	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00058	0.00072	0.00054	0.00053	0.00051	0.00069	0.00050	0.00018
20	0.01608	0.01998	0.01504	0.01490	0.01421	0.01927	0.01394	0.00505
30	0.00057	0.00071	0.00054	0.00053	0.00051	0.00070	0.00050	0.00018
40	0.00057	0.00070	0.00054	0.00054	0.00052	0.00071	0.00052	0.00019
50	0.00057	0.00070	0.00055	0.00054	0.00053	0.00072	0.00053	0.00019
60	0.00059	0.00074	0.00057	0.00056	0.00054	0.00073	0.00053	0.00019
70	0.00059	0.00073	0.00057	0.00056	0.00055	0.00075	0.00055	0.00020
80	0.00078	0.00097	0.00069	0.00068	0.00061	0.00082	0.00058	0.00021
90	0.00076	0.00094	0.00069	0.00068	0.00062	0.00084	0.00060	0.00022
100	0.00083	0.00104	0.00076	0.00075	0.00068	0.00092	0.00065	0.00023
100	0.00076	0.00094	0.00068	0.00068	0.00063	0.00086	0.00062	0.00022
100	0.00080	0.00099	0.00074	0.00073	0.00067	0.00091	0.00065	0.00023
<b>SUN2000-100KTL-M2</b>								
L1								
Test Condition	Measurement							
	30°		50°		70°		85°	
P/Pn [%]	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00057	0.00071	0.00053	0.00053	0.00050	0.00068	0.00049	0.00018
20	0.00058	0.00072	0.00054	0.00054	0.00051	0.00070	0.00050	0.00018
30	0.00058	0.00072	0.00055	0.00054	0.00052	0.00071	0.00051	0.00019
40	0.00057	0.00071	0.00054	0.00054	0.00052	0.00071	0.00052	0.00019
50	0.00058	0.00072	0.00056	0.00055	0.00054	0.00074	0.00053	0.00019
60	0.00059	0.00073	0.00056	0.00055	0.00054	0.00073	0.00053	0.00019
70	0.00058	0.00072	0.00056	0.00056	0.00055	0.00074	0.00054	0.00020
80	0.00078	0.00097	0.00070	0.00069	0.00061	0.00083	0.00058	0.00021
90	0.00076	0.00094	0.00069	0.00068	0.00062	0.00084	0.00060	0.00022
100	0.00077	0.00096	0.00071	0.00070	0.00066	0.00089	0.00064	0.00023
100	0.00077	0.00096	0.00071	0.00070	0.00066	0.00089	0.00064	0.00023
100	0.00077	0.00096	0.00071	0.00070	0.00066	0.00089	0.00064	0.00023
L2								
Test Condition	Measurement							
	30°		50°		70°		85°	
P/Pn [%]	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00058	0.00072	0.00054	0.00053	0.00051	0.00069	0.00050	0.00018
20	0.00058	0.00072	0.00055	0.00054	0.00052	0.00070	0.00051	0.00018
30	0.00058	0.00072	0.00055	0.00054	0.00052	0.00071	0.00051	0.00019
40	0.00058	0.00072	0.00055	0.00055	0.00053	0.00072	0.00052	0.00019
50	0.00057	0.00071	0.00056	0.00055	0.00054	0.00073	0.00053	0.00019
60	0.00060	0.00074	0.00057	0.00056	0.00054	0.00074	0.00053	0.00019
70	0.00059	0.00074	0.00057	0.00057	0.00056	0.00075	0.00055	0.00020
80	0.00077	0.00096	0.00068	0.00068	0.00060	0.00081	0.00057	0.00021
90	0.00077	0.00095	0.00070	0.00069	0.00063	0.00085	0.00061	0.00022

**Prüfbericht-Nr.:**  
Test report no.:

**CN224DKW 001 Attachment 1**

Seite 10 von 153  
Page 10 of 153

100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00064	0.00023
100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00064	0.00023
100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00064	0.00023
L3								
Test Condition	Measurement							
	30°		50°		70°		85°	
P/Pn [%]	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>	Pst	C <sub>ψk</sub>
10	0.00058	0.00072	0.00054	0.00053	0.00051	0.00069	0.00050	0.00018
20	0.00057	0.00071	0.00054	0.00053	0.00051	0.00069	0.00050	0.00018
30	0.00057	0.00071	0.00054	0.00053	0.00051	0.00070	0.00050	0.00018
40	0.00057	0.00070	0.00054	0.00054	0.00052	0.00071	0.00052	0.00019
50	0.00057	0.00070	0.00055	0.00054	0.00053	0.00072	0.00053	0.00019
60	0.00059	0.00074	0.00057	0.00056	0.00054	0.00073	0.00053	0.00019
70	0.00059	0.00073	0.00057	0.00056	0.00055	0.00075	0.00055	0.00020
80	0.00078	0.00097	0.00069	0.00068	0.00061	0.00082	0.00058	0.00021
90	0.00076	0.00094	0.00069	0.00068	0.00062	0.00084	0.00060	0.00022
100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00063	0.00023
100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00063	0.00023
100	0.00079	0.00098	0.00072	0.00071	0.00066	0.00089	0.00063	0.00023
Note(s):								

5.2.4	TABLE: Harmonics and inter-harmonics										P
<b>SUN2000-115KTL-M2</b>											
Harmonics											
P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order No.	I <sub>ln</sub> [%]										
2	0.560	0.186	0.109	0.121	0.145	0.139	0.120	0.114	0.115	0.126	0.124
3	0.688	0.144	0.054	0.079	0.137	0.099	0.153	0.119	0.150	0.107	0.101
4	1.328	0.290	0.138	0.101	0.084	0.077	0.063	0.070	0.051	0.032	0.029
5	0.834	0.185	0.203	0.139	0.181	0.112	0.331	0.184	0.118	0.275	0.444
6	1.194	0.290	0.134	0.086	0.078	0.069	0.053	0.068	0.060	0.046	0.048
7	0.856	0.206	0.200	0.125	0.169	0.155	0.234	0.100	0.133	0.242	0.453
8	0.796	0.185	0.086	0.056	0.046	0.036	0.028	0.019	0.025	0.026	0.021
9	0.467	0.083	0.041	0.028	0.064	0.111	0.053	0.060	0.033	0.035	0.066
10	0.258	0.067	0.035	0.022	0.018	0.022	0.016	0.015	0.014	0.015	0.023
11	0.429	0.110	0.063	0.081	0.099	0.129	0.134	0.086	0.077	0.205	0.104
12	0.249	0.071	0.028	0.020	0.015	0.016	0.017	0.017	0.017	0.019	0.013
13	0.329	0.082	0.048	0.053	0.047	0.126	0.124	0.077	0.066	0.128	0.144
14	0.398	0.083	0.041	0.027	0.025	0.026	0.020	0.022	0.014	0.016	0.020
15	0.628	0.083	0.053	0.025	0.035	0.064	0.062	0.034	0.042	0.037	0.037
16	0.288	0.064	0.033	0.019	0.015	0.016	0.013	0.011	0.010	0.012	0.015
17	0.655	0.134	0.111	0.138	0.148	0.181	0.210	0.144	0.116	0.119	0.147



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 11 von 153  
 Page 11 of 153

18	0.275	0.063	0.026	0.018	0.016	0.015	0.012	0.012	0.012	0.013	0.010
19	0.352	0.082	0.083	0.107	0.108	0.126	0.164	0.144	0.152	0.163	0.179
20	0.238	0.050	0.025	0.020	0.017	0.016	0.014	0.012	0.013	0.012	0.012
21	0.653	0.097	0.061	0.050	0.086	0.068	0.075	0.048	0.068	0.070	0.065
22	0.298	0.064	0.030	0.040	0.026	0.024	0.015	0.014	0.011	0.013	0.013
23	0.723	0.094	0.079	0.099	0.151	0.170	0.173	0.159	0.129	0.108	0.158
24	0.307	0.070	0.040	0.047	0.034	0.030	0.023	0.022	0.016	0.017	0.010
25	0.588	0.111	0.095	0.111	0.106	0.141	0.178	0.172	0.210	0.191	0.157
26	0.649	0.130	0.060	0.021	0.016	0.015	0.015	0.019	0.019	0.017	0.011
27	0.749	0.157	0.087	0.051	0.101	0.067	0.077	0.073	0.073	0.076	0.098
28	0.667	0.155	0.042	0.022	0.016	0.015	0.012	0.013	0.015	0.021	0.018
29	0.959	0.174	0.074	0.092	0.135	0.203	0.172	0.167	0.148	0.151	0.186
30	0.282	0.076	0.032	0.022	0.017	0.016	0.014	0.014	0.017	0.020	0.020
31	0.663	0.158	0.085	0.092	0.123	0.233	0.218	0.237	0.234	0.200	0.160
32	0.264	0.061	0.031	0.021	0.016	0.015	0.019	0.015	0.014	0.012	0.012
33	1.268	0.210	0.094	0.042	0.051	0.058	0.075	0.093	0.075	0.071	0.097
34	0.266	0.059	0.030	0.020	0.018	0.014	0.013	0.012	0.013	0.017	0.012
35	1.219	0.149	0.055	0.082	0.135	0.176	0.178	0.182	0.159	0.173	0.204
36	0.268	0.062	0.028	0.020	0.018	0.016	0.014	0.016	0.016	0.021	0.017
37	0.648	0.249	0.092	0.084	0.140	0.219	0.208	0.223	0.233	0.194	0.136
38	0.253	0.063	0.027	0.018	0.016	0.016	0.015	0.017	0.016	0.018	0.021
39	1.311	0.314	0.183	0.088	0.037	0.026	0.065	0.074	0.066	0.058	0.068
40	0.364	0.086	0.035	0.020	0.015	0.016	0.014	0.015	0.020	0.027	0.022

**SUN2000-100KTL-M2**

Harmonics

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100
Order No.	I/In [%]										
2	1.469	0.540	0.227	0.163	0.140	0.083	0.090	0.094	0.113	0.084	0.089
3	1.786	0.399	0.397	0.385	0.241	0.151	0.249	0.162	0.046	0.097	0.115
4	1.370	0.350	0.209	0.176	0.145	0.094	0.088	0.124	0.150	0.110	0.121
5	6.408	0.979	0.734	0.493	0.350	0.412	0.461	0.305	0.209	0.164	0.066
6	1.030	0.252	0.133	0.096	0.077	0.057	0.045	0.040	0.037	0.026	0.024
7	6.707	0.335	0.446	0.426	0.321	0.322	0.547	0.270	0.090	0.082	0.056
8	0.524	0.103	0.069	0.050	0.042	0.032	0.028	0.046	0.029	0.019	0.023
9	1.940	0.292	0.310	0.320	0.273	0.044	0.104	0.102	0.054	0.036	0.027
10	0.515	0.117	0.104	0.064	0.044	0.025	0.027	0.032	0.031	0.030	0.025
11	21.45	2.445	2.584	1.612	1.096	0.255	0.212	0.118	0.121	0.062	0.115
12	0.760	0.216	0.205	0.157	0.111	0.022	0.028	0.026	0.020	0.023	0.020
13	20.31	2.475	2.568	1.586	1.051	0.338	0.314	0.167	0.088	0.114	0.074
14	0.435	0.098	0.093	0.062	0.042	0.022	0.016	0.017	0.022	0.022	0.032
15	1.736	0.278	0.358	0.339	0.293	0.093	0.091	0.109	0.095	0.071	0.044
16	0.492	0.105	0.065	0.047	0.036	0.030	0.023	0.020	0.014	0.013	0.011

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 12 von 153  
 Page 12 of 153

17	3.173	0.387	0.160	0.192	0.199	0.207	0.179	0.199	0.198	0.185	0.222
18	0.444	0.088	0.069	0.048	0.035	0.020	0.017	0.017	0.013	0.016	0.019
19	2.126	0.163	0.319	0.244	0.290	0.159	0.151	0.220	0.202	0.171	0.158
20	0.468	0.086	0.063	0.041	0.029	0.017	0.018	0.021	0.025	0.023	0.016
21	1.073	0.290	0.207	0.202	0.157	0.064	0.091	0.100	0.096	0.075	0.069
22	0.463	0.097	0.070	0.043	0.030	0.027	0.023	0.026	0.026	0.040	0.034
23	1.779	0.378	0.487	0.320	0.240	0.158	0.131	0.114	0.161	0.179	0.178
24	0.692	0.121	0.123	0.083	0.053	0.019	0.017	0.022	0.022	0.016	0.015
25	2.288	0.406	0.490	0.344	0.273	0.191	0.129	0.202	0.197	0.188	0.202
26	0.684	0.169	0.094	0.051	0.033	0.029	0.023	0.022	0.027	0.029	0.023
27	1.660	0.215	0.252	0.226	0.165	0.066	0.078	0.063	0.083	0.079	0.073
28	0.500	0.167	0.085	0.060	0.045	0.039	0.035	0.033	0.032	0.033	0.027
29	3.021	0.364	0.154	0.107	0.134	0.126	0.131	0.108	0.175	0.181	0.183
30	0.515	0.098	0.060	0.040	0.043	0.024	0.019	0.030	0.034	0.026	0.026
31	2.109	0.186	0.167	0.143	0.153	0.135	0.150	0.196	0.224	0.205	0.209
32	0.489	0.102	0.055	0.039	0.029	0.021	0.019	0.022	0.023	0.029	0.024
33	1.638	0.294	0.152	0.140	0.110	0.072	0.047	0.052	0.069	0.075	0.070
34	0.357	0.098	0.055	0.035	0.029	0.026	0.030	0.030	0.033	0.032	0.028
35	4.039	0.633	0.307	0.159	0.123	0.127	0.152	0.152	0.165	0.181	0.170
36	0.450	0.097	0.055	0.038	0.029	0.024	0.020	0.020	0.023	0.023	0.024
37	2.682	0.409	0.260	0.169	0.128	0.123	0.114	0.176	0.221	0.207	0.202
38	0.450	0.085	0.049	0.037	0.035	0.023	0.022	0.029	0.023	0.023	0.021
39	1.210	0.358	0.203	0.153	0.124	0.098	0.053	0.049	0.068	0.067	0.060
40	0.421	0.120	0.062	0.039	0.035	0.031	0.029	0.031	0.029	0.025	0.024

Note(s): The max. value of three phases were chosen.

<b>SUN2000-115KTL-M2</b>												
Inter-harmonics												
P/Pn [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [Hz]	I/In [%]											
75	1.566	0.355	0.154	0.147	0.110	0.113	0.093	0.096	0.113	0.090	0.078	--
125	1.691	0.372	0.158	0.144	0.110	0.082	0.087	0.091	0.093	0.082	0.071	--
175	0.864	0.200	0.098	0.153	0.122	0.127	0.107	0.110	0.115	0.109	0.092	--
225	0.754	0.153	0.074	0.116	0.092	0.089	0.091	0.124	0.129	0.089	0.067	--
275	0.807	0.169	0.094	0.134	0.147	0.104	0.201	0.173	0.142	0.156	0.193	--
325	0.683	0.146	0.077	0.121	0.105	0.063	0.100	0.128	0.128	0.125	0.133	--
375	0.734	0.152	0.085	0.099	0.122	0.041	0.155	0.141	0.109	0.142	0.185	--
425	0.695	0.155	0.078	0.101	0.081	0.037	0.075	0.053	0.047	0.106	0.125	--
475	0.679	0.158	0.073	0.062	0.048	0.060	0.039	0.035	0.032	0.036	0.041	--
525	0.734	0.163	0.073	0.058	0.044	0.050	0.033	0.033	0.029	0.030	0.030	--
575	0.774	0.164	0.079	0.079	0.068	0.059	0.067	0.061	0.056	0.063	0.064	--
625	0.736	0.173	0.085	0.094	0.064	0.050	0.055	0.043	0.040	0.063	0.072	--

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 13 von 153  
 Page 13 of 153

675	0.743	0.170	0.081	0.079	0.067	0.041	0.063	0.058	0.054	0.064	0.062	--
725	0.814	0.187	0.090	0.099	0.067	0.040	0.054	0.041	0.038	0.064	0.076	--
775	0.812	0.192	0.089	0.061	0.051	0.043	0.034	0.031	0.029	0.030	0.030	--
825	0.847	0.200	0.091	0.060	0.051	0.044	0.033	0.030	0.028	0.028	0.027	--
875	0.884	0.206	0.094	0.063	0.054	0.046	0.036	0.031	0.029	0.030	0.030	--
925	0.881	0.207	0.097	0.066	0.055	0.046	0.036	0.032	0.030	0.030	0.027	--
975	0.884	0.207	0.100	0.064	0.056	0.051	0.038	0.034	0.030	0.030	0.028	--
1025	0.905	0.212	0.103	0.067	0.058	0.077	0.038	0.035	0.031	0.030	0.027	--
1075	0.938	0.217	0.107	0.076	0.061	0.128	0.038	0.035	0.031	0.029	0.026	--
1125	1.005	0.235	0.110	0.131	0.092	0.131	0.047	0.036	0.032	0.030	0.027	--
1175	1.036	0.243	0.113	0.217	0.157	0.122	0.080	0.048	0.035	0.033	0.030	--
1225	1.026	0.238	0.133	0.213	0.162	0.067	0.106	0.084	0.045	0.035	0.030	--
1275	1.171	0.255	0.231	0.194	0.152	0.055	0.109	0.095	0.070	0.045	0.030	--
1325	1.980	0.390	0.340	0.103	0.088	0.058	0.085	0.091	0.082	0.067	0.031	--
1375	2.516	0.602	0.312	0.085	0.058	0.060	0.049	0.057	0.077	0.075	0.037	--
1425	2.228	0.633	0.279	0.089	0.060	0.059	0.047	0.041	0.052	0.069	0.054	--
1475	1.840	0.570	0.144	0.093	0.062	0.059	0.049	0.043	0.041	0.049	0.070	--
1525	0.998	0.371	0.124	0.088	0.064	0.062	0.050	0.044	0.041	0.041	0.067	--
1575	0.890	0.245	0.124	0.082	0.066	0.058	0.051	0.045	0.043	0.041	0.055	--
1625	0.857	0.228	0.120	0.077	0.067	0.062	0.051	0.046	0.044	0.042	0.039	--
1675	0.783	0.202	0.110	0.073	0.066	0.061	0.051	0.047	0.043	0.041	0.038	--
1725	0.751	0.189	0.107	0.075	0.069	0.060	0.053	0.047	0.045	0.043	0.041	--
1775	0.746	0.185	0.098	0.071	0.066	0.058	0.054	0.049	0.048	0.048	0.043	--
1825	0.733	0.187	0.093	0.068	0.065	0.061	0.055	0.051	0.051	0.049	0.044	--
1875	0.704	0.175	0.092	0.066	0.061	0.055	0.058	0.055	0.052	0.051	0.046	--
1925	0.683	0.173	0.088	0.063	0.058	0.057	0.057	0.055	0.056	0.049	0.072	--
1975	0.675	0.190	0.081	0.061	0.054	0.052	0.058	0.059	0.051	0.052	0.073	--
<b>SUN2000-100KTL-M2</b>												
Inter-harmonics												
P/Pn [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [Hz]	I/In [%]											
75	3.987	1.124	0.624	0.466	0.350	0.151	0.125	0.106	0.078	0.061	0.055	--
125	3.473	0.774	0.724	0.423	0.339	0.145	0.122	0.105	0.080	0.062	0.058	--
175	4.310	1.219	0.427	0.515	0.374	0.136	0.117	0.107	0.105	0.051	0.034	--
225	2.201	0.458	0.689	0.330	0.267	0.117	0.108	0.096	0.081	0.036	0.028	--
275	3.974	0.842	0.368	0.529	0.398	0.141	0.229	0.208	0.162	0.071	0.037	--
325	2.414	0.331	0.408	0.285	0.230	0.123	0.148	0.113	0.095	0.059	0.031	--
375	2.355	0.362	0.236	0.346	0.268	0.123	0.192	0.163	0.125	0.063	0.040	--
425	1.915	0.246	0.184	0.183	0.158	0.092	0.119	0.083	0.067	0.056	0.030	--
475	1.246	0.285	0.161	0.124	0.094	0.055	0.049	0.044	0.038	0.033	0.034	--
525	1.117	0.293	0.355	0.115	0.086	0.050	0.043	0.038	0.035	0.028	0.025	--
575	1.932	0.393	0.327	0.253	0.214	0.083	0.071	0.063	0.057	0.036	0.027	--

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 14 von 153  
 Page 14 of 153

625	1.871	0.402	0.363	0.253	0.187	0.103	0.081	0.062	0.048	0.039	0.027	--
675	1.987	0.488	0.320	0.262	0.217	0.081	0.070	0.062	0.057	0.037	0.028	--
725	1.790	0.400	0.163	0.248	0.180	0.114	0.081	0.062	0.048	0.040	0.031	--
775	1.122	0.401	0.158	0.121	0.087	0.054	0.045	0.040	0.038	0.033	0.029	--
825	1.133	0.312	0.164	0.113	0.086	0.053	0.044	0.039	0.036	0.032	0.030	--
875	1.231	0.303	0.158	0.119	0.089	0.054	0.047	0.041	0.038	0.033	0.030	--
925	1.243	0.302	0.151	0.113	0.089	0.055	0.048	0.041	0.038	0.033	0.030	--
975	1.272	0.319	0.156	0.110	0.085	0.055	0.048	0.042	0.039	0.034	0.031	--
1025	1.228	0.303	0.159	0.104	0.084	0.057	0.047	0.043	0.040	0.036	0.032	--
1075	1.237	0.326	0.168	0.108	0.082	0.057	0.046	0.043	0.040	0.035	0.032	--
1125	1.192	0.341	0.172	0.106	0.081	0.059	0.049	0.044	0.042	0.037	0.034	--
1175	1.297	0.346	0.177	0.118	0.093	0.060	0.053	0.047	0.043	0.037	0.034	--
1225	1.576	0.339	0.205	0.115	0.092	0.063	0.056	0.049	0.045	0.038	0.035	--
1275	2.102	0.417	0.329	0.122	0.097	0.066	0.056	0.050	0.047	0.040	0.036	--
1325	2.198	0.684	0.353	0.138	0.094	0.098	0.069	0.053	0.049	0.041	0.037	--
1375	1.969	0.726	0.338	0.215	0.106	0.158	0.116	0.061	0.051	0.042	0.038	--
1425	1.416	0.693	0.255	0.248	0.173	0.149	0.131	0.102	0.064	0.047	0.043	--
1475	1.281	0.502	0.182	0.232	0.195	0.137	0.124	0.122	0.104	0.070	0.067	--
1525	1.192	0.348	0.179	0.181	0.182	0.086	0.095	0.115	0.110	0.097	0.087	--
1575	1.161	0.343	0.177	0.123	0.138	0.073	0.067	0.094	0.108	0.094	0.084	--
1625	1.103	0.351	0.163	0.120	0.098	0.077	0.067	0.069	0.086	0.085	0.073	--
1675	1.072	0.320	0.157	0.120	0.093	0.075	0.066	0.068	0.069	0.063	0.057	--
1725	0.971	0.288	0.162	0.119	0.091	0.074	0.067	0.071	0.073	0.059	0.056	--
1775	0.981	0.286	0.153	0.115	0.091	0.073	0.070	0.072	0.073	0.063	0.059	--
1825	0.959	0.285	0.152	0.113	0.085	0.073	0.069	0.070	0.075	0.070	0.065	--
1875	0.967	0.279	0.145	0.106	0.086	0.068	0.065	0.074	0.097	0.106	0.096	--
1925	0.913	0.264	0.133	0.106	0.104	0.067	0.067	0.104	0.118	0.089	0.092	--
1975	0.793	0.247	0.153	0.128	0.115	0.075	0.088	0.109	0.092	0.090	0.084	--

Note(s): The max. value of three phases were chosen.

**SUN2000-115KTL-M2**

Higher frequency Harmonics

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [kHz]	I <sub>ln</sub> [%]											
2.1	2.227	0.504	0.251	0.174	0.230	0.302	0.272	0.302	0.294	0.282	0.242	--
2.3	2.156	0.497	0.265	0.205	0.222	0.209	0.189	0.195	0.161	0.155	0.179	--
2.5	1.772	0.447	0.245	0.171	0.165	0.198	0.161	0.171	0.178	0.161	0.130	--
2.7	1.862	0.345	0.189	0.150	0.164	0.197	0.174	0.165	0.160	0.146	0.155	--
2.9	1.989	0.419	0.322	0.235	0.204	0.171	0.101	0.085	0.072	0.077	0.130	--
3.1	1.646	0.304	0.226	0.183	0.170	0.150	0.161	0.163	0.171	0.149	0.103	--
3.3	1.133	0.297	0.242	0.220	0.193	0.198	0.136	0.140	0.126	0.117	0.136	--
3.5	1.329	0.373	0.157	0.159	0.138	0.156	0.173	0.182	0.192	0.172	0.157	--
3.7	1.348	0.287	0.181	0.122	0.103	0.077	0.101	0.083	0.084	0.091	0.086	--

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 15 von 153  
 Page 15 of 153

3.9	1.211	0.183	0.085	0.095	0.117	0.124	0.151	0.131	0.124	0.114	0.121	--
4.1	1.375	0.261	0.147	0.110	0.117	0.112	0.136	0.126	0.130	0.128	0.117	--
4.3	0.925	0.221	0.127	0.106	0.091	0.091	0.075	0.071	0.079	0.081	0.083	--
4.5	1.241	0.196	0.095	0.084	0.087	0.097	0.124	0.120	0.136	0.134	0.120	--
4.7	1.144	0.193	0.127	0.124	0.117	0.098	0.105	0.112	0.117	0.132	0.125	--
4.9	0.747	0.176	0.091	0.102	0.103	0.106	0.088	0.084	0.094	0.095	0.095	--
5.1	0.978	0.196	0.088	0.072	0.091	0.086	0.128	0.131	0.133	0.131	0.115	--
5.3	0.775	0.182	0.096	0.093	0.091	0.106	0.091	0.101	0.091	0.110	0.123	--
5.5	0.645	0.170	0.098	0.073	0.084	0.100	0.096	0.099	0.101	0.096	0.104	--
5.7	0.759	0.169	0.088	0.058	0.057	0.053	0.080	0.083	0.095	0.096	0.090	--
5.9	0.734	0.175	0.077	0.069	0.072	0.069	0.065	0.064	0.069	0.078	0.108	--
6.1	0.859	0.187	0.065	0.054	0.046	0.037	0.045	0.052	0.064	0.066	0.075	--
6.3	0.584	0.148	0.075	0.049	0.053	0.051	0.040	0.041	0.041	0.044	0.051	--
6.5	0.804	0.196	0.079	0.055	0.051	0.055	0.042	0.044	0.047	0.047	0.043	--
6.7	0.923	0.238	0.102	0.059	0.049	0.037	0.027	0.031	0.032	0.032	0.026	--
6.9	0.512	0.178	0.080	0.043	0.039	0.041	0.032	0.030	0.029	0.031	0.025	--
7.1	0.892	0.243	0.120	0.073	0.050	0.040	0.025	0.029	0.028	0.030	0.027	--
7.3	0.913	0.252	0.145	0.087	0.058	0.036	0.025	0.025	0.022	0.021	0.018	--
7.5	0.519	0.167	0.068	0.042	0.030	0.026	0.022	0.021	0.022	0.022	0.019	--
7.7	0.864	0.239	0.149	0.096	0.064	0.040	0.023	0.023	0.018	0.018	0.017	--
7.9	0.850	0.227	0.144	0.103	0.071	0.044	0.023	0.020	0.016	0.014	0.015	--
8.1	0.501	0.158	0.074	0.040	0.033	0.026	0.021	0.019	0.016	0.014	0.015	--
8.3	0.788	0.217	0.136	0.102	0.076	0.053	0.028	0.023	0.015	0.013	0.014	--
8.5	0.735	0.214	0.128	0.098	0.079	0.058	0.028	0.023	0.016	0.012	0.014	--
8.7	0.450	0.163	0.081	0.041	0.030	0.025	0.024	0.019	0.016	0.013	0.012	--
8.9	0.643	0.200	0.126	0.096	0.081	0.063	0.038	0.030	0.020	0.014	0.012	--

**SUN2000-100KTL-M2**

Higher frequency Harmonics

P/P <sub>n</sub> [%]	0	10	20	30	40	50	60	70	80	90	100	Limit
f [kHz]	V <sub>ln</sub> [%]											
2.1	5.022	0.875	0.469	0.320	0.223	0.244	0.273	0.279	0.287	0.267	0.266	--
2.3	3.437	0.968	0.481	0.337	0.240	0.223	0.206	0.170	0.176	0.168	0.166	--
2.5	2.147	0.647	0.309	0.241	0.201	0.196	0.200	0.202	0.207	0.190	0.190	--
2.7	3.046	0.827	0.411	0.296	0.224	0.203	0.197	0.202	0.203	0.207	0.217	--
2.9	2.721	0.852	0.447	0.346	0.289	0.207	0.175	0.157	0.165	0.160	0.147	--
3.1	1.990	0.491	0.263	0.215	0.177	0.201	0.208	0.186	0.151	0.142	0.138	--
3.3	1.932	0.514	0.366	0.285	0.258	0.244	0.199	0.199	0.189	0.167	0.148	--
3.5	1.776	0.556	0.381	0.351	0.318	0.310	0.295	0.246	0.194	0.163	0.156	--
3.7	1.578	0.279	0.223	0.198	0.164	0.160	0.167	0.148	0.132	0.122	0.118	--
3.9	1.732	0.374	0.229	0.216	0.190	0.177	0.144	0.168	0.187	0.179	0.167	--
4.1	1.621	0.272	0.214	0.203	0.177	0.184	0.175	0.170	0.157	0.148	0.137	--
4.3	1.526	0.299	0.170	0.166	0.120	0.103	0.121	0.109	0.110	0.102	0.103	--



**Prüfbericht-Nr.:**  
Test report no.:

**CN224DKW 001 Attachment 1**

Seite 16 von 153  
Page 16 of 153

4.5	2.037	0.450	0.182	0.159	0.148	0.162	0.144	0.149	0.145	0.141	0.136	--
4.7	1.507	0.320	0.186	0.171	0.149	0.163	0.172	0.152	0.119	0.113	0.110	--
4.9	1.693	0.427	0.173	0.143	0.120	0.105	0.129	0.106	0.099	0.086	0.089	--
5.1	1.903	0.456	0.192	0.147	0.116	0.119	0.138	0.148	0.132	0.121	0.119	--
5.3	1.247	0.356	0.187	0.153	0.131	0.113	0.149	0.132	0.095	0.088	0.088	--
5.5	1.357	0.381	0.186	0.146	0.124	0.107	0.100	0.099	0.114	0.097	0.095	--
5.7	1.294	0.329	0.173	0.129	0.116	0.088	0.089	0.107	0.122	0.112	0.103	--
5.9	1.008	0.287	0.140	0.105	0.088	0.079	0.067	0.066	0.065	0.054	0.058	--
6.1	1.002	0.315	0.131	0.096	0.086	0.082	0.071	0.071	0.085	0.091	0.094	--
6.3	0.814	0.244	0.119	0.073	0.064	0.065	0.056	0.058	0.067	0.069	0.072	--
6.5	0.776	0.185	0.120	0.082	0.066	0.065	0.050	0.047	0.048	0.045	0.045	--
6.7	0.678	0.212	0.110	0.069	0.060	0.066	0.060	0.048	0.045	0.046	0.049	--
6.9	0.583	0.195	0.108	0.073	0.048	0.033	0.040	0.042	0.042	0.046	0.049	--
7.1	0.570	0.228	0.126	0.089	0.056	0.048	0.051	0.039	0.035	0.031	0.033	--
7.3	0.512	0.196	0.113	0.082	0.064	0.044	0.039	0.043	0.035	0.030	0.033	--
7.5	0.452	0.170	0.102	0.080	0.056	0.041	0.032	0.029	0.028	0.029	0.029	--
7.7	0.455	0.182	0.118	0.088	0.065	0.046	0.033	0.040	0.036	0.030	0.028	--
7.9	0.408	0.146	0.111	0.085	0.069	0.061	0.042	0.039	0.035	0.028	0.026	--
8.1	0.389	0.141	0.099	0.077	0.052	0.053	0.047	0.031	0.022	0.021	0.020	--
8.3	0.367	0.130	0.115	0.084	0.064	0.055	0.031	0.038	0.038	0.030	0.025	--
8.5	0.334	0.117	0.107	0.090	0.068	0.059	0.048	0.043	0.040	0.031	0.025	--
8.7	0.312	0.111	0.101	0.083	0.051	0.041	0.044	0.031	0.020	0.019	0.017	--
8.9	0.309	0.108	0.109	0.092	0.064	0.052	0.039	0.039	0.042	0.034	0.059	--

Note(s): The max. value of three phases were chosen.

5.2.5	TABLE: Commutation notches			P
Test Conditions P/ P <sub>Emax</sub>	Measurements			Limit
	I <sub>com</sub> [A]			
	L1	L2	L3	
25% - 35%	54.32	54.26	53.98	
65% - 75%	126.69	126.53	126.00	
> 90%	182.06	182.42	181.88	

Note(s):

5.2.6	TABLE: DC current feeding to network (I <sub>dc</sub> )			P
Test Conditions P/ P <sub>Emax</sub>	Measurements			Limit
	I <sub>dc</sub> / I <sub>n</sub> [%]			
	L1	L2	L3	I <sub>dc</sub> /I <sub>n</sub>
<b>SUN2000-115KTL-M2</b>				
30% - 40%	0.060%	0.084%	0.090%	0.5%
60% - 70%	0.054%	0.133%	0.151%	0.5%
> 95%	0.042%	0.090%	0.133%	0.5%
<b>SUN2000-100KTL-M2</b>				
30% - 40%	0.021%	0.021%	0.028%	0.5%
60% - 70%	0.021%	0.069%	0.069%	0.5%

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 17 von 153  
 Page 17 of 153

> 95%	0.021%	0.062%	0.042%	0.5%
Note(s):				

5.3.2		TABLE: Tests of three-phase inverter (Imbalance)					P
Test Conditions		Measurements					Limit
cosφ	S/S <sub>E<sub>max</sub></sub> [%]	S <sub>asy</sub> /S <sub>E<sub>max</sub></sub> [%]					S <sub>asy</sub> /S <sub>E<sub>max</sub></sub> [%]
1.0	100	0.20%	0.21%	0.21%	0.20%	0.21%	≤ ±5
1.0	50	0.04%	0.04%	0.03%	0.04%	0.04%	
Max. un	100	0.21%	0.22%	0.24%	0.22%	0.23%	
Max. un	50	0.06%	0.07%	0.06%	0.07%	0.06%	
Max. ov	100	0.22%	0.23%	0.22%	0.22%	0.22%	
Max. ov	50	0.04%	0.07%	0.06%	0.04%	0.07%	
Note(s):							
S <sub>asy</sub> : Max. Asymmetry power among three phases.							

5.4.2		TABLE: Measurement of active- and reactive power ranges (P&Q range)				P		
Test Conditions		Measurements				Δ Limit		
U/Un	cosφ	U [V]	P <sub>max</sub> [W]	S <sub>max</sub> [VA]	cosφ	cosφ	P <sub>max</sub> /P <sub>E<sub>max</sub></sub>	S <sub>max</sub> /S <sub>E<sub>max</sub></sub>
0.9	1.0	207.76	113886	113887	1.000	--	≤102%	≤102%
1.0		230.76	126086	126086	1.000			
1.09		251.53	126123	126126	1.000			
0.9	Max. un	207.72	83181	103676	0.802	≤0.9(5)		
1.0		230.78	100414	124938	0.804			
1.09		251.50	100311	125046	0.802			
0.9	Max. ov	207.48	78307	98178	0.798			
1.0		230.59	99816	125258	0.797			
1.09		251.30	99632	125363	0.795			
Note(s):								

5.4.3(a)		TABLE: Active power reduction through setting provision (P control)		P
Test Conditions		Measurements		Limit
P/P <sub>n</sub> [%]		P/P <sub>n</sub> [%]	ΔP/P <sub>n</sub> [%]	Δ P/P <sub>n</sub> [%]
100		99.94	-0.06	≤ 5%
90		90.27	0.27	
80		80.24	0.24	
70		70.20	0.2	
60		60.14	0.14	
50		50.12	0.12	
40		40.06	0.06	
30		30.02	0.02	
20		19.98	-0.02	
10		9.95	-0.05	
No disconnection occur				

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 18 von 153  
 Page 18 of 153

5.4.3(b)	TABLE: Active power reduction through setting provision (P control)		P
Test Conditions	Measurements		Limit
P/P <sub>n</sub> [%]	$\Delta P/\Delta t$ [%P <sub>n</sub> /s]		$\Delta P/\Delta t$ [%P <sub>n</sub> /s]
100->5	0.502		0.33-0.66
5->100	0.503		


5.4.3(d)	TABLE: Active power reduction through setting provision (P control)		P
Test Conditions		Measurements	Limit
P/P <sub>n</sub> [%]		T <sub>response</sub> [s]	T <sub>response</sub> [s]
100->0		1.2	≤ 5
Note(s):			

5.4.4(a)	TABLE: Active power output of PGU by over-frequency (LFSM-O)								P		
LFSM-O settings	f <sub>active</sub>			f <sub>stop</sub>			f <sub>deactive</sub>		Droop		
	50.2			N/A			50.2		5%(40%P <sub>M</sub> /Hz)		
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>Emax</sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>Emax</sub> [%]	$\Delta P/P_{Emax}$ [%]	$\Delta P$ [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]
50.00	100	99.93	50.00	--	--	--	100	-0.07	≤±10	≤2	≤20
50.25	100	97.58	50.25	1	1	--	98	-0.42			
50.70	100	79.62	50.70	1	1	--	80	-0.38			
51.40	100	51.70	51.40	1	1	--	52	-0.30			
50.70	100	79.65	50.70	1	1	--	80	-0.35			
50.25	100	97.60	50.25	1	1	--	98	-0.40			
50.00	100	99.93	50.00	1	1	--	100	-0.07			
51.65	100	Disconnection					0	--			
50.15	100	No Reconnection					0	--			
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>Emax</sub> [%]	f [Hz]	$\Delta P/\Delta t$ [%/min]		P/P <sub>Emax</sub> [%]	$\Delta P/P_{Emax}$ [%]	$\Delta P$ [%]	$\Delta P/\Delta t$ [%/min]		
50.00	100	99.87	50.00	9.20		100	-0.13	≤±10	≤10		
Note(s):											
Plotting diagram:											


**Prüfbericht-Nr.:**  
**Test report no.:**

**CN224DKW 001 Attachment 1**

Seite 19 von 153  
 Page 19 of 153



5.4.4(b)		TABLE: Active power output of PGU by over-frequency (LFSM-O)							P		
LFSM-O settings		$f_{active}$		$f_{stop}$		$f_{deactive}$		Droop			
		50.5		N/A		50.2		12% (16.67% $P_M/Hz$ )			
Test Conditions		Measurements					Target	Tolerance	Limit		
$f$ [Hz]	$P_{rim}$ [%]	$P/P_{Emax}$ [%]	$f$ [Hz]	$T_{rise}$ [s]	$T_{set}$ [s]	$T_v$ [s]	$P/P_{Emax}$ [%]	$\Delta P/P_{Emax}$ [%]	$\Delta P$ [%]	$T_{rise}$ [s]	$T_{set}$ [s]
50.00	60	60.00	50.00	--	--	--	60		$\leq \pm 10$	$\leq 2$	$\leq 20$
50.40	60	59.99	50.40	--	--	--	60				
50.70	60->100	58.00	50.70	1	1	--	58				
51.40	100	51.00	51.40	1	1	--	51				
50.70	100	58.01	50.70	1	1	--	58				
50.40	100	60.02	50.40	1	1	--	60				
Test Conditions		Measurements				Target	Tolerance	Limit			
$f$ [Hz]	$P_{rim}$ [%]	$P/P_{Emax}$ [%]	$f$ [Hz]	$\Delta P/\Delta t$ [%/min]		$P/P_{Emax}$ [%]	$\Delta P/P_{Emax}$ [%]	$\Delta P$ [%]	$\Delta P/\Delta t$ [%/min]		
50.00	100	101.09	50.00	9.21		100	1.09	$\leq \pm 10$	$\leq 10$		
Note(s):											
Plotting diagram:											



5.4.5(a)		TABLE: Active power output of ESS by over-frequency (LFSSM-O)								N/A			
LFSSM-O settings		f <sub>active</sub>			f <sub>stop</sub>			f <sub>deactive</sub>			Droop		
		50.2			N/A			50.2			5%(40%P <sub>E<sub>max</sub></sub> /Hz)		
Test Conditions		Measurements						Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]		
50.00	100			--	--	--	100		≤±10	≤1	≤20		
50.25	100					--	98						
50.70	100					--	80						
51.40	100					--	52						
50.70	100					--	80						
50.25	100					--	98						
50.00	100					--	100						
51.65	100	Disconnection					0	--					
50.15	100	No Reconnection					0	--					
Test Conditions		Measurements				Target	Tolerance	Limit					
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	ΔP/Δt [%/min]	P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	ΔP/Δt [%/min]					
50.00	100				100		≤±10	≤10					
Note(s):													
Plotting diagram:													

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 21 von 153  
 Page 21 of 153


5.4.5(b)		TABLE: Active power output of ESS by over-frequency (LFSM-O)										N/A	
LFSM-O settings		f <sub>active</sub>			f <sub>stop</sub>			f <sub>deactive</sub>			Droop		
		50.5			N/A			50.2			5%(40%P <sub>E<sub>max</sub></sub> /Hz)		
Test Conditions		Measurements						Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]		
50.00	60			--	--	--	60		≤±10	≤1	≤20		
50.40	60			--	--	--	60						
50.70	60->100					--	52						
51.40	100					--	24						
50.70	100					--	52						
Test Conditions		Measurements						Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	ΔP/Δt [%/min]			P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	ΔP/Δt [%/min]			
50.10	100						100		≤±10	≤10			
50.00	100						100		≤±10	--			
Note(s):													
Plotting diagram:													

5.4.6(a)		TABLE: Active power output of PGU by under-frequency (LFSM-U)										P	
LFSM-U settings		f <sub>active</sub>			f <sub>stop</sub>			f <sub>deactive</sub>			Droop		
		49.8			N/A			49.8			5%(40%P <sub>E<sub>max</sub></sub> /Hz)		
Test Conditions		Measurements						Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]		
50.00	100	9.92	50.00	--	--	--	10	-0.08	≤±10	≤2	≤20		
49.75	100	11.85	49.75	1	1	--	12	-0.15					
48.80	100	49.92	48.80	1	1	--	50	-0.08					
47.60	100	98.06	47.60	1	1	--	98	0.06					
48.80	100	49.89	48.80	1	1	--	50	-0.11					
49.75	100	11.84	49.75	1	1	--	12	-0.16					
50.00	100	9.91	50.00	1	1	--	10	-0.09					
47.35	100	Disconnection					0	--					
47.40	100	No Reconnection					0	--					
Test Conditions		Measurements						Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	ΔP/Δt [%/min]			P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	ΔP/Δt [%/min]			
50.00	100	9.91	50.00	9.21			10	-0.09	≤±10	≤10			
Note(s):													
Product power was limited to 10% at the beginning of test by a lower priority command from user.													
Plotting diagram:													


**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 22 von 153  
 Page 22 of 153



5.4.6(b)		TABLE: Active power output of PGU by under-frequency (LFSM-U)							P		
LFSM-U settings		$f_{active}$		$f_{stop}$		$f_{deactive}$		Droop			
		49.8		N/A		49.8		5% (40% $P_{Emax}/Hz$ )			
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	$P_{rim}$ [%]	$P/P_{Emax}$ [%]	f [Hz]	$T_{rise}$ [s]	$T_{set}$ [s]	$T_v$ [s]	$P/P_{Emax}$ [%]	$\Delta P/P_{Emax}$ [%]	$\Delta P$ [%]	$T_{rise}$ [s]	$T_{set}$ [s]
50.00	100	60.02	50.00	--	--	--	60	0.02	$\leq \pm 10$	$\leq 2$	$\leq 20$
49.75	100	62.01	49.75	1	1	--	62	0.01			
49.20	100	84.11	49.20	1	1	--	84	0.11			
48.80	100	100.80	48.80	1	1	--	100	0.80			
49.20	100	84.06	49.20	1	1	--	84	0.06			
49.85	100	60.07	49.85	1	1	--	60	0.07			
50.00	100	60.02	50.00	--	--	--	60	0.02			
Note(s): Product power was limited to 60% at the beginning of test by a lower priority command from user. Plotting diagram:											



5.4.7(a)		TABLE: Active power output of ESS by under-frequency (LFSM-U)							N/A		
LFSM-U settings		$f_{active}$		$f_{stop}$		$f_{deactive}$		Droop			
		49.8		N/A		49.8		2%(100%P <sub>E<sub>max</sub></sub> /Hz)			
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>E<sub>max</sub></sub> [%]	$\Delta P/P_{E_{max}}$ [%]	$\Delta P$ [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]
50.00	100			--	--	--	-100		$\leq \pm 10$	$\leq 1$	$\leq 20$
49.75	100					--	-95				
48.80	100					--	0				
47.60	100					--	100				
48.80	100					--	0				
49.85	100					--	-100				
50.00	100			--	--	--	-100				
47.35	100	Disconnection					0	--			
47.40	100	No Reconnection					0	--			
Test Conditions		Measurements					Target	Tolerance	Limit		
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	$\Delta P/\Delta t$ [%/min]			P/P <sub>E<sub>max</sub></sub> [%]	$\Delta P/P_{E_{max}}$ [%]	$\Delta P$ [%]	$\Delta P/\Delta t$ [%/min]	
50.00	100						-100		$\leq \pm 10$	$\leq 10$	
Note(s): Product was set in charging mode under rated power at the beginning of test.											
Plotting diagram:											



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 24 von 153  
 Page 24 of 153

5.4.7(b)		TABLE: Active power output of ESS by under-frequency (LFSM-U)								N/A		
LFSM-U settings		f <sub>active</sub>		f <sub>stop</sub>			f <sub>deactive</sub>		Droop			
		49.8		N/A			49.8		2%(100%P <sub>E<sub>max</sub></sub> /Hz)			
Test Conditions		Measurements					Target	Tolerance	Limit			
f [Hz]	P <sub>rim</sub> [%]	P/P <sub>E<sub>max</sub></sub> [%]	f [Hz]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	T <sub>v</sub> [s]	P/P <sub>E<sub>max</sub></sub> [%]	ΔP/P <sub>E<sub>max</sub></sub> [%]	ΔP [%]	T <sub>rise</sub> [s]	T <sub>set</sub> [s]	
50.00	100			--	--	--	10		≤±10	≤1	≤20	
49.75	100					--	15					
48.80	100					--	100					
47.60	100					--	100					
48.80	100					--	100					
49.85	100					--	10					
50.00	100			--	--	--	10					
Note(s): Product power was limited to 10% at the beginning of test by a lower priority command from user. Plotting diagram:												

5.4.8.2		TABLE: Tests of reactive power / displacement factor setting accuracy (Fixed cosφ)								P	
Test Conditions			Measurements					Target	Tolerance	Limit	
U/Un [%]	P/P <sub>E<sub>max</sub></sub> [%]	cosφ	P [W]	Q [Var]	S [VA]	U [V]	cosφ	Q [Var]	ΔQ/P <sub>E<sub>max</sub></sub> [%]	ΔQ/P <sub>E<sub>max</sub></sub> [%]	
90	50	0.90 under-excited	62501	-30554	69571	207.48	0.898	-30271	0.23	≤± 4	
90	S <sub>E<sub>max</sub></sub>		94571	-46374	105328	207.61	0.898	-45803	0.46	≤± 4	
100	50		62549	-30610	69637	230.51	0.898	-30294	0.25	≤± 4	
100	S <sub>E<sub>max</sub></sub>		112477	-55458	125406	230.70	0.897	-54475	0.79	≤± 4	
110	50		62510	-30622	69607	253.51	0.898	-30275	0.28	≤± 4	
110	S <sub>E<sub>max</sub></sub>		112523	-55150	125310	253.68	0.898	-54497	0.52	≤± 4	
90	50	0.95 under-excited	62513	-20826	65892	207.51	0.949	-20547	0.22	≤± 4	
90	S <sub>E<sub>max</sub></sub>		102578	-34446	108209	207.68	0.948	-33716	0.58	≤± 4	
100	50		62570	-20876	65960	230.52	0.949	-20566	0.25	≤± 4	
100	S <sub>E<sub>max</sub></sub>		118636	-39872	125158	230.75	0.948	-38994	0.70	≤± 4	
110	50		62516	-20891	65914	253.53	0.948	-20548	0.27	≤± 4	
110	S <sub>E<sub>max</sub></sub>		118850	-39670	125296	253.72	0.949	-39064	0.48	≤± 4	
90	50	0.90 over-excited	62540	29984	69358	207.57	0.902	30290	0.24	≤± 4	
90	S <sub>E<sub>max</sub></sub>		97402	46518	107940	207.80	0.902	47174	0.52	≤± 4	
100	50		62630	30046	69466	230.61	0.902	30333	0.23	≤± 4	
100	S <sub>E<sub>max</sub></sub>		112950	53873	125140	230.85	0.903	54704	0.66	≤± 4	
110	50		62624	30010	69445	253.60	0.902	30330	0.26	≤± 4	
110	S <sub>E<sub>max</sub></sub>		112833	54061	125115	253.83	0.902	54648	0.47	≤± 4	
90	50	0.95 over-excited	62545	20270	65748	207.57	0.951	20558	0.23	≤± 4	
90	S <sub>E<sub>max</sub></sub>		104416	33662	109707	207.82	0.952	34320	0.53	≤± 4	
100	50		62606	20268	65805	230.58	0.951	20578	0.25	≤± 4	

**Prüfbericht-Nr.:**  
 Test report no.:


**CN224DKW 001 Attachment 1**

 Seite 25 von 153  
 Page 25 of 153


100	$S_{E_{max}}$	119204	38348	125221	230.87	0.952	39180	0.67	$\leq \pm 4$
110	50	62600	20264	65798	253.58	0.951	20576	0.25	$\leq \pm 4$
110	$S_{E_{max}}$	119047	38569	125138	253.83	0.951	39129	0.45	$\leq \pm 4$

Note(s):


P-Q Diagram:




5.4.8.3(a)	TABLE: Tests of displacement factor- / active power character curve ( $\cos\phi(P)$ )			P
cos $\phi$ (P) curve settings:	P/P <sub>E<sub>max</sub></sub> [%]	10	50	100
	cos $\phi$	1.0	1.0	0.9
	3Tau [s]	10		
Test Conditions				Limit
P <sub>dc</sub> /P <sub>dc,r</sub> [%]				$\Delta Q/P_{E_{max}}$ [%]
100->10->100 with ramp $\leq 30\%P_{dc,r}/\text{min}$				$\leq \pm 4.0$
Plotting diagram: P <sub>AC</sub> (t), Q <sub>measure</sub> (t), Q <sub>standard</sub> (t), Q <sub>tolerance</sub> (t)				



5.4.8.3(b)	TABLE: Tests of displacement factor- / active power character curve (cosφ(P))	P
Test Conditions	Measurements	Limit
$P_{rim}/P_{dc,r}$ [%]	Response time T [s]	Response time T [s]
100->40	9.8	Complied with PT-1 curve
40->100	8.0	
100->75	8.6	





5.4.8.4(a)		TABLE: Tests of reactive power-voltage character curve (Q(U))				P
Q (U) curve settings:	U/Un	0.93	0.97	1.03	1.07	
	Q/S <sub>E<sub>max</sub></sub>	+0.436	0	0	-0.436	
	3Tau [s]	10				
Test Conditions		Measurements		Target	Tolerance	Limit
U/Un[%]		Q[Var]	U [V]	Q[Var]	ΔQ/P <sub>E<sub>max</sub></sub> [%]	ΔQ [Var]
100		-1017	230.95	0	-0.81	±(0.01*Un,Y*K QU +0.04PE <sub>max</sub> ), KQU= Q <sub>max</sub> /  (0.04*Un,Y)
99		-1021	228.65	0	-0.82	
98		-1052	226.32	0	-0.84	
97		-954	224.02	0	-0.76	
96		12717	221.73	13625	-0.73	
95		26235	219.46	27250	-0.81	
94		39759	217.16	40875	-0.89	
93		53643	214.85	54500	-0.69	
92		53654	212.55	54500	-0.68	
91		53688	210.23	54500	-0.65	
90		53698	207.93	54500	-0.64	
91		53681	210.25	54500	-0.66	
92		53666	212.56	54500	-0.67	
93		53637	214.85	54500	-0.69	
94		44474	217.13	40875	2.88	
95		28584	219.45	27250	1.07	
96		13784	221.75	13625	0.13	


**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 29 von 153  
 Page 29 of 153

97	-1035	224.02	0	-0.83
98	-994	226.32	0	-0.80
99	-1003	228.63	0	-0.80
100	-1037	230.93	0	-0.83
101	-910	233.19	0	-0.36
102	-934	235.49	0	-0.37
103	-867	237.81	0	-0.35
104	-14569	240.06	-13625	-0.38
105	-27841	242.32	-27250	-0.24
106	-41588	244.59	-40875	-0.29
107	-55271	247.14	-54500	-0.31
108	-55201	249.13	-54500	-0.28
109	-55277	251.44	-54500	-0.31
110	-55167	253.74	-54500	-0.27
109	-55201	251.44	-54500	-0.28
108	-55141	249.14	-54500	-0.26
107	-55303	246.85	-54500	-0.32
106	-45316	244.57	-40875	-1.78
105	-30321	242.32	-27250	-1.23
104	-16682	240.08	-13625	-1.22
103	-879	237.80	0	-0.35
102	-955	235.51	0	-0.38
101	-1006	233.22	0	-0.40
100	-1070	230.92	0	-0.43


Diagram:




5.4.8.4(b)	TABLE: Tests of reactive power-voltage character curve (Q(U))					P
Test Conditions	Measurement			Target	Limit	
	Settling time T [s]	Q <sub>Start</sub> [Var]	Q <sub>End</sub> [Var]	Q <sub>End</sub> /S <sub>E<sub>max</sub></sub> [%]	Settling time T [s]	$\Delta Q_{End}/P_{E_{max}}$ [%]
Un -> Un+ΔU <sub>ind,Y</sub>	12.4	-129	-44064	-0.85Q <sub>max</sub>	PT1 complied, See attached curve for detail.	≤±4
Un+ΔU <sub>ind,Y</sub> -> Un	12.4	-46651	-35	0		≤±4
Un -> Un+ΔU <sub>ind,Y</sub>	12.4	-139	-44061	-0.85Q <sub>max</sub>		≤±4
Un+ΔU <sub>ind,Y</sub> -> Un	12.4	-46591	-282	0		≤±4
Un -> Un+ΔU <sub>ind,Y</sub>	12.4	-239	-44059	-0.85Q <sub>max</sub>		≤±4
Un+ΔU <sub>ind,Y</sub> -> Un	12.4	-46567	-280	0		≤±4
Un -> Un+ΔU <sub>cap,Y</sub>	13	-213	44115	0.85Q <sub>max</sub>		≤±4
Un+ΔU <sub>cap,Y</sub> -> Un	13	46536	37	0		≤±4
Un -> Un+ΔU <sub>cap,Y</sub>	13	-93	44041	0.85Q <sub>max</sub>		≤±4
Un+ΔU <sub>cap,Y</sub> -> Un	13	46555	11	0		≤±4
Un -> Un+ΔU <sub>cap,Y</sub>	13.2	-156	44043	0.85Q <sub>max</sub>		≤±4
Un+ΔU <sub>cap,Y</sub> -> Un	13	46566	-13	0		≤±4


Plotting Diagram

Un -> Un+ΔU<sub>ind,Y</sub>







Un+ΔU<sub>ind,Y</sub>-> Un












**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 34 von 153  
 Page 34 of 153



Note(s):

5.5.2, 5.5.4, 5.5.6		TABLE: NS-protection, Integrated interface switch (Functional safety)					P
The max. initial short-circuited current I <sub>k</sub> " [A]:				182.3			
DIN EN 62109-1 cert/report No.:				N/A			
No.	component No.	fault	test voltage (V)	test time	fuse No.	Input current (A)	Result
1.	Relay defect K5 Pin 1-pin 2	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.
2.	Relay defect K8 Pin 1-pin 2	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.
3.	Relay defect C956	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.
4.	Relay defect R144	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.

**Prüfbericht-Nr.:**  
Test report no.:

**CN224DKW 001 Attachment 1**

Seite 35 von 153  
Page 35 of 153

5.	Relay defect Q5	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.
6.	Relay defect Q6	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: Leakage current sensor hardware failure No hazard, no damage, no reconnection.
7.	Relay defect R144	Open before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: Leakage current sensor hardware failure No hazard, no damage, no reconnection.
8.	Relay defect C28	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: alarm grid relay abnormal No hazard, no damage, no reconnection.
9.	PV insulation measuremen t defect Q7	Short before start-up	230Vac 600Vdc	10min	--	--	EUT can't start up. Error message: Unit can't power on, alarm, ISO fault. No hazard, no damage, no reconnection.
10.	PV insulation measuremen t defect D98	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: Unit can't power on, alarm, ISO fault. No hazard, no damage, no reconnection.
11.	PV insulation measuremen t defect U35	Short before start-up	230Vac 600Vdc	10min	--	--	PCE can't start up. Error message: Unit can't power on, alarm, ISO fault. No hazard, no damage, no reconnection.
12.	RCMU measuremen t defect Q14	s-c	230Vac 600Vdc	10min	--	--	PCE shutdown immediately. Error message: alarm boost input over current No hazard, no damage, no reconnection.

**Prüfbericht-Nr.:**  
*Test report no.:*
**CN224DKW 001 Attachment 1**

 Seite 36 von 153  
 Page 36 of 153

13.	RCMU measurement defect C747 +5V	s-c	230Vac 600Vdc	10min	--	--	PCE shutdown immediately. Error message: alarm boost input over current No hazard, no damage, no reconnection.
14.	RCMU measurement defect R126	o-c	230Vac 600Vdc	10min	--	--	PCE shutdown immediately. Error message: alarm boost input over current No hazard, no damage, no reconnection.
15.	RCMU measurement defect R461	o-c	230Vac 600Vdc	10min	--	--	PCE shutdown immediately. Error message: alarm boost input over current No hazard, no damage, no reconnection.
16.	RCMU measurement defect U34 pin1 to pin4	s-c	230Vac 600Vdc	10min	--	--	PCE shutdown immediately. Error message: alarm boost input over current No hazard, no damage, no reconnection.
17.	PV voltage detect D1502 PIN2- PIN3	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "High String Input Voltage". No components damage, no hazard.
18.	PV voltage detect D1502 PIN1- PIN3	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "High String Input Voltage". No components damage, no hazard.
19.	PV current detect C3201 SMP_BOOS T_A_CUR_D C-3V3	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
20.	PV current detect C3201 SMP_BOOS T_A_CUR_D C-AGND	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.

**Prüfbericht-Nr.:**  
*Test report no.:*
**CN224DKW 001 Attachment 1**

 Seite 37 von 153  
 Page 37 of 153

21.	PV current detect D1501 PIN2-PIN3	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
22.	PV current detect D1501 PIN1-PIN3	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
23.	Grid voltage L2L3 line monitoring U59, PIN8-+5V	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Grid Overvoltage". No components damage, no hazard.
24.	Grid voltage L2L3 line monitoring U59, PIN8-AGND	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Grid Overvoltage". No components damage, no hazard.
25.	Grid voltage L3 phase monitoring U59, PIN8-+5V	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "alarm grid relay abnormal". No components damage, no hazard.
26.	Grid voltage L3 phase monitoring U59, PIN8-AGND	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "alarm grid relay abnormal". No components damage, no hazard.
27.	Grid frequency monitoring U50 PIN2-PIN3	s-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Grid Under frequency". No components damage, no hazard.
28.	Grid frequency monitoring U50 PIN2-PIN12	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Grid Under frequency". No components damage, no hazard.
29.	Main ARM pin 139 R1767	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 38 von 153  
 Page 38 of 153

30.	Main ARM pin 140 R1766	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
31.	Slave ARM pin 139 R1733	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
32.	Slave ARM pin 140 R1732	o-c	230Vac 600Vdc	10min	--	--	PV inverter shut down. Error message "Device Fault". No components damage, no hazard.
33.	Loss of control DSP failure CPU, C104	s-c +3.3V	230Vac 600Vdc	10min	--	--	PV inverter shut down. No components damage, no hazard. Inverter can be restarted and operated normally when the fault was removed, no alarm.

Note(s): The unit passed electric strength test after single fault test above.

5.5.7(a)	TABLE: Protection devices and protection settings (OV/UV)						P
Condition	Setting U/Un [%]	Measurement				Limitation $\Delta U/Un$ [%]	
		Trip value [V]					
		L123	L1	L2	L3		
		U>>	125	286.9	286.5		
U<	80	185.4	184.3	184.0	184.4	$\leq \pm 1.0$	
U<<	45	104.9	101.6	103.8	103.8		
Condition	Setting U/Un [%]	Measurement				Limitation $\Delta U/Un$ [%]	
		Trip value [V]					
		L123	L1-L2	L2-L3	L3-L1		
		U>>	125	--	286.2		
U<	80	--	185.3	185.3	185.3	$\leq \pm 1.0$	
U<<	45	--	104.8	104.8	103.8		
Condition	Setting [ms]	Measurement				Limitation [ms]	
		Trip time [ms]					
		L123	L1	L2	L3		
		U>>	100	138	139		
U<	3000	3036	3035	3027	3027	3000-3100	
U<<	300	338	338	345	345	300-400	
Condition	Setting	Measurement				Limitation [ms]	
		Trip time [ms]					
		L123	L1-L2	L2-L3	L3-L1		
		U>>	100	--	125		

<b>Prüfbericht-Nr.:</b> Test report no.:	<b>CN224DKW 001 Attachment 1</b>	Seite 39 von 153 Page 39 of 153
---	----------------------------------	------------------------------------

U<	3000	--	3030	3020	3020	3000-3100
U<<	300	--	340	330	340	300-400
Condition	Setting [s]	Measurement				Limitation [s]
		Trip time [s]				
		L123	L1	L2	L3	
U> 230->257.6	500	471	464	460	504	450-550
U> 230->248.4	No disconnect	No disconnect				No disconnect
U> 244->262.2	300	245	250	243	314	225-375
Note(s): Tests on L-L voltages are applicable to product over 30kVA.						

5.5.7(b)	TABLE: Protection devices and protection settings (OF/UF)					P
Condition	Setting f [Hz]	Measurement				Limitation Δf/fn [%]
		Trip value [Hz]				
f>	51.5	51.49				≤±0.1
f<	47.5	47.50				
Condition	Setting [ms]	Measurement				Limitation [ms]
		Trip time [ms]				
f>	100	120				≤200
f<	100	148				≤200
Note(s):						

5.5.7(c)	TABLE: Protection devices and protection settings					P
1.	The last 5 fault indication can be read					<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Failed
	Fault 1: Grid Undervoltage					Interface equipment: Communication with PC.
	Fault 2: Grid Underfrequency					Interface equipment: Communication with PC.
	Fault 3: Grid Loss					Interface equipment: Communication with PC.
	Fault 4: Grid Loss					Interface equipment: Communication with PC.
	Fault 5: Grid Loss					Interface equipment: Communication with PC.
2.	Fault indication can be read after a supply interruption ≤3s					<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Failed
	Fault 1: Grid Undervoltage					Interface equipment: Communication with PC.
	Fault 2: Grid Underfrequency					Interface equipment: Communication with PC.
	Fault 3: Grid Loss					Interface equipment: Communication with PC.



<b>Prüfbericht-Nr.:</b> Test report no.:	<b>CN224DKW 001 Attachment 1</b>	Seite 40 von 153 Page 40 of 153
---	----------------------------------	------------------------------------

Fault 4: Grid Loss	Interface equipment: Communication with PC.
Fault 5: Grid Loss	Interface equipment: Communication with PC.

5.5.9	TABLE: Constructional features of NS protection	P
1.	The protection settings can be read on PGU or data interface equipment	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Failed Interface equipment: Communication with PC.
2.	The NS protection settings shall be protected.	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Failed Protection type: Password Protected
3.	If all protection settings are fixed	<input checked="" type="checkbox"/> Pass <input type="checkbox"/> Failed Protection settings: Can be set but requires password authentication

5.5.10	TABLE: Islanding detection (per IEC 62116: 2014)					P
Power 100%						
Conditions	P <sub>R</sub> [kW]	Q <sub>L</sub> [kVar]	Q <sub>C</sub> [kVar]	Q <sub>f</sub>	Trip time [ms]	Limitation [ms]
P <sub>R</sub> : -10% Q <sub>C</sub> : +10%	L1: 37.54	L1: 45.84	L1: 41.64	1.16	216	
	L2: 37.58	L2: 45.86	L2: 41.62	1.16		9000
	L3: 37.61	L3: 45.88	L3: 41.63	1.16		
P <sub>R</sub> : -10% Q <sub>C</sub> : +5%	L1: 37.49	L1: 43.77	L1: 41.59	1.14	247	
	L2: 37.51	L2: 43.71	L2: 41.60	1.14		9000
	L3: 37.56	L3: 43.74	L3: 41.63	1.14		
P <sub>R</sub> : -10% Q <sub>C</sub> : 0%	L1: 37.66	L1: 41.67	L1: 41.58	1.11	304	
	L2: 37.61	L2: 41.65	L2: 41.62	1.11		9000
	L3: 37.68	L3: 41.61	L3: 41.64	1.11		
P <sub>R</sub> : -10% Q <sub>C</sub> : -5%	L1: 37.58	L1: 39.61	L1: 41.66	1.08	220	
	L2: 37.60	L2: 39.56	L2: 41.61	1.08		9000
	L3: 37.54	L3: 39.57	L3: 41.63	1.08		
P <sub>R</sub> : -10% Q <sub>C</sub> : -10%	L1: 37.48	L1: 37.53	L1: 41.67	1.06	203	
	L2: 37.52	L2: 37.58	L2: 41.59	1.06		9000
	L3: 37.54	L3: 37.52	L3: 41.62	1.06		
P <sub>R</sub> : -5% Q <sub>C</sub> : +10%	L1: 39.62	L1: 45.86	L1: 41.61	1.10	215	
	L2: 39.59	L2: 45.79	L2: 41.63	1.10		9000
	L3: 39.64	L3: 45.83	L3: 41.66	1.10		
P <sub>R</sub> : -5% Q <sub>C</sub> : -10%	L1: 39.64	L1: 37.56	L1: 41.68	0.99	199	
	L2: 39.61	L2: 37.55	L2: 41.56	1.00		9000

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 41 von 153  
 Page 41 of 153

	L3: 39.59	L3: 37.48	L3: 41.61	1.00		
P <sub>R</sub> : 0% Q <sub>C</sub> : +10%	L1: 41.58	L1: 45.88	L1: 41.64	1.05	227	9000
	L2: 41.62	L2: 45.81	L2: 41.62	1.04		
	L3: 41.65	L3: 45.86	L3: 41.65	1.05		
P <sub>R</sub> : -5% Q <sub>C</sub> : +5%	L1: 39.66	L1: 43.78	L1: 41.61	1.08	239	9000
	L2: 39.62	L2: 43.71	L2: 41.63	1.07		
	L3: 39.64	L3: 43.72	L3: 41.62	1.08		
P <sub>R</sub> : -5% Q <sub>C</sub> : 0%	L1: 39.64	L1: 41.71	L1: 41.65	1.05	275	9000
	L2: 39.62	L2: 41.66	L2: 41.68	1.05		
	L3: 39.61	L3: 41.64	L3: 41.62	1.05		
P <sub>R</sub> : -5% Q <sub>C</sub> : -5%	L1: 39.63	L1: 39.62	L1: 41.63	1.02	208	9000
	L2: 39.65	L2: 39.57	L2: 41.67	1.03		
	L3: 39.58	L3: 39.63	L3: 41.62	1.02		
P <sub>R</sub> : 0% Q <sub>C</sub> : +5%	L1: 41.66	L1: 43.71	L1: 41.62	1.02	332	9000
	L2: 41.57	L2: 43.77	L2: 41.58	1.02		
	L3: 41.63	L3: 43.69	L3: 41.63	1.02		
P <sub>R</sub> : 0% Q <sub>C</sub> : 0%	L1: 41.7	L1: 41.65	L1: 41.68	1.00	346	9000
	L2: 41.68	L2: 41.61	L2: 41.73	1.00		
	L3: 41.63	L3: 41.63	L3: 41.65	1.00		
P <sub>R</sub> : 0% Q <sub>C</sub> : -5%	L1: 41.69	L1: 39.64	L1: 41.66	0.97	213	9000
	L2: 41.71	L2: 39.59	L2: 41.59	0.97		
	L3: 41.66	L3: 39.55	L3: 41.61	0.97		
P <sub>R</sub> : +5% Q <sub>C</sub> : +5%	L1: 43.81	L1: 39.64	L1: 41.66	0.93	240	9000
	L2: 43.79	L2: 39.59	L2: 41.59	0.93		
	L3: 43.74	L3: 39.55	L3: 41.61	0.93		
P <sub>R</sub> : +5% Q <sub>C</sub> : 0%	L1: 41.65	L1: 37.56	L1: 41.68	0.95	322	9000
	L2: 41.64	L2: 37.55	L2: 41.56	0.95		
	L3: 41.61	L3: 37.48	L3: 41.61	0.95		
P <sub>R</sub> : +5% Q <sub>C</sub> : -5%	L1: 43.81	L1: 45.88	L1: 41.64	1.00	216	9000
	L2: 43.79	L2: 45.81	L2: 41.62	1.00		
	L3: 43.74	L3: 45.86	L3: 41.65	1.00		
P <sub>R</sub> : 0% Q <sub>C</sub> : -10%	L1: 43.81	L1: 37.56	L1: 41.68	0.9	193	9000
	L2: 43.79	L2: 37.55	L2: 41.56	0.9		
	L3: 43.74	L3: 37.48	L3: 41.61	0.9		
P <sub>R</sub> : +5% Q <sub>C</sub> : +10%	L1: 45.89	L1: 45.88	L1: 41.64	0.95	215	9000
	L2: 45.81	L2: 45.81	L2: 41.62	0.95		
	L3: 45.84	L3: 45.86	L3: 41.65	0.95		
P <sub>R</sub> : +5% Q <sub>C</sub> : -10%	L1: 45.89	L1: 43.71	L1: 41.62	0.93	323	9000
	L2: 45.81	L2: 43.77	L2: 41.58	0.93		

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 42 von 153  
 Page 42 of 153

	L3: 45.84	L3: 43.69	L3: 41.63	0.93		
P <sub>R</sub> : +10% Q <sub>C</sub> : +10%	L1: 45.89	L1: 41.65	L1: 41.68	0.91	225	9000
	L2: 45.81	L2: 41.61	L2: 41.73	0.91		
	L3: 45.84	L3: 41.63	L3: 41.65	0.91		
P <sub>R</sub> : +10% Q <sub>C</sub> : +5%	L1: 45.81	L1: 39.64	L1: 41.66	0.89	227	9000
	L2: 45.79	L2: 39.59	L2: 41.59	0.89		
	L3: 45.83	L3: 39.55	L3: 41.61	0.89		
P <sub>R</sub> : +10% Q <sub>C</sub> : 0%	L1: 45.81	L1: 37.56	L1: 41.68	0.86	338	9000
	L2: 45.79	L2: 37.55	L2: 41.56	0.86		
	L3: 45.83	L3: 37.48	L3: 41.61	0.86		
P <sub>R</sub> : +10% Q <sub>C</sub> : -5%	L1: 39.62	L1: 45.86	L1: 41.61	1.10	210	9000
	L2: 39.59	L2: 45.79	L2: 41.63	1.10		
	L3: 39.64	L3: 45.83	L3: 41.66	1.10		
P <sub>R</sub> : +10% Q <sub>C</sub> : -10%	L1: 39.64	L1: 37.56	L1: 41.68	0.99	192	9000
	L2: 39.61	L2: 37.55	L2: 41.56	1.00		
	L3: 39.59	L3: 37.48	L3: 41.61	1.00		
Power 66%						
Conditions	P <sub>R</sub> [kW]	Q <sub>L</sub> [kVar]	Q <sub>C</sub> [kVar]	Q <sub>f</sub>	Trip time [ms]	Limitation [ms]
P <sub>R</sub> : 0% Q <sub>C</sub> : -5%	L1: 27.42	L1: 25.56	L1: 27.58	0.97	195	9000
	L2: 27.48	L2: 25.51	L2: 27.53	0.97		
	L3: 27.51	L3: 25.49	L3: 27.55	0.97		
P <sub>R</sub> : 0% Q <sub>C</sub> : -4%	L1: 27.46	L1: 25.91	L1: 27.58	0.97	208	9000
	L2: 27.48	L2: 25.96	L2: 27.53	0.97		
	L3: 27.51	L3: 26.29	L3: 27.55	0.97		
P <sub>R</sub> : 0% Q <sub>C</sub> : -3%	L1: 27.45	L1: 26.45	L1: 27.61	0.98	214	9000
	L2: 27.50	L2: 26.38	L2: 27.63	0.98		
	L3: 27.46	L3: 26.29	L3: 27.59	0.98		
P <sub>R</sub> : 0% Q <sub>C</sub> : -2%	L1: 27.45	L1: 26.56	L1: 27.61	0.99	219	9000
	L2: 27.50	L2: 26.57	L2: 27.63	0.99		
	L3: 27.46	L3: 26.61	L3: 27.59	0.99		
P <sub>R</sub> : 0% Q <sub>C</sub> : -1%	L1: 27.45	L1: 26.98	L1: 27.61	0.99	264	9000
	L2: 27.50	L2: 26.87	L2: 27.63	0.99		
	L3: 27.46	L3: 26.91	L3: 27.59	0.99		
P <sub>R</sub> : 0% Q <sub>C</sub> : 0%	L1: 27.45	L1: 27.58	L1: 27.62	1.00	276	9000
	L2: 27.50	L2: 27.56	L2: 27.61	1.00		
	L3: 27.46	L3: 27.54	L3: 27.54	1.00		
P <sub>R</sub> : 0% Q <sub>C</sub> : +1%	L1: 27.45	L1: 28.14	L1: 27.62	1.02	276	9000
	L2: 27.50	L2: 28.17	L2: 27.61	1.02		

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 43 von 153  
 Page 43 of 153

	L3: 27.46	L3: 28.12	L3: 27.54	1.02		
P <sub>R</sub> : 0% Q <sub>C</sub> : +2%	L1: 27.45	L1: 28.58	L1: 27.58	1.02	252	9000
	L2: 27.50	L2: 28.62	L2: 27.61	1.02		
	L3: 27.46	L3: 28.51	L3: 27.57	1.02		
P <sub>R</sub> : 0% Q <sub>C</sub> : +3%	L1: 27.51	L1: 28.91	L1: 27.62	1.03	215	9000
	L2: 27.55	L2: 28.94	L2: 27.61	1.03		
	L3: 27.46	L3: 29.01	L3: 27.54	1.03		
P <sub>R</sub> : 0% Q <sub>C</sub> : +4%	L1: 27.47	L1: 29.32	L1: 27.64	1.04	212	9000
	L2: 27.50	L2: 29.27	L2: 27.63	1.04		
	L3: 27.46	L3: 29.28	L3: 27.57	1.04		
P <sub>R</sub> : 0% Q <sub>C</sub> : +5%	L1: 27.45	L1: 29.72	L1: 27.62	1.04	200	9000
	L2: 27.50	L2: 29.75	L2: 27.61	1.04		
	L3: 27.46	L3: 29.78	L3: 27.54	1.04		
Power 33%						
Conditions	P <sub>R</sub> [kW]	Q <sub>L</sub> [kVar]	Q <sub>C</sub> [kVar]	Q <sub>f</sub>	Trip time [ms]	Limitation [ms]
P <sub>R</sub> : 0% Q <sub>C</sub> : -5%	L1: 13.67	L1: 11.55	L1: 13.81	0.92	212	9000
	L2: 13.72	L2: 11.61	L2: 13.79	0.92		
	L3: 13.78	L3: 11.59	L3: 13.71	0.92		
P <sub>R</sub> : 0% Q <sub>C</sub> : -4%	L1: 13.78	L1: 12.12	L1: 13.89	0.94	213	9000
	L2: 13.74	L2: 12.18	L2: 13.72	0.94		
	L3: 13.72	L3: 12.21	L3: 13.69	0.94		
P <sub>R</sub> : 0% Q <sub>C</sub> : -3%	L1: 13.68	L1: 12.56	L1: 13.89	0.96	215	9000
	L2: 13.74	L2: 12.61	L2: 13.72	0.96		
	L3: 13.72	L3: 12.58	L3: 13.69	0.96		
P <sub>R</sub> : 0% Q <sub>C</sub> : -2%	L1: 13.79	L1: 12.94	L1: 13.89	0.97	248	9000
	L2: 13.74	L2: 12.97	L2: 13.72	0.97		
	L3: 13.72	L3: 13.01	L3: 13.69	0.97		
P <sub>R</sub> : 0% Q <sub>C</sub> : -1%	L1: 13.69	L1: 13.42	L1: 13.91	0.99	256	9000
	L2: 13.72	L2: 13.38	L2: 13.87	0.99		
	L3: 13.78	L3: 13.47	L3: 13.85	0.99		
P <sub>R</sub> : 0% Q <sub>C</sub> : 0%	L1: 13.77	L1: 13.76	L1: 13.84	1.00	280	9000
	L2: 13.65	L2: 13.81	L2: 13.81	1.00		
	L3: 13.72	L3: 13.86	L3: 13.77	1.00		
P <sub>R</sub> : 0% Q <sub>C</sub> : +1%	L1: 13.81	L1: 14.17	L1: 13.71	1.01	256	9000
	L2: 13.78	L2: 14.27	L2: 13.79	1.01		
	L3: 13.72	L3: 14.31	L3: 13.72	1.01		
P <sub>R</sub> : 0% Q <sub>C</sub> : +2%	L1: 13.86	L1: 14.62	L1: 13.75	1.02	222	9000
	L2: 13.77	L2: 14.78	L2: 13.84	1.02		

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 44 von 153  
 Page 44 of 153

	L3: 13.76	L3: 14.82	L3: 13.82	1.02		
P <sub>R</sub> : 0% Q <sub>c</sub> : +3%	L1: 13.74	L1: 15.24	L1: 13.75	1.05	214	9000
	L2: 13.78	L2: 15.34	L2: 13.79	1.05		
	L3: 13.72	L3: 15.24	L3: 13.72	1.05		
P <sub>R</sub> : 0% Q <sub>c</sub> : +4%	L1: 13.81	L1: 15.75	L1: 13.79	1.07	212	9000
	L2: 13.78	L2: 15.72	L2: 13.82	1.07		
	L3: 13.72	L3: 15.79	L3: 13.75	1.07		
P <sub>R</sub> : 0% Q <sub>c</sub> : +5%	L1: 13.81	L1: 16.21	L1: 13.71	1.08	202	9000
	L2: 13.78	L2: 16.18	L2: 13.79	1.08		
	L3: 13.72	L3: 16.31	L3: 13.72	1.08		


5.6	TABLE: Connection conditions and synchronization (Reconnection)				P
Condition	Measurement		Limitation		
	Reconnection	Delay time [s]	Reconnection	Delay time [s]	
f < 47.45 Hz	No	--	No	≥ 60	
f ≥ 47.55 Hz	Yes	69	Yes	≥ 60	
f > 50.15 Hz	No	--	No	≥ 60	
f ≤ 50.05 Hz	Yes	68	Yes	≥ 60	
U < 0.84 Un	No	--	No	≥ 60	
U ≥ 0.86 Un	Yes	68	Yes	≥ 60	
U > 1.11 Un	No	--	No	≥ 60	
U ≤ 1.09 Un	Yes	68	Yes	≥ 60	
Note(s):					

5.7	TABLE: P <sub>AV,E</sub> monitoring			P
P <sub>AV,E</sub> value setting: 60% P <sub>n</sub>				
Power limit method				
Test method		Condition		
Jump of primary energy		P <sub>rim</sub> / P <sub>dc,r</sub> : 60% -> 100%		
Cut of load		P <sub>load</sub> /P <sub>n</sub> : 40% -> 0%		

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 45 von 153  
 Page 45 of 153




Disconnection method

Condition	Trip time [ms]	
	Measurement	Limitation
0.98* P <sub>AV,E</sub>	N/A	No disconnect
1.02 P <sub>AV,E</sub> - 1.067* P <sub>AV,E</sub>	N/A	< 10000+200
1.067 P <sub>AV,E</sub> - 1.670* P <sub>AV,E</sub>	N/A	< 3000 + 200
1.690* P <sub>AV,E</sub>	N/A	< 200

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

Seite 46 von 153  
 Page 46 of 153

5.8	TABLE: Verification of dynamic network supporting (FVRT)	P
FVRT curve settings: 		
Fault Type	3-phase fault and 2-phase fault	
Transformer Type	Dy5	
NS protection settings	See table 5.5.7 for detail.	
Any auxilliary power supply in fault ride through?	Yes/No	
Terminal sequence	For D1: U-L1, V-L2, W-L3 For D2: U-L3, V-L1, W-L2	

**Prüfbericht-Nr.:**  
*Test report no.:*

**CN224DKW 001 Attachment 1**

Seite 47 von 153  
 Page 47 of 153


5.8		Verification of dynamic network support				P
Test	Voltage depth U/Un [p.u.]	Fault type	Fault duration [ms]	Power P/Pn [p.u.]	Reactive power Q/Pn [p.u.]	Test No.
1	0.15.....0.25	A	For 0.15pu ≥150 For 0.25pu ≥500	1.0	0...±0.1	1.1
				0.2...0.6		1.2
		D1		1.0		1.3
				0.2...0.6		1.4
				D2		1.0
2	0.50....0.60	A	For 0.5pu ≥1500 For 0.60pu ≥ 2000	1.0	Max. over- excited	2.1
				0.2...0.6		2.2
		D1		1.0		2.3
				0.2...0.6		2.4
3	0.50....0.60	A	For 0.5pu ≥1500 For 0.60pu ≥ 2000	1.0	Max. under- excited	3.1
				0.2...0.6		3.2
		D1		1.0		3.3
				0.2...0.6		3.4
4	0.85....0.90	A	≥ 60000	1.0	0...±0.1	4.1
				0.2...0.6		4.2
		D1		1.0		4.3
				0.2...0.6		4.4
5	1.2....1.25	A	≥ 100	1.0	0...±0.1	5.1
				0.2...0.6		5.2
		D1		1.0		5.3
				0.2...0.6		5.4
				D2		1.0
6	1.15...1.20	A	≥ 5000	1.0	0...±0.1	6.1
				0.2...0.6		6.2
		D1		1.0		6.3
				0.2...0.6		6.4
7	1.10...1.15	A	≥ 60000	1.0	0...±0.1	7.1
				0.2...0.6		7.2
		D1		1.0		7.3
				0.2...0.6		7.4




**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 48 von 153  
 Page 48 of 153

**Test No. 1.1 idle test**


Time [s]	A	B	Delta
	9.99369	0:10.16454	0.17085
AI 1/U1 [V]	-160.5587	9.770394	170.3291
AI 1/U2 [V]	-165.5908	31.02660	196.6174
AI 1/U3 [V]	325.5811	-40.64584	-366.2269
AI 1/I1 [A]	-0.921249	0.130057	1.051307
AI 1/I2 [A]	0.888586	-0.118971	-1.007557
AI 1/I3 [A]	5.007e-3	-0.041246	-0.046253
U1_tRMS@POWER/0 [V]	230.3129	29.96355	-200.3494
U2_tRMS@POWER/0 [V]	230.4378	30.13037	-200.3074
U3_tRMS@POWER/0 [V]	230.2596	30.03052	-200.2291
U_fundRMS_SYM+@POWER/0 [V]	230.3367	30.04126	-200.2954
U_fundRMS_SYM-@POWER/0 [V]	0.063896	0.063543	-3.536e-4

**Test No. 1.1 with PGU  
 Before dip**



Time [s]	A	B	Delta
	4.72338	6.72407	2.00069
AI 1/U1 [V]	280.7491	66.06579	-214.6833
AI 1/U2 [V]	-283.8013	-85.51002	198.2913
AI 1/U3 [V]	-0.793934	-35.62498	-34.83105
AI 1/I1 [A]	203.2113	307.5026	104.2913
AI 1/I2 [A]	-202.3902	-239.5028	-37.11260
AI 1/I3 [A]	1.669e-3	-67.23202	-67.23369
U1_tRMS@POWER/0 [V]	230.8028	230.6610	-0.141739
U2_tRMS@POWER/0 [V]	230.9451	230.9664	0.021347
U3_tRMS@POWER/0 [V]	230.7197	230.7673	0.047668
I1_tRMS@POWER/0 [A]	166.1521	165.8797	-0.272415
I2_tRMS@POWER/0 [A]	166.4600	166.3286	-0.131378
I3_tRMS@POWER/0 [A]	166.8282	166.7179	-0.110336
P_t@POWER/0 [W]	115276.8	115145.0	-131.8750
Q_t@POWER/0 [var]	1093.076	1210.888	117.8116
PF_t@POWER/0 []	0.999955	0.999945	-1.037e-5
U_fundRMS_SYM+@POWER/0 [V]	230.8191	230.7946	-0.024536

Prüfbericht-Nr.:  
Test report no.:


CN224DKW 001 Attachment 1

Seite 49 von 153  
Page 49 of 153

During dip



Time [s]	A	B	Delta
AI 1/U1 [V]	6.72368	6.89480	0.17112
AI 1/U2 [V]	299.3405	-322.5806	-621.9211
AI 1/U3 [V]	-262.0976	175.9324	438.0300
AI 1/I1 [A]	-40.74407	147.3188	188.0629
AI 1/I2 [A]	215.9245	22.04955	-193.8750
AI 1/I3 [A]	-185.9217	-7.794857	178.1268
AI 1/I3 [A]	-30.31361	-14.19246	16.12115
U1_tRMS@POWER/0 [V]	230.6610	30.01526	-200.6458
U2_tRMS@POWER/0 [V]	230.9664	30.17792	-200.7885
U3_tRMS@POWER/0 [V]	230.7673	30.06332	-200.7040
I1_tRMS@POWER/0 [A]	165.8797	8.420364	-157.4593
I2_tRMS@POWER/0 [A]	166.3286	8.468319	-157.8603
I3_tRMS@POWER/0 [A]	166.1719	8.544556	-158.1734
P_t@POWER/0 [W]	115145.0	741.8311	-114403.1
Q_t@POWER/0 [var]	1210.888	187.5549	-1023.333
PF_t@POWER/0 []	0.999945	0.966944	-0.030450
U_fundRMS_SYM+@POWER/0 [V]	230.7946	30.06460	-200.7300



Time [s]	A	B	Delta
AI 1/U1 [V]	6.82301	6.87389	0.05088
AI 1/U2 [V]	34.88612	-39.40344	-74.28956
AI 1/U3 [V]	-38.79452	32.83143	71.62595
AI 1/I1 [A]	3.725529	6.903649	3.178120
AI 1/I2 [A]	13.36801	-11.01601	-24.38402
AI 1/I3 [A]	-13.29911	11.35445	24.65356
AI 1/I3 [A]	-0.044823	-0.413537	-0.368714
U1_tRMS@POWER/0 [V]	30.02924	30.02027	-8.976e-3
U2_tRMS@POWER/0 [V]	30.16854	30.16704	-1.503e-3
U3_tRMS@POWER/0 [V]	30.05279	30.04761	-5.177e-3
I1_tRMS@POWER/0 [A]	8.429290	8.461449	0.032159
I2_tRMS@POWER/0 [A]	8.412232	8.473787	0.061555
I3_tRMS@POWER/0 [A]	8.690016	8.571336	-0.118680
P_t@POWER/0 [W]	736.3004	741.8449	5.544495
Q_t@POWER/0 [var]	218.6139	195.5763	-23.03767
PF_t@POWER/0 []	0.958638	0.966961	8.323e-3
U_fundRMS_SYM+@POWER/0 [V]	30.06162	30.05766	-3.954e-3


After dip

Prüfbericht-Nr.:  
Test report no.:


CN224DKW 001 Attachment 1

Seite 50 von 153  
Page 50 of 153



**Test No. 1.2 idle test**


Time [s]	A	B	Delta
	9.99369	0:10.16454	0.17085
AI 1/U1 [V]	-160.5587	9.770394	170.3291
AI 1/U2 [V]	-165.5908	31.02660	196.6174
AI 1/U3 [V]	325.5811	-40.64584	-366.2269
AI 1/I1 [A]	-0.921249	0.130057	1.051307
AI 1/I2 [A]	0.888586	-0.118971	-1.007557
AI 1/I3 [A]	5.007e-3	-0.041246	-0.046253
U1_tRMS@POWER/0 [V]	230.3129	29.96355	-200.3494
U2_tRMS@POWER/0 [V]	230.4378	30.13037	-200.3074
U3_tRMS@POWER/0 [V]	230.2596	30.03052	-200.2291
U_fundRMS_SYM+@POWER/0 [V]	230.3367	30.04126	-200.2954
U_fundRMS_SYM-@POWER/0 [V]	0.063896	0.063543	-3.536e-4


**Test No. 1.2 with PGU  
 Before dip**


Time [s]	A	B	Delta
	3.85001	5.84901	1.99900
AI 1/U1 [V]	325.7930	-43.43987	-282.3532
AI 1/U2 [V]	-170.0482	-32.52268	137.5256
AI 1/U3 [V]	-155.6389	-12.26163	143.3773
AI 1/I1 [A]	46.72766	103.5423	56.81467
AI 1/I2 [A]	-23.81599	-79.87631	-56.06032
AI 1/I3 [A]	-22.78221	-23.83900	-1.056790
U1_tRMS@POWER/0 [V]	230.4339	231.3441	0.910141
U2_tRMS@POWER/0 [V]	230.5291	230.1390	-0.390152
U3_tRMS@POWER/0 [V]	230.3736	229.7945	-0.579056
I1_tRMS@POWER/0 [A]	33.33472	33.47761	0.142883
I2_tRMS@POWER/0 [A]	33.38157	33.34067	-0.040897
I3_tRMS@POWER/0 [A]	33.43444	33.31470	-0.119736
P_t@POWER/0 [W]	23076.26	23070.61	-5.642578
Q_t@POWER/0 [var]	373.8032	356.5409	-17.26227
PF_t@POWER/0 []	0.999869	0.999881	1.180e-5
U_fundRMS_SYM+@POWER/0 [V]	230.4438	230.3984	-0.045334

During dip









**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 54 von 153  
 Page 54 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	1.1	1.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	13:15:1 4	13:15:1 4	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.15	0.15
	5	Setting dip duration		--		ms	170	170
	6	Point of fault entry	Total	--		s	9.99369	9.99369
	7	Point of fault clearance	Total	--		s	10.1645 4	10.1645 4
	8	Fault duration in empty load test	Total	--		ms	170.85	170.85
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.131	0.1306
10	Pos.				p.u.	1.001	1.0015	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.004	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.002	0.201	
	13	Active power	Total	t1-10s to t1	p.u.	1.002	0.201	
	14		Pos.			1.001	0.201	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.009	0.003	
	16		Pos.			0.009	0.003	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.131	0.132	
	19	Line current	Phase 1	t1+60ms	p.u.	0.053	0.053	
	20		Phase 2			0.050	0.055	
	21		Phase 3			0.055	0.051	
	22	Line current	Phase 1	t1+100ms	p.u.	0.051	0.052	
	23		Phase 2			0.051	0.052	
	24		Phase 3			0.052	0.052	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.006	0.006	
26	Pos.		0.006			0.006		
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.004	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.001	0.199	
	29		Pos.			1.001	0.199	
	30	Active power rising time	Pos.	--	s	0.449	0.112	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes		







Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 56 von 153  
Page 56 of 153



Time [s]	A	B	Delta
	9.998027	0:10.168539	0.170512
AI 1/U1 [V]	-23.38672	298.4126	321.7993
AI 1/U2 [V]	111.2204	-230.8879	-342.1083
AI 1/U3 [V]	-112.6535	-65.75561	46.89789
AI 1/I1 [A]	-265.1210	-24.02222	241.0988
AI 1/I2 [A]	228.4585	4.782439	-223.6761
AI 1/I3 [A]	39.70361	17.51983	-22.18378
U1_tRMS@POWER/0 [V]	230.7792	29.08387	-201.6953
U2_tRMS@POWER/0 [V]	230.9467	206.3722	-24.57445
U3_tRMS@POWER/0 [V]	230.7464	205.1960	-25.55038
I1_tRMS@POWER/0 [A]	167.3129	8.076260	-159.2366
I2_tRMS@POWER/0 [A]	167.6494	9.196913	-158.4525
I3_tRMS@POWER/0 [A]	168.0878	7.926978	-160.1609
P_t@POWER/0 [W]	116109.7	3286.866	-112822.8
Q_t@POWER/0 [var]	1214.455	1824.844	610.3892
PF_t@POWER/0 []	0.999945	0.874292	-0.125653
U_fundRMS_SYM+@POWER/0 [V]	230.8207	128.7171	-102.1036






Time [s]	A	B	Delta
	0:10.097968	0:10.148416	0.050448
AI 1/U1 [V]	-37.74262	40.07936	77.82197
AI 1/U2 [V]	136.4472	-95.37244	-231.8196
AI 1/U3 [V]	-126.4343	85.53148	211.9658
AI 1/I1 [A]	-11.00218	12.66956	23.67175
AI 1/I2 [A]	10.81669	-10.94616	-21.76285
AI 1/I3 [A]	0.161052	-1.752496	-1.913548
U1_tRMS@POWER/0 [V]	30.05396	30.01887	-0.035093
U2_tRMS@POWER/0 [V]	200.1550	200.2960	0.141006
U3_tRMS@POWER/0 [V]	199.1012	199.2309	0.129684
I1_tRMS@POWER/0 [A]	8.715985	8.425449	-0.290536
I2_tRMS@POWER/0 [A]	9.184925	8.898936	-0.285989
I3_tRMS@POWER/0 [A]	7.691195	7.624022	-0.067173
P_t@POWER/0 [W]	3079.887	3036.649	-43.23828
Q_t@POWER/0 [var]	1924.428	1847.078	-77.34998
PF_t@POWER/0 []	0.848060	0.854363	6.303e-3
U_fundRMS_SYM+@POWER/0 [V]	126.3812	126.4479	0.066658

After dip

**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**


 Seite 57 von 153  
 Page 57 of 153





Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 59 von 153  
Page 59 of 153



Time [s]	A	B	Delta
AI 1/U1 [V]	60.54569	-293.5357	-354.0814
AI 1/U2 [V]	68.25185	29.92535	-38.32650
AI 1/U3 [V]	-81.66433	262.8861	344.5504
AI 1/I1 [A]	91.74967	17.58921	-74.16046
AI 1/I2 [A]	-29.32108	-11.53243	17.78865
AI 1/I3 [A]	-66.08713	-6.110549	59.97658
U1_tRMS@POWER/0 [V]	229.8936	30.05604	-199.8375
U2_tRMS@POWER/0 [V]	230.7866	201.0770	-29.70966
U3_tRMS@POWER/0 [V]	230.6276	200.0980	-30.52962
I1_tRMS@POWER/0 [A]	33.22286	8.336529	-24.88633
I2_tRMS@POWER/0 [A]	33.40812	8.960395	-24.44773
I3_tRMS@POWER/0 [A]	33.42044	7.523364	-25.89708
P_t@POWER/0 [W]	23053.04	3058.665	-19994.37
Q_t@POWER/0 [var]	340.1598	1817.088	1476.928
PF_t@POWER/0 []	0.999891	0.859731	-0.140160
U_fundRMS_SYM+@POWER/0 [V]	230.4267	126.9408	-103.4859




Time [s]	A	B	Delta
AI 1/U1 [V]	42.39083	-41.28075	-83.67157
AI 1/U2 [V]	35.51531	-0.505209	-36.02052
AI 1/U3 [V]	-46.44585	7.012129	53.45798
AI 1/I1 [A]	9.512306	-7.861376	-17.37368
AI 1/I2 [A]	-5.189300	6.954909	12.14421
AI 1/I3 [A]	-4.362107	0.794888	5.156994
U1_tRMS@POWER/0 [V]	30.10540	30.10785	2.447e-3
U2_tRMS@POWER/0 [V]	200.7814	200.7786	-2.838e-3
U3_tRMS@POWER/0 [V]	199.7932	199.7956	2.350e-3
I1_tRMS@POWER/0 [A]	8.364895	8.368990	4.095e-3
I2_tRMS@POWER/0 [A]	8.951420	8.984138	0.032719
I3_tRMS@POWER/0 [A]	7.598106	7.615536	0.017430
P_t@POWER/0 [W]	3067.918	3080.319	12.40015
Q_t@POWER/0 [var]	1820.024	1819.076	-0.948608
PF_t@POWER/0 []	0.860046	0.861063	1.017e-3
U_fundRMS_SYM+@POWER/0 [V]	126.7887	126.7886	-9.918e-5

After dip

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 60 von 153  
Page 60 of 153






**Prüfbericht-Nr.:**  
 Test report no.:


**CN224DKW 001 Attachment 1**

 Seite 61 von 153  
 Page 61 of 153

Condition						Measurement	
	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.3	1.4
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15
	2	Time (start of test)	--	--	hh:mm:ss	15:52:1 9	15:52:1 9
	3	Fault type (phase)	--	--		2 phase	2 phase
	4	Setting voltage depth	Line to neutral	--	p.u.	0.15	0.15
	5	Setting dip duration		--	ms	170	170
	6	Point of fault entry	Total	--	s	9.99408	9.99408
	7	Point of fault clearance	Total	--	s	10.1666 9	10.1666 9
	8	Fault duration in empty load test	Total	--	ms	172.61	172.61
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.130	0.130
10	Pos.			p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.004	1.002
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.011	0.201
	13	Active power	Total	t1-10s to t1	p.u.	1.010	0.201
	14		Pos.			1.010	0.200
	15	Reactive power	Total	t1-10s to t1	p.u.	0.009	0.003
	16		Pos.			0.009	0.003
	17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.131	0.131
	19	Line current	Phase 1	t1+60ms	p.u.	0.056	0.051
	20		Phase 2			0.043	0.051
	21		Phase 3			0.051	0.047
	22	Line current	Phase 1	t1+100ms	p.u.	0.053	0.050
	23		Phase 2			0.055	0.054
	24		Phase 3			0.046	0.046
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.017	0.027
	26		Pos.			0.016	0.027
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.004	1.002
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.010	0.200
	29		Pos.			1.006	0.199
	30	Active power rising time	Pos.	--	s	0.420	0.119
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A
	32		Pos.			N/A	N/A
	33	Reactive power rising time	Pos.	--	s	N/A	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes

**Test No. 1.3(D2) idle test**


Time [s]	A	B	Delta
AI 1/U1 [V]	112.5615	-236.2373	-348.7988
AI 1/U2 [V]	-321.2395	241.8795	563.1190
AI 1/U3 [V]	208.2889	-22.82691	-231.1158
AI 1/I1 [A]	-0.998497	0.664830	1.663327
AI 1/I2 [A]	0.156760	-0.598192	-0.754952
AI 1/I3 [A]	0.812650	-0.093937	-0.906587
U1_trMS@POWER/0 [V]	230.2165	200.3036	-29.91293
U2_trMS@POWER/0 [V]	230.4737	200.4272	-30.04648
U3_trMS@POWER/0 [V]	230.3135	30.01465	-200.2988
U_fundRMS_SYM+@POWER/0 [V]	230.3342	126.8795	-103.4548
U_fundRMS_SYM-@POWER/0 [V]	0.154177	104.4444	104.2902

**Test No. 1.3(D2) with PGU  
 Before dip**



Time [s]	A	B	Delta
AI 1/U1 [V]	248.9433	17.77315	-231.1702
AI 1/U2 [V]	-307.6749	6.106377	313.7813
AI 1/U3 [V]	57.91164	-57.97410	-115.8857
AI 1/I1 [A]	181.6110	117.9237	-63.68721
AI 1/I2 [A]	-222.8596	85.31714	308.1768
AI 1/I3 [A]	41.03995	-202.5186	-243.5585
U1_trMS@POWER/0 [V]	230.7859	230.9818	0.195862
U2_trMS@POWER/0 [V]	230.9412	230.8354	-0.105743
U3_trMS@POWER/0 [V]	230.7357	230.6851	-0.050690
I1_trMS@POWER/0 [A]	167.3821	167.4865	0.104370
I2_trMS@POWER/0 [A]	167.6494	167.5263	-0.123077
I3_trMS@POWER/0 [A]	168.0116	167.9316	-0.080002
P_t@POWER/0 [W]	116106.8	116091.6	-15.21094
Q_t@POWER/0 [var]	1184.255	1080.700	-103.5546
PF_t@POWER/0 []	0.999948	0.999957	8.702e-6
U_fundRMS_SYM+@POWER/0 [V]	230.8177	230.8297	0.011963

Prüfbericht-Nr.:  
Test report no.:


CN224DKW 001 Attachment 1

Seite 63 von 153  
Page 63 of 153

During dip



Time [s]	A	B	Delta
	9.98117	0:10.14970	0.16853
AI 1/U1 [V]	4.254818	-128.4101	-132.6649
AI 1/U2 [V]	12.70938	116.5681	103.8587
AI 1/U3 [V]	-53.19262	38.57780	91.77042
AI 1/I1 [A]	108.3900	-12.76589	-121.1559
AI 1/I2 [A]	110.6639	0.123262	-110.5406
AI 1/I3 [A]	-218.5465	12.61735	231.1639
U1_tRMS@POWER/0 [V]	230.9818	200.1271	-30.85474
U2_tRMS@POWER/0 [V]	230.8354	199.5444	-31.29108
U3_tRMS@POWER/0 [V]	230.6851	30.05199	-200.6331
I1_tRMS@POWER/0 [A]	167.4865	8.923440	-158.5631
I2_tRMS@POWER/0 [A]	167.5263	7.614997	-159.9113
I3_tRMS@POWER/0 [A]	167.9316	8.370033	-159.5616
P_t@POWER/0 [W]	116091.6	3061.342	-113030.3
Q_t@POWER/0 [var]	1080.700	1810.977	730.2765
PF_t@POWER/0 []	0.999957	0.860680	-0.139277
U_fundRMS_SYM+@POWER/0 [V]	230.8297	126.6065	-104.2231



Time [s]	A	B	Delta
	0:10.10986	0:10.12990	0.02004
AI 1/U1 [V]	-120.9638	-112.5844	8.379460
AI 1/U2 [V]	110.0779	101.8014	-8.276463
AI 1/U3 [V]	39.09803	39.41131	0.313282
AI 1/I1 [A]	-11.31153	-11.50143	-0.189900
AI 1/I2 [A]	-1.052022	-1.404882	-0.352860
AI 1/I3 [A]	12.36093	12.84802	0.487089
U1_tRMS@POWER/0 [V]	200.1217	200.1255	3.754e-3
U2_tRMS@POWER/0 [V]	199.5491	199.5442	-4.868e-3
U3_tRMS@POWER/0 [V]	30.05639	30.04866	-7.729e-3
I1_tRMS@POWER/0 [A]	8.939065	8.918580	-0.020485
I2_tRMS@POWER/0 [A]	7.694782	7.651060	-0.043722
I3_tRMS@POWER/0 [A]	8.367007	8.358994	-8.013e-3
P_t@POWER/0 [W]	3078.463	3070.462	-8.001221
Q_t@POWER/0 [var]	1819.316	1807.029	-12.28674
PF_t@POWER/0 []	0.860899	0.861827	9.277e-4
U_fundRMS_SYM+@POWER/0 [V]	126.6085	126.6050	-3.479e-3


After dip



Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 64 von 153  
Page 64 of 153




**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**


 Seite 65 von 153  
 Page 65 of 153

Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	1.3(D2)
	1	Date	--	--	yyyy.mm.dd	2022.08.15
	2	Time (start of test)	--	--	hh:mm:ss	16:42:00
	3	Fault type (phase)	--	--		2 phase
	4	Setting voltage depth	Line to neutral	--	p.u.	0.15
	5	Setting dip duration		--	ms	170
	6	Point of fault entry	Total	--	s	9.98758
	7	Point of fault clearance	Total	--	s	10.15790
	8	Fault duration in empty load test	Total	--	ms	170.32
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	0.130
10	Pos.		p.u.		1.004	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.004
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.010
	13	Active power	Total	t1-10s to t1	p.u.	1.010
	14		Pos.			1.009
	15	Reactive power	Total	t1-10s to t1	p.u.	0.009
	16		Pos.			0.009
	17	Cos $\varphi$	--	t1-10s to t1	--	0.999
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.131
	19	Line current	Phase 1	t1+60ms	p.u.	0.050
	20		Phase 2			0.048
	21		Phase 3			0.054
	22	Line current	Phase 1	t1+100ms	p.u.	0.054
	23		Phase 2			0.047
	24		Phase 3			0.051
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.016
26	Pos.		0.016			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.004
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.010
	29		Pos.			1.010
	30	Active power rising time	Pos.	--	s	0.427
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A
	32		Pos.			N/A
	33	Reactive power rising time	Pos.	--	s	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes


**Test No. 2.1 idle test**

**Test No. 2.1 with PGU  
Before dip**


During dip



Time [s]	A	B	Delta
	9.99292	0:11.51242	1.51950
AI 1/U1 [V]	-109.8483	-213.6781	-103.8299
AI 1/U2 [V]	-58.87032	-61.48267	-2.612353
AI 1/U3 [V]	172.9550	223.1755	50.22049
AI 1/I1 [A]	-248.8405	18.21923	267.0597
AI 1/I2 [A]	63.10213	6.509185	-56.59294
AI 1/I3 [A]	184.9806	-24.56737	-209.5480
U1_tRMS@POWER/0 [V]	230.8119	112.1751	-118.6368
U2_tRMS@POWER/0 [V]	230.9640	112.2249	-118.7391
U3_tRMS@POWER/0 [V]	230.7938	112.1175	-118.6764
I1_tRMS@POWER/0 [A]	179.8022	8.307678	-171.4946
I2_tRMS@POWER/0 [A]	180.6296	8.329228	-172.3004
I3_tRMS@POWER/0 [A]	181.1508	8.267489	-172.8834
P_t@POWER/0 [W]	100395.5	2768.030	-97627.43
Q_t@POWER/0 [var]	74516.67	377.0446	-74139.63
PF_t@POWER/0 []	0.802984	0.990850	0.187866
U_fundRMS_SYM+@POWER/0 [V]	230.8527	112.1723	-118.6804




Time [s]	A	B	Delta
	0:10.09245	0:11.49100	1.39856
AI 1/U1 [V]	-115.6147	-150.1570	-34.54232
AI 1/U2 [V]	-34.99437	30.47180	65.46617
AI 1/U3 [V]	148.6697	119.4429	-29.22678
AI 1/I1 [A]	-9.604097	-11.09612	-1.492024
AI 1/I2 [A]	-0.626087	2.526999	3.153086
AI 1/I3 [A]	10.21349	8.546830	-1.666665
U1_tRMS@POWER/0 [V]	110.6473	112.1690	1.521706
U2_tRMS@POWER/0 [V]	110.9085	112.2311	1.322556
U3_tRMS@POWER/0 [V]	110.4090	112.1237	1.714630
I1_tRMS@POWER/0 [A]	8.221786	8.403695	0.181910
I2_tRMS@POWER/0 [A]	8.259031	8.445786	0.186755
I3_tRMS@POWER/0 [A]	8.201781	8.270570	0.068789
P_t@POWER/0 [W]	2702.568	2787.240	84.67188
Q_t@POWER/0 [var]	394.8920	414.1476	19.25565
PF_t@POWER/0 []	0.989493	0.989140	-3.524e-4
U_fundRMS_SYM+@POWER/0 [V]	110.6535	112.1743	1.520813

After dip

Prüfbericht-Nr.:  
Test report no.:


CN224DKW 001 Attachment 1

Seite 68 von 153  
Page 68 of 153







**Test No. 2.2 idle test**

**Test No. 2.2 with PGU  
Before dip**


During dip




Time [s]	A	B	Delta
	9.99600	0:11.51646	1.52046
AI 1/U1 [V]	-96.49277	-235.9710	-139.4782
AI 1/U2 [V]	170.9414	313.4916	142.5502
AI 1/U3 [V]	-72.62898	-77.64554	-5.016566
AI 1/I1 [A]	-6.790758	6.673098	13.46386
AI 1/I2 [A]	69.29028	-5.326987	-74.61727
AI 1/I3 [A]	-67.16502	-1.355648	65.80937
U1_tRMS@POWER/0 [V]	230.3957	112.1946	-118.2011
U2_tRMS@POWER/0 [V]	230.5858	112.2023	-118.3835
U3_tRMS@POWER/0 [V]	230.3908	112.1198	-118.2710
I1_tRMS@POWER/0 [A]	41.18972	8.225066	-32.96466
I2_tRMS@POWER/0 [A]	41.17127	8.281811	-32.88946
I3_tRMS@POWER/0 [A]	41.21570	8.306753	-32.90895
P_t@POWER/0 [W]	22890.12	2759.952	-20130.17
Q_t@POWER/0 [var]	16944.18	360.5042	-16583.68
PF_t@POWER/0 []	0.803750	0.991577	0.187827
U_fundRMS_SYM+@POWER/0 [V]	230.4563	112.1720	-118.2843




Time [s]	A	B	Delta
	0:10.09608	0:11.49571	1.39964
AI 1/U1 [V]	-96.26842	-88.19342	8.074999
AI 1/U2 [V]	156.9097	158.2339	1.324177
AI 1/U3 [V]	-60.36878	-70.00828	-9.639502
AI 1/I1 [A]	-6.995202	-5.666733	1.328468
AI 1/I2 [A]	11.96051	11.45697	-0.503540
AI 1/I3 [A]	-4.961729	-5.827666	-0.865936
U1_tRMS@POWER/0 [V]	111.8262	112.1612	0.334953
U2_tRMS@POWER/0 [V]	112.0621	112.2136	0.151543
U3_tRMS@POWER/0 [V]	111.6353	112.1379	0.502533
I1_tRMS@POWER/0 [A]	8.152849	8.217999	0.065150
I2_tRMS@POWER/0 [A]	8.254631	8.268262	0.013631
I3_tRMS@POWER/0 [A]	8.200034	8.250005	0.049971
P_t@POWER/0 [W]	2723.398	2750.369	26.97119
Q_t@POWER/0 [var]	396.7577	366.5723	-30.18546
PF_t@POWER/0 []	0.989554	0.991235	1.681e-3
U_fundRMS_SYM+@POWER/0 [V]	111.8400	112.1707	0.330711

After dip



Time [s]	A	B	Delta
AI 1/U1 [V]	0:11.51462	0:11.63251	0.11788
AI 1/U2 [V]	-38.46026	131.1092	169.5695
AI 1/U3 [V]	152.4122	192.9698	40.55763
AI 1/I1 [A]	-114.0401	-324.3623	-210.3222
AI 1/I2 [A]	-0.781655	21.92700	22.70866
AI 1/I3 [A]	10.84292	25.69056	14.84764
AI 1/I3 [A]	-10.09619	-47.65082	-37.55462
U1_tRMS@POWER/0 [V]	112.1946	230.4399	118.2453
U2_tRMS@POWER/0 [V]	112.2023	230.2278	118.0255
U3_tRMS@POWER/0 [V]	112.1198	230.7117	118.5919
I1_tRMS@POWER/0 [A]	8.225066	33.02239	24.79732
I2_tRMS@POWER/0 [A]	8.281811	33.21028	24.92847
I3_tRMS@POWER/0 [A]	8.306753	33.09782	24.79107
P_t@POWER/0 [W]	2759.952	22801.36	20041.41
Q_t@POWER/0 [var]	360.5042	2031.307	1670.802
PF_t@POWER/0 []	0.991577	0.996055	4.478e-3
U_fundRMS_SYM+@POWER/0 [V]	112.1720	230.4593	118.2873





Time [s]	A	B	Delta
AI 1/U1 [V]	0:14.52360	0:21.52712	7.00352
AI 1/U2 [V]	-26.38936	294.3206	320.7100
AI 1/U3 [V]	-268.3988	-267.8270	0.571728
AI 1/I1 [A]	294.2779	-26.38340	-320.6613
AI 1/I2 [A]	-24.67656	28.86176	53.53833
AI 1/I3 [A]	-26.71659	-55.81951	-29.10292
AI 1/I3 [A]	51.53311	25.73729	-25.79582
U1_tRMS@POWER/0 [V]	230.4318	230.4574	0.025574
U2_tRMS@POWER/0 [V]	230.5809	230.5660	-0.014893
U3_tRMS@POWER/0 [V]	230.4057	230.3608	-0.044907
I1_tRMS@POWER/0 [A]	36.03171	40.28246	4.250744
I2_tRMS@POWER/0 [A]	36.13643	40.46002	4.323589
I3_tRMS@POWER/0 [A]	36.13575	40.48960	4.353855
P_t@POWER/0 [W]	22785.90	22794.99	9.093750
Q_t@POWER/0 [var]	10191.16	16155.29	5964.137
PF_t@POWER/0 []	0.912856	0.815875	-0.096981
U_fundRMS_SYM+@POWER/0 [V]	230.4715	230.4603	-0.011261



**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**

 Seite 72 von 153  
 Page 72 of 153


Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	2.1	2.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	17:01:1 0	17:01:1 0	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.5	0.5
	5	Setting dip duration		--		ms	1518	1518
	6	Point of fault entry	Total	--		s	9.99644	9.99644
	7	Point of fault clearance	Total	--		s	11.5146 3	11.5146 3
	8	Fault duration in empty load test	Total	--		ms	1518.20	1518.20
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.488	0.488
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.004	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.088	0.248	
	13	Active power	Total	t1-10s to t1	p.u.	0.873	0.199	
	14		Pos.			0.873	0.199	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.648	0.148	
	16		Pos.			0.648	0.147	
17	Cos $\phi$	--	t1-10s to t1	--	0.803	0.803		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.481	0.488	
	19	Line current	Phase 1	t1+60ms	p.u.	0.049	0.049	
	20		Phase 2			0.053	0.051	
	21		Phase 3			0.049	0.048	
	22	Line current	Phase 1	t1+100ms	p.u.	0.049	0.049	
	23		Phase 2			0.050	0.050	
	24		Phase 3			0.049	0.049	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.024	0.024	
	26		Pos.			0.024	0.024	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.004	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.868	0.198	
	29		Pos.			0.874	0.198	
	30	Active power rising time	Pos.	--	s	0.368	0.118	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.380	0.089	
	32		Pos.			0.614	0.140	
	33	Reactive power rising time	Pos.	--	s	10	10	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	




Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 74 von 153  
Page 74 of 153



Time [s]	A	B	Delta
	9.99655	0:11.51451	1.51796
AI 1/U1 [V]	146.5974	70.18304	-76.41435
AI 1/U2 [V]	-207.3486	-287.5009	-80.15228
AI 1/U3 [V]	65.51814	216.5542	151.0360
AI 1/I1 [A]	120.4454	3.791929	-116.6534
AI 1/I2 [A]	-253.7244	-12.41505	241.3093
AI 1/I3 [A]	133.2027	8.647204	-124.5555
U1_tRMS@POWER/0 [V]	231.2300	111.5622	-119.6678
U2_tRMS@POWER/0 [V]	230.7951	207.3622	-23.43294
U3_tRMS@POWER/0 [V]	230.5341	207.1490	-23.38507
I1_tRMS@POWER/0 [A]	179.8327	8.249948	-171.5828
I2_tRMS@POWER/0 [A]	180.9214	8.654881	-172.2666
I3_tRMS@POWER/0 [A]	180.8060	7.924991	-172.8810
P_t@POWER/0 [W]	100405.4	4158.699	-96246.68
Q_t@POWER/0 [var]	74490.75	1298.586	-73192.16
PF_t@POWER/0 []	0.803112	0.954546	0.151434
U_fundRMS_SYM+@POWER/0 [V]	230.8452	171.1230	-59.72226




Time [s]	A	B	Delta
	0:10.09580	0:11.49408	1.39828
AI 1/U1 [V]	115.9926	47.04452	-68.94803
AI 1/U2 [V]	-244.9050	-291.8866	-46.98158
AI 1/U3 [V]	126.7417	244.4403	117.6987
AI 1/I1 [A]	8.302093	1.600385	-6.701708
AI 1/I2 [A]	-11.75630	-11.12437	0.631928
AI 1/I3 [A]	3.392577	9.485007	6.092430
U1_tRMS@POWER/0 [V]	110.6578	112.1678	1.510056
U2_tRMS@POWER/0 [V]	203.8569	206.4067	2.549774
U3_tRMS@POWER/0 [V]	202.9696	206.2341	3.264481
I1_tRMS@POWER/0 [A]	8.388457	8.224748	-0.163710
I2_tRMS@POWER/0 [A]	8.709339	8.687604	-0.021735
I3_tRMS@POWER/0 [A]	7.902981	7.877448	-0.025534
P_t@POWER/0 [W]	4066.062	4137.599	71.53638
Q_t@POWER/0 [var]	1422.688	1311.009	-111.6788
PF_t@POWER/0 []	0.943890	0.953291	9.401e-3
U_fundRMS_SYM+@POWER/0 [V]	168.4467	170.8443	2.397598

After dip

Prüfbericht-Nr.:  
Test report no.:



CN224DKW 001 Attachment 1

Seite 75 von 153  
Page 75 of 153



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**


 Seite 76 von 153  
 Page 76 of 153





Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 77 von 153  
Page 77 of 153



Time [s]	A	B	Delta
	9.99444	0:11.51326	1.51881
AI 1/U1 [V]	42.57965	183.0156	140.4359
AI 1/U2 [V]	251.9932	133.9951	-117.9981
AI 1/U3 [V]	-291.0767	-326.0358	-34.95908
AI 1/I1 [A]	45.94744	-0.180244	-46.12768
AI 1/I2 [A]	10.40018	4.766226	-5.633951
AI 1/I3 [A]	-56.43666	-4.405737	52.03092
U1_trMS@POWER/0 [V]	230.5723	112.0279	-118.5444
U2_trMS@POWER/0 [V]	230.5058	206.6220	-23.88385
U3_trMS@POWER/0 [V]	230.3216	206.4571	-23.86446
I1_trMS@POWER/0 [A]	41.08278	8.275843	-32.80694
I2_trMS@POWER/0 [A]	41.19530	8.641236	-32.55407
I3_trMS@POWER/0 [A]	41.12214	7.903700	-33.21843
P_t@POWER/0 [W]	22828.36	4144.248	-18684.11
Q_t@POWER/0 [var]	16961.08	1303.365	-15657.72
PF_t@POWER/0 []	0.802696	0.953935	0.151240
U_fundRMS_SYM+@POWER/0 [V]	230.4651	170.9172	-59.54794




Time [s]	A	B	Delta
	0:10.09640	0:11.49496	1.39856
AI 1/U1 [V]	-56.14114	13.93437	70.07552
AI 1/U2 [V]	290.3738	272.2063	-18.16750
AI 1/U3 [V]	-234.4849	-286.3898	-51.90492
AI 1/I1 [A]	-2.480030	0.604868	3.084898
AI 1/I2 [A]	11.05201	7.655383	-3.396630
AI 1/I3 [A]	-8.650542	-8.282304	0.368238
U1_trMS@POWER/0 [V]	111.8384	112.1630	0.324600
U2_trMS@POWER/0 [V]	205.9623	206.4139	0.451553
U3_trMS@POWER/0 [V]	205.2779	206.2462	0.968353
I1_trMS@POWER/0 [A]	8.181339	8.291390	0.110051
I2_trMS@POWER/0 [A]	8.584079	8.704296	0.120217
I3_trMS@POWER/0 [A]	7.943722	7.958221	0.014500
P_t@POWER/0 [W]	4123.437	4172.357	48.91992
Q_t@POWER/0 [var]	1266.840	1292.712	25.87146
PF_t@POWER/0 []	0.955903	0.955204	-6.995e-4
U_fundRMS_SYM+@POWER/0 [V]	170.2702	170.8495	0.579285

After dip

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 78 von 153  
Page 78 of 153





**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 79 von 153  
 Page 79 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	2.3	2.4	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	17:58:0 0	17:58:0 0	
	3	Fault type (phase)	--	--		2 phase	2 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.5	0.5
	5	Setting dip duration		--		ms	1518	1518
	6	Point of fault entry	Total	--		s	9.99042	9.99042
	7	Point of fault clearance	Total	--		s	11.5113 6	11.5113 6
	8	Fault duration in empty load test	Total	--		ms	1520.95	1520.95
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.488	0.488
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.004	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.088	0.248	
	13	Active power	Total	t1-10s to t1	p.u.	0.873	0.198	
	14		Pos.			0.873	0.199	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.647	0.148	
	16		Pos.			0.648	0.147	
17	Cos $\phi$	--	t1-10s to t1	--	0.804	0.802		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.487	0.488	
	19	Line current	Phase 1	t1+60ms	p.u.	0.051	0.051	
	20		Phase 2			0.052	0.049	
	21		Phase 3			0.048	0.048	
	22	Line current	Phase 1	t1+100ms	p.u.	0.051	0.049	
	23		Phase 2			0.052	0.052	
	24		Phase 3			0.048	0.048	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.035	0.036	
26	Pos.		0.036			0.036		
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.004	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.868	0.198	
	29		Pos.			0.873	0.199	
	30	Active power rising time	Pos.	--	s	0.380	0.099	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	0.384	0.089	
	32		Pos.			0.616	0.141	
	33	Reactive power rising time	Pos.	--	s	10	10	
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes		









**Prüfbericht-Nr.:**  
 Test report no.:


**CN224DKW 001 Attachment 1**

 Seite 82 von 153  
 Page 82 of 153



**Test No. 3.2 idle test**

**Test No. 3.2 with PGU  
 Before dip**


During dip



Time [s]	A	B	Delta
AI 1/U1 [V]	162.7488	129.5631	-33.18572
AI 1/U2 [V]	-98.65952	-144.2053	-45.54582
AI 1/U3 [V]	-65.27090	14.32014	79.59104
AI 1/I1 [A]	65.83298	9.869815	-55.96316
AI 1/I2 [A]	-6.372810	-10.68592	-4.313112
AI 1/I3 [A]	-57.66261	0.778675	58.44128
U1_tRMS@POWER/0 [V]	230.3986	112.1626	-118.2361
U2_tRMS@POWER/0 [V]	230.4892	112.2314	-118.2578
U3_tRMS@POWER/0 [V]	230.3150	112.1226	-118.1924
I1_tRMS@POWER/0 [A]	41.69176	8.208763	-33.48300
I2_tRMS@POWER/0 [A]	41.72783	8.294829	-33.43300
I3_tRMS@POWER/0 [A]	41.76194	8.239311	-33.52263
P_t@POWER/0 [W]	22953.43	2749.918	-20203.51
Q [var]	-17464.18	375.7422	17839.92
PF_t@POWER/0 []	0.795835	0.990794	0.194959
U_fundRMS_SYM+@POWER/0 [V]	230.3996	112.1720	-118.2277



Time [s]	A	B	Delta
AI 1/U1 [V]	152.2110	78.38941	-73.82155
AI 1/U2 [V]	-116.9374	-158.8359	-41.89849
AI 1/U3 [V]	-36.43966	80.37186	116.8115
AI 1/I1 [A]	10.39112	4.824996	-5.566120
AI 1/I2 [A]	-9.103656	-11.88076	-2.777100
AI 1/I3 [A]	-1.313329	7.011652	8.324981
U1_tRMS@POWER/0 [V]	112.7206	112.1634	-0.557236
U2_tRMS@POWER/0 [V]	112.9312	112.2310	-0.700172
U3_tRMS@POWER/0 [V]	112.5158	112.1184	-0.397400
I1_tRMS@POWER/0 [A]	8.238027	8.262645	0.024618
I2_tRMS@POWER/0 [A]	8.207569	8.260685	0.053116
I3_tRMS@POWER/0 [A]	8.277748	8.274929	-2.819e-3
P_t@POWER/0 [W]	2754.136	2757.078	2.941162
Q [var]	425.8393	368.8626	-56.97665
PF_t@POWER/0 []	0.988257	0.991169	2.912e-3
U_fundRMS_SYM+@POWER/0 [V]	112.7212	112.1707	-0.550461


After dip




Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 85 von 153  
Page 85 of 153



Time [s]	A	B	Delta
	0:11.51638	0:11.61978	0.10340
AI 1/U1 [V]	134.9161	283.1621	148.2461
AI 1/U2 [V]	-139.8711	-2.469063	137.4021
AI 1/U3 [V]	4.926205	-281.0590	-285.9852
AI 1/I1 [A]	10.18858	42.80222	32.61364
AI 1/I2 [A]	-11.12068	-5.831361	5.289316
AI 1/I3 [A]	0.937700	-38.21194	-39.14964
U1_tRMS@POWER/0 [V]	112.1626	230.4075	118.2450
U2_tRMS@POWER/0 [V]	112.2314	230.2030	117.9716
U3_tRMS@POWER/0 [V]	112.1226	230.6469	118.5243
I1_tRMS@POWER/0 [A]	8.208763	34.41064	26.20188
I2_tRMS@POWER/0 [A]	8.294829	34.25594	25.96111
I3_tRMS@POWER/0 [A]	8.239311	34.48195	26.24264
P_t@POWER/0 [W]	2749.918	23746.82	20996.91
Q [var]	375.7422	989.8982	614.1560
PF_t@POWER/0 []	0.990794	0.999132	0.339e-3
U_fundRMS_SYM+@POWER/0 [V]	112.1720	230.4184	118.2465





Time [s]	A	B	Delta
	0:14.54123	0:21.56490	7.02367
AI 1/U1 [V]	173.1277	-196.7602	-369.8879
AI 1/U2 [V]	152.1897	323.7472	171.5574
AI 1/U3 [V]	-325.5890	-125.5949	199.9941
AI 1/I1 [A]	6.809712	-55.29702	-62.10673
AI 1/I2 [A]	40.24029	42.30833	2.068043
AI 1/I3 [A]	-47.25719	13.02409	60.28128
U1_tRMS@POWER/0 [V]	230.3720	230.4069	0.034912
U2_tRMS@POWER/0 [V]	230.4755	230.5210	0.045547
U3_tRMS@POWER/0 [V]	230.3314	230.3262	-5.127e-3
I1_tRMS@POWER/0 [A]	36.17057	40.72757	4.557003
I2_tRMS@POWER/0 [A]	36.31139	40.86963	4.558239
I3_tRMS@POWER/0 [A]	36.31513	40.85624	4.541111
P_t@POWER/0 [W]	22941.45	22841.40	-100.0508
Q [var]	-10099.43	-16564.54	-6465.115
PF_t@POWER/0 []	0.915239	0.809534	-0.105705
U_fundRMS_SYM+@POWER/0 [V]	230.3914	230.4167	0.025269


**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**

 Seite 86 von 153  
 Page 86 of 153


Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	3.1	3.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	17:01:1 0	17:01:1 0	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.5	0.5
	5	Setting dip duration		--		ms	1518	1518
	6	Point of fault entry	Total	--		s	9.99644	9.99644
	7	Point of fault clearance	Total	--		s	11.5146 3	11.5146 3
	8	Fault duration in empty load test	Total	--		ms	1518.20	1518.20
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.488	0.488
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.091	0.251	
	13	Active power	Total	t1-10s to t1	p.u.	0.868	0.199	
	14		Pos.			0.866	0.200	
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.659	-0.152	
	16		Pos.			-0.647	-0.152	
17	Cos $\phi$	--	t1-10s to t1	--	0.796	0.802		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.488	0.488	
	19	Line current	Phase 1	t1+60ms	p.u.	0.051	0.051	
	20		Phase 2			0.052	0.049	
	21		Phase 3			0.048	0.050	
	22	Line current	Phase 1	t1+100ms	p.u.	0.051	0.049	
	23		Phase 2			0.052	0.049	
	24		Phase 3			0.048	0.050	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.024	0.024	
26	Pos.		0.024			0.024		
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.851	0.199	
	29		Pos.			0.850	0.199	
	30	Active power rising time	Pos.	--	s	0.365	0.103	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.387	-0.088	
	32		Pos.			-0.620	-0.144	
	33	Reactive power rising time	Pos.	--	s	10	10	
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes		










Time [s]	A	B	Delta
9.99878	0:11.51614	1.51736	
AI 1/U1 [V]	-160.8989	-122.0794	38.81955
AI 1/U2 [V]	134.9540	292.6626	157.7087
AI 1/U3 [V]	27.77434	-189.0772	-216.8515
AI 1/I1 [A]	-271.5480	10.22899	281.7770
AI 1/I2 [A]	38.09619	4.323244	-33.77295
AI 1/I3 [A]	235.2370	-14.49311	-249.7301
U1_tRMS@POWER/0 [V]	230.5720	112.2173	-118.3547
U2_tRMS@POWER/0 [V]	230.7235	206.3581	-24.36546
U3_tRMS@POWER/0 [V]	230.5322	206.1922	-24.33998
I1_tRMS@POWER/0 [A]	180.7570	8.392798	-172.3642
I2_tRMS@POWER/0 [A]	181.2468	8.803678	-172.4431
I3_tRMS@POWER/0 [A]	181.8569	8.084840	-173.7721
P_t@POWER/0 [W]	99842.47	4231.979	-95610.49
Q [var]	-75904.40	1294.574	77198.97
PF_t@POWER/0 []	0.796070	0.956259	0.160189
U_fundRMS_SYM+@POWER/0 [V]	230.6049	170.8379	-59.76701




Time [s]	A	B	Delta
0:10.09819	0:11.49103	1.39284	
AI 1/U1 [V]	-146.6713	136.9834	283.6547
AI 1/U2 [V]	188.3965	72.37769	-116.0188
AI 1/U3 [V]	-38.95331	-210.7229	-171.7696
AI 1/I1 [A]	-11.61599	11.96754	23.58353
AI 1/I2 [A]	11.54602	-3.783703	-15.32972
AI 1/I3 [A]	0.081778	-8.177042	-8.258820
U1_tRMS@POWER/0 [V]	113.3641	112.1814	-1.182671
U2_tRMS@POWER/0 [V]	208.7018	206.4138	-2.288010
U3_tRMS@POWER/0 [V]	208.0589	206.2445	-1.814377
I1_tRMS@POWER/0 [A]	8.386936	8.425336	0.038400
I2_tRMS@POWER/0 [A]	8.762168	8.814753	0.052585
I3_tRMS@POWER/0 [A]	8.104587	8.075561	-0.029026
P_t@POWER/0 [W]	4263.709	4235.103	-28.60693
Q [var]	1327.839	1300.199	-27.64001
PF_t@POWER/0 []	0.954771	0.955963	1.193e-3
U_fundRMS_SYM+@POWER/0 [V]	172.5656	170.8556	-1.709930

After dip










Time [s]	A	B	Delta
AI 1/U1 [V]	146.7049	71.34343	-75.36149
AI 1/U2 [V]	-326.0322	-287.0517	38.98049
AI 1/U3 [V]	177.0082	214.8352	37.82702
AI 1/I1 [A]	53.65026	3.903866	-49.74640
AI 1/I2 [A]	-49.05379	-12.20346	36.85034
AI 1/I3 [A]	-3.848315	8.278847	12.12716
U1_tRMS@POWER/0 [V]	231.0423	111.5286	-119.5136
U2_tRMS@POWER/0 [V]	230.2438	207.4749	-22.76894
U3_tRMS@POWER/0 [V]	229.9477	207.2243	-22.72342
I1_tRMS@POWER/0 [A]	41.65191	8.118587	-33.53333
I2_tRMS@POWER/0 [A]	41.51966	8.601213	-32.91844
I3_tRMS@POWER/0 [A]	41.81450	7.747000	-34.06750
P_t@POWER/0 [W]	22896.35	4091.165	-18805.18
Q [var]	-17466.84	1308.609	18775.45
PF_t@POWER/0 []	0.795063	0.952462	0.157399
U_fundRMS_SYM+@POWER/0 [V]	230.3995	171.1610	-59.23849




Time [s]	A	B	Delta
AI 1/U1 [V]	30.67398	43.41936	12.74538
AI 1/U2 [V]	-291.8937	-291.8749	0.018835
AI 1/U3 [V]	261.5910	247.9675	-13.62348
AI 1/I1 [A]	0.763893	1.290083	0.526190
AI 1/I2 [A]	-10.63836	-10.43451	0.203848
AI 1/I3 [A]	9.976149	9.061575	-0.914574
U1_tRMS@POWER/0 [V]	112.7309	112.1736	-0.557281
U2_tRMS@POWER/0 [V]	207.5848	206.4333	-1.151520
U3_tRMS@POWER/0 [V]	206.8618	206.2347	-0.627121
I1_tRMS@POWER/0 [A]	8.175544	8.165303	-0.010241
I2_tRMS@POWER/0 [A]	8.666278	8.665733	-0.010545
I3_tRMS@POWER/0 [A]	7.829175	7.752389	-0.076786
P_t@POWER/0 [W]	4135.282	4101.161	-34.12158
Q [var]	1317.805	1297.699	-20.10669
PF_t@POWER/0 []	0.952790	0.953409	6.189e-4
U_fundRMS_SYM+@POWER/0 [V]	171.6035	170.8550	-0.748459

After dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 92 von 153  
Page 92 of 153



Time [s]	A	B	Delta
AI 1/U1 [V]	38.78284	-72.21795	-111.0008
AI 1/U2 [V]	-291.7938	-239.2206	52.57321
AI 1/U3 [V]	252.6391	311.4212	58.78210
AI 1/I1 [A]	1.059294	-11.39128	-12.45058
AI 1/I2 [A]	-10.51414	-33.89693	-23.38278
AI 1/I3 [A]	9.389520	45.51995	36.13043
U1_tRMS@POWER/0 [V]	111.5286	230.4469	118.9182
U2_tRMS@POWER/0 [V]	207.4749	230.4635	22.98868
U3_tRMS@POWER/0 [V]	207.2243	230.5583	23.33405
I1_tRMS@POWER/0 [A]	8.118587	33.01830	24.89971
I2_tRMS@POWER/0 [A]	8.601213	33.22156	24.62035
I3_tRMS@POWER/0 [A]	7.747000	32.94956	25.20256
P_t@POWER/0 [W]	4091.165	22818.32	18727.15
Q [var]	1308.609	1414.487	105.8776
PF_t@POWER/0 []	0.952462	0.998084	0.045622
U_fundRMS_SYM+@POWER/0 [V]	171.1610	230.4891	59.32811



Time [s]	A	B	Delta
AI 1/U1 [V]	-75.04869	199.8410	274.8897
AI 1/U2 [V]	-236.6984	-323.3156	-86.61724
AI 1/U3 [V]	312.7992	122.3328	-190.4664
AI 1/I1 [A]	9.173751	55.22323	46.04948
AI 1/I2 [A]	-48.60974	-41.02063	7.589102
AI 1/I3 [A]	39.47616	-14.08482	-53.56098
U1_tRMS@POWER/0 [V]	230.3853	230.3842	-1.114e-3
U2_tRMS@POWER/0 [V]	230.4747	230.5252	0.050491
U3_tRMS@POWER/0 [V]	230.3120	230.3323	0.020279
I1_tRMS@POWER/0 [A]	36.17421	40.59988	4.425674
I2_tRMS@POWER/0 [A]	36.21788	40.57192	4.354038
I3_tRMS@POWER/0 [A]	36.28209	40.65791	4.375824
P_t@POWER/0 [W]	22922.58	22631.56	-291.0137
Q [var]	-10071.37	-16607.45	-6536.079
PF_t@POWER/0 []	0.915529	0.806219	-0.109311
U_fundRMS_SYM+@POWER/0 [V]	230.3892	230.4126	0.023407



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 93 von 153  
 Page 93 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	3.3	3.4	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	17:58:0 0	17:58:0 0	
	3	Fault type (phase)	--	--		2 phase	2 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.5	0.5
	5	Setting dip duration		--		ms	1518	1518
	6	Point of fault entry	Total	--		s	9.99042	9.99042
	7	Point of fault clearance	Total	--		s	11.5113 6	11.5113 6
	8	Fault duration in empty load test	Total	--		ms	1520.95	1520.95
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.488	0.488
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.091	0.251	
	13	Active power	Total	t1-10s to t1	p.u.	0.869	0.199	
	14		Pos.			0.868	0.199	
	15	Reactive power	Total	t1-10s to t1	p.u.	-0.657	-0.152	
	16		Pos.			-0.660	-0.152	
17	Cos $\phi$	--	t1-10s to t1	--	0.797	0.795		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.488	0.488	
	19	Line current	Phase 1	t1+60ms	p.u.	0.052	0.051	
	20		Phase 2			0.048	0.051	
	21		Phase 3			0.049	0.048	
	22	Line current	Phase 1	t1+100ms	p.u.	0.051	0.049	
	23		Phase 2			0.053	0.052	
	24		Phase 3			0.049	0.047	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.037	0.036	
	26		Pos.			0.037	0.036	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.869	0.199	
	29		Pos.			0.870	0.197	
	30	Active power rising time	Pos.	--	s	0.365	0.118	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	-0.384	-0.088	
	32		Pos.			-0.624	-0.144	
	33	Reactive power rising time	Pos.	--	s	10	10	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	




**Test No. 4.1 idle test**

**Test No. 4.1 with PGU  
 Before dip**


During dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 95 von 153  
Page 95 of 153



Time [s]	A	B	Delta
AI 1/U1 [V]	-88.31358	-144.3102	-55.99666
AI 1/U2 [V]	-180.7890	-129.5948	51.19419
AI 1/U3 [V]	268.8201	273.5644	4.744292
AI 1/I1 [A]	-86.21800	-133.7645	-47.54651
AI 1/I2 [A]	-166.9498	-124.8489	42.10091
AI 1/I3 [A]	253.2762	258.6686	5.392313
U1_tRMS@POWER/0 [V]	230.7215	193.7454	-36.97609
U2_tRMS@POWER/0 [V]	230.9872	193.8746	-37.11267
U3_tRMS@POWER/0 [V]	230.8215	193.7096	-37.11195
I1_tRMS@POWER/0 [A]	167.2387	182.0051	14.76643
I2_tRMS@POWER/0 [A]	167.6576	182.7706	15.11299
I3_tRMS@POWER/0 [A]	168.0655	183.2934	15.22792
P_t@POWER/0 [W]	116100.5	106196.4	-9904.008
Q_t@POWER/0 [var]	1078.839	1172.858	94.01831
PF_t@POWER/0 []	0.999957	0.999939	-1.782e-5
U_fundRMS_SYM+@POWER/0 [V]	230.8399	193.7720	-37.06789




Time [s]	A	B	Delta
AI 1/U1 [V]	-230.0141	267.3097	497.3238
AI 1/U2 [V]	243.6018	-186.0426	-429.6444
AI 1/U3 [V]	-10.43272	-82.11017	-71.67745
AI 1/I1 [A]	-219.1503	252.0627	471.2130
AI 1/I2 [A]	222.3477	-172.0798	-394.4276
AI 1/I3 [A]	-3.381849	-80.36197	-76.98012
U1_tRMS@POWER/0 [V]	193.7624	193.7757	0.013290
U2_tRMS@POWER/0 [V]	193.8586	193.8793	0.020691
U3_tRMS@POWER/0 [V]	193.6920	193.7204	0.028397
I1_tRMS@POWER/0 [A]	180.1044	182.0259	1.921448
I2_tRMS@POWER/0 [A]	180.7382	182.7774	2.039154
I3_tRMS@POWER/0 [A]	181.2538	183.2889	2.035126
P_t@POWER/0 [W]	104984.5	106210.0	1225.438
Q_t@POWER/0 [var]	3490.495	1107.818	-2382.677
PF_t@POWER/0 []	0.999448	0.999946	4.978e-4
U_fundRMS_SYM+@POWER/0 [V]	193.7664	193.7872	0.020752



After dip

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 96 von 153  
Page 96 of 153




**Test No. 4.2 idle test**

**Test No. 4.2 with PGU  
 Before dip**


During dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 98 von 153  
Page 98 of 153



Time [s]	A	B	Delta
AI 1/U1 [V]	199.2724	246.6984	47.42599
AI 1/U2 [V]	-323.0858	-225.8320	97.25381
AI 1/U3 [V]	123.5328	-24.92452	-148.4573
AI 1/I1 [A]	29.45066	51.21541	21.76476
AI 1/I2 [A]	-46.46671	-45.53378	0.932932
AI 1/I3 [A]	16.94989	-4.921675	-21.87157
U1_tRMS@POWER/0 [V]	230.4449	193.3756	-37.06931
U2_tRMS@POWER/0 [V]	230.5611	193.5025	-37.05859
U3_tRMS@POWER/0 [V]	230.3557	193.3248	-37.03081
I1_tRMS@POWER/0 [A]	33.31846	39.60799	6.289536
I2_tRMS@POWER/0 [A]	33.38300	39.64545	6.262444
I3_tRMS@POWER/0 [A]	33.36890	39.70418	6.335274
P_t@POWER/0 [W]	23057.33	23004.03	-53.30273
Q_t@POWER/0 [var]	444.1763	338.6569	-105.5194
PF_t@POWER/0 []	0.999815	0.999892	7.713e-5
U_fundRMS_SYM+@POWER/0 [V]	230.4521	193.3987	-37.05344




Time [s]	A	B	Delta
AI 1/U1 [V]	-11.21163	-261.4460	-250.2344
AI 1/U2 [V]	-230.0632	60.06718	290.1304
AI 1/U3 [V]	243.0039	200.7413	-42.26256
AI 1/I1 [A]	-1.478434	-54.49200	-53.01357
AI 1/I2 [A]	-47.93275	12.07542	60.00817
AI 1/I3 [A]	47.99021	42.33027	-5.659938
U1_tRMS@POWER/0 [V]	193.3783	193.3958	0.017502
U2_tRMS@POWER/0 [V]	193.4795	193.4928	0.013245
U3_tRMS@POWER/0 [V]	193.3088	193.3507	0.041901
I1_tRMS@POWER/0 [A]	39.56332	39.54719	-0.016129
I2_tRMS@POWER/0 [A]	39.65802	39.60833	-0.049688
I3_tRMS@POWER/0 [A]	39.62736	39.65178	0.024426
P_t@POWER/0 [W]	22977.30	22976.47	-0.830078
Q_t@POWER/0 [var]	555.9703	333.5486	-222.4217
PF_t@POWER/0 []	0.999707	0.999895	1.872e-4
U_fundRMS_SYM+@POWER/0 [V]	193.3866	193.4108	0.024200

After dip

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 99 von 153  
Page 99 of 153





**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 100 von 153  
 Page 100 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	4.1	4.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	18:29:0 0	18:29:0 0	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.85	0.85
	5	Setting dip duration		--		s	60000	60000
	6	Point of fault entry	Total	--		s	9.98254	9.98254
	7	Point of fault clearance	Total	--		s	70.0004 1	70.0004 1
	8	Fault duration in empty load test	Total	--		ms	60000	60000
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.840	0.840
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.010	0.201	
	13	Active power	Total	t1-10s to t1	p.u.	1.010	0.200	
	14		Pos.			1.010	0.199	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010	0.003	
	16		Pos.			0.009	0.026	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.991		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.842	0.841	
	19	Line current	Phase 1	t1+60ms	p.u.	1.054	0.242	
	20		Phase 2			1.114	0.243	
	21		Phase 3			1.096	0.241	
	22	Line current	Phase 1	t1+100ms	p.u.	1.102	0.252	
	23		Phase 2			1.054	0.261	
	24		Phase 3			1.090	0.259	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.913	0.200	
	26		Pos.			0.924	0.200	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.002	0.201	
	29		Pos.			1.005	0.200	
	30	Active power rising time	Pos.	--	s	0.133	0.101	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	



**Test No. 4.3 idle test**

**Test No. 4.3 with PGU  
 Before dip**


During dip



Time [s]	A	B	Delta
	9.99253	1:10.00025	1:00.00772
AI 1/U1 [V]	-196.4171	203.3434	399.7605
AI 1/U2 [V]	-102.3305	91.42566	193.7561
AI 1/U3 [V]	294.8585	-290.9875	-585.8460
AI 1/I1 [A]	-184.4802	186.6355	371.1157
AI 1/I2 [A]	-66.68461	63.85184	130.5364
AI 1/I3 [A]	250.9692	-250.2271	-501.1963
U1_tRMS@POWER/0 [V]	229.8323	196.3072	-33.52513
U2_tRMS@POWER/0 [V]	229.9572	220.9846	-8.972595
U3_tRMS@POWER/0 [V]	229.7419	220.7462	-8.995728
I1_tRMS@POWER/0 [A]	168.0219	180.2715	12.24959
I2_tRMS@POWER/0 [A]	168.3278	180.2413	11.91356
I3_tRMS@POWER/0 [A]	168.7443	183.0274	14.28304
P_t@POWER/0 [W]	116086.5	115434.1	-652.3672
Q_t@POWER/0 [var]	1198.549	6583.855	5385.306
PF_t@POWER/0 []	0.999947	0.998377	-1.569e-3
U_fundRMS_SYM+@POWER/0 [V]	229.8404	212.3198	-17.52066




Time [s]	A	B	Delta
	0:10.48583	1:09.27176	0:58.78593
AI 1/U1 [V]	-70.30249	-97.32152	-27.01903
AI 1/U2 [V]	305.5353	-214.2601	-519.7954
AI 1/U3 [V]	-235.7757	311.0757	546.8514
AI 1/I1 [A]	-188.4375	-89.28013	99.15734
AI 1/I2 [A]	242.8547	-167.0859	-409.9406
AI 1/I3 [A]	-54.43549	256.4229	310.8584
U1_tRMS@POWER/0 [V]	195.8147	196.3072	0.492493
U2_tRMS@POWER/0 [V]	220.3722	220.9538	0.581650
U3_tRMS@POWER/0 [V]	219.7593	220.7493	0.990005
I1_tRMS@POWER/0 [A]	179.7402	180.5197	0.779449
I2_tRMS@POWER/0 [A]	180.2829	180.4749	0.191986
I3_tRMS@POWER/0 [A]	180.5460	183.0882	2.542191
P_t@POWER/0 [W]	95971.85	115544.2	19572.30
Q_t@POWER/0 [var]	62633.62	6565.050	-56068.57
PF_t@POWER/0 []	0.837438	0.998390	0.160952
U_fundRMS_SYM+@POWER/0 [V]	211.6113	212.3106	0.699234

After dip



Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1


Seite 103 von 153  
Page 103 of 153




## Test No. 4.4 idle test


 Test No. 4.4 with PGU  
 Before dip


During dip




Time [s]	A	B	Delta
AI 1/U1 [V]	0:10.0052	1:10.0233	100.0182
AI 1/U2 [V]	257.9079	313.7489	55.84097
AI 1/U3 [V]	-230.8252	-229.1279	1.697302
AI 1/I1 [A]	-26.87311	-86.17354	-59.30043
AI 1/I2 [A]	49.07775	45.30382	-3.773928
AI 1/I3 [A]	-39.10661	-30.63488	8.471728
U1_tRMS@POWER/0 [V]	-10.37633	-15.02133	-4.644990
U2_tRMS@POWER/0 [V]	206.2952	220.0394	13.74425
U3_tRMS@POWER/0 [V]	225.7958	224.3736	-1.422180
I1_tRMS@POWER/0 [A]	220.3664	229.3215	8.955139
I2_tRMS@POWER/0 [A]	36.07198	33.67678	-2.395191
I3_tRMS@POWER/0 [A]	34.67519	34.97339	0.298199
P_t@POWER/0 [W]	34.96234	35.15065	0.188309
Q_t@POWER/0 [var]	22846.72	23233.85	387.1289
PF_t@POWER/0 []	2429.345	1980.770	-448.5750
U_fundRMS_SYM+@POWER/0 [V]	0.994394	0.996386	1.991e-3
	217.0487	224.2963	7.247635



Time [s]	A	B	Delta
AI 1/U1 [V]	0:10.3693	1:09.6850	0:59.3157
AI 1/U2 [V]	160.6135	267.2866	106.6730
AI 1/U3 [V]	147.3117	-57.25408	-204.5658
AI 1/I1 [A]	-306.5806	-205.7705	100.8101
AI 1/I2 [A]	-11.67178	49.53575	61.20754
AI 1/I3 [A]	68.24756	-12.43937	-80.68693
U1_tRMS@POWER/0 [V]	-56.63169	-37.07516	19.55652
U2_tRMS@POWER/0 [V]	195.4323	195.8782	0.445877
U3_tRMS@POWER/0 [V]	220.0990	220.5247	0.425797
I1_tRMS@POWER/0 [A]	219.8108	220.3458	0.534988
I2_tRMS@POWER/0 [A]	51.17042	36.08535	-15.08506
I3_tRMS@POWER/0 [A]	50.89818	36.15257	-14.74561
P_t@POWER/0 [W]	51.58488	36.44878	-15.13610
Q_t@POWER/0 [var]	22841.15	23031.50	190.3555
PF_t@POWER/0 []	23178.81	1369.856	-21808.96
U_fundRMS_SYM+@POWER/0 [V]	0.701900	0.998236	0.296336
	211.4119	211.8835	0.471588

After dip





**Prüfbericht-Nr.:**  
 Test report no.:


**CN224DKW 001 Attachment 1**

 Seite 107 von 153  
 Page 107 of 153


Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	4.3	4.4	
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15	
	2	Time (start of test)	--	--	hh:mm:ss	18:33:0 0	18:33:0 0	
	3	Fault type (phase)	--	--		2 phase	2 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	0.85	0.85
	5	Setting dip duration		--		ms	60000	60000
	6	Point of fault entry	Total	--		s	9.96743	9.96743
	7	Point of fault clearance	Total	--		s	69.9910 5	69.9910 5
	8	Fault duration in empty load test	Total	--		ms	60000	60000
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	0.851	0.851
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	0.999	0.997	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.013	0.201	
	13	Active power	Total	t1-10s to t1	p.u.	1.009	0.200	
	14		Pos.			1.009	0.201	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010	0.003	
	16		Pos.			0.010	0.003	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	0.852	0.851	
	19	Line current	Phase 1	t1+60ms	p.u.	1.090	0.219	
	20		Phase 2			1.084	0.217	
	21		Phase 3			1.087	0.220	
	22	Line current	Phase 1	t1+100ms	p.u.	1.084	0.219	
	23		Phase 2			1.089	0.217	
	24		Phase 3			1.084	0.220	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.835	0.199	
	26		Pos.			1.005	0.200	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.000	0.997	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.958	0.199	
	29		Pos.			1.006	0.201	
	30	Active power rising time	Pos.	--	s	0.077	0.069	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	







	A	B	Delta
Time [s]	0:20.05595	0:20.17145	0.11550
AI 1/U1 [V]	165.9896	-255.8091	-421.7987
AI 1/U2 [V]	-326.1421	-50.35758	275.7845
AI 1/U3 [V]	160.0423	304.1535	144.1112
AI 1/I1 [A]	120.3774	-14.53793	-134.9154
AI 1/I2 [A]	-233.8880	-1.325607	232.5624
AI 1/I3 [A]	113.6066	15.41305	-98.19353
U1_tRMS@POWER/0 [V]	230.7960	286.4783	55.68225
U2_tRMS@POWER/0 [V]	230.5513	286.3427	55.79132
U3_tRMS@POWER/0 [V]	230.7474	286.5828	55.83540
I1_tRMS@POWER/0 [A]	166.0588	8.499860	-157.5590
I2_tRMS@POWER/0 [A]	165.4532	8.618752	-156.8344
I3_tRMS@POWER/0 [A]	165.7173	8.222830	-157.4944
P_t@POWER/0 [W]	114703.5	6785.918	-107917.6
Q_t@POWER/0 [var]	1216.435	2578.974	1362.539
PF_t@POWER/0 []	0.999944	0.934769	-0.065175
U_fundRMS_SYM+@POWER/0 [V]	230.6926	286.4654	55.77277




	A	B	Delta
Time [s]	0:20.11125	0:20.13936	0.02811
AI 1/U1 [V]	-332.9745	405.4249	738.3993
AI 1/U2 [V]	-34.92451	-198.9493	-164.0248
AI 1/U3 [V]	368.2332	-207.7658	-575.9991
AI 1/I1 [A]	-8.723379	14.27686	23.00024
AI 1/I2 [A]	1.852036	-10.75792	-12.60996
AI 1/I3 [A]	6.822825	-3.559828	-10.38265
U1_tRMS@POWER/0 [V]	286.3428	286.4437	0.100922
U2_tRMS@POWER/0 [V]	286.3334	286.3486	0.015137
U3_tRMS@POWER/0 [V]	286.4813	286.5714	0.090057
I1_tRMS@POWER/0 [A]	8.283027	8.518106	0.235079
I2_tRMS@POWER/0 [A]	8.619269	8.724524	0.105254
I3_tRMS@POWER/0 [A]	6.621188	8.060544	1.439356
P_t@POWER/0 [W]	6353.521	6787.929	434.4082
Q_t@POWER/0 [var]	2239.368	2541.547	302.1790
PF_t@POWER/0 []	0.943132	0.936507	-6.625e-3
U_fundRMS_SYM+@POWER/0 [V]	286.3833	286.4520	0.068665



After dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1


Seite 110 von 153  
Page 110 of 153







Time [s]	A	B	Delta
AI 1/U1 [V]	9.99610	0:10.11231	0.11621
AI 1/U2 [V]	-272.5189	-381.8736	-109.3547
AI 1/U3 [V]	-119.0317	311.3516	430.3832
AI 1/I1 [A]	390.0564	70.11176	-319.9446
AI 1/I2 [A]	133.4486	-9.153009	-142.6016
AI 1/I3 [A]	42.08386	11.85548	-30.22838
U1_tRMS@POWER/0 [V]	-177.5533	-2.595902	174.9574
U2_tRMS@POWER/0 [V]	230.4349	287.4577	57.02275
U3_tRMS@POWER/0 [V]	230.5300	287.4116	56.88161
I1_tRMS@POWER/0 [A]	230.3692	287.2990	56.92975
I2_tRMS@POWER/0 [A]	33.31125	8.545745	-24.76551
I3_tRMS@POWER/0 [A]	33.38980	8.403592	-24.98621
P_t@POWER/0 [W]	33.40276	8.587940	-24.81482
Q_t@POWER/0 [var]	23065.05	7007.206	-16057.85
PF_t@POWER/0 []	392.5746	2182.197	1789.623
U_fundRMS_SYM+@POWER/0 [V]	0.999855	0.954773	-0.045083
	230.4430	287.3886	56.94568



Time [s]	A	B	Delta
AI 1/U1 [V]	0:10.03874	0:10.09633	0.05759
AI 1/U2 [V]	34.91664	-251.5633	-286.4800
AI 1/U3 [V]	-368.6176	-152.1273	216.4903
AI 1/I1 [A]	332.2356	402.4213	70.18567
AI 1/I2 [A]	-1.258969	-9.619117	-8.360148
AI 1/I3 [A]	-8.070350	-2.560377	5.509973
U1_tRMS@POWER/0 [V]	8.645177	12.15732	3.512144
U2_tRMS@POWER/0 [V]	287.5060	287.4633	-0.042664
U3_tRMS@POWER/0 [V]	287.3788	287.4287	0.049896
I1_tRMS@POWER/0 [A]	287.2591	287.3087	0.049561
I2_tRMS@POWER/0 [A]	8.388242	8.564362	0.176120
I3_tRMS@POWER/0 [A]	6.835315	8.282463	1.447148
P_t@POWER/0 [W]	8.903139	8.682918	-0.220222
Q_t@POWER/0 [var]	6408.110	6992.387	584.2769
PF_t@POWER/0 []	2647.561	2222.957	-424.6040
U_fundRMS_SYM+@POWER/0 [V]	0.924224	0.953000	0.028776
	287.3803	287.3995	0.019135


After dip



Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 113 von 153  
Page 113 of 153





**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**

 Seite 114 von 153  
 Page 114 of 153

Condition						Measurement	
	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.1	5.2
	1	Date	--	--	yyyy.mm.dd	2022.08 .15	2022.08 .15
	2	Time (start of test)	--	--	hh:mm:ss	18:39:0 0	18:39:0 0
	3	Fault type (phase)	--	--		3 phase	3 phase
	4	Setting voltage depth	Line to neutral	--	p.u.	1.25	1.25
	5	Setting dip duration		--	ms	120	120
	6	Point of fault entry	Total	--	s	9.99074	9.99074
	7	Point of fault clearance	Total	--	s	10.1106 5	10.1106 5
	8	Fault duration in empty load test	Total	--	ms	120	120
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.249	1.249
10	Pos.			p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	0.996	0.201
	13	Active power	Total	t1-10s to t1	p.u.	0.997	0.201
	14		Pos.			0.997	0.201
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010	0.003
	16		Pos.			0.011	0.003
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.246	1.250
	19	Line current	Phase 1	t1+60ms	p.u.	0.052	0.051
	20		Phase 2			0.054	0.041
	21		Phase 3			0.047	0.054
	22	Line current	Phase 1	t1+100ms	p.u.	0.051	0.052
	23		Phase 2			0.052	0.050
	24		Phase 3			0.049	0.052
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.019	0.023
26	Pos.		0.022			0.019	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.997	0.199
	29		Pos.			0.997	0.199
	30	Active power rising time	Pos.	--	s	0.403	0.099
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A
	32		Pos.			N/A	N/A
	33	Reactive power rising time	Pos.	--	s	N/A	N/A
34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	




**Test No. 5.3 idle test**

**Test No. 5.3 with PGU  
 Before dip**


During dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 116 von 153  
Page 116 of 153



Time [s]	A	B	Delta
9.99347	0:10.10732	0:11.1385	
AI 1/U1 [V]	32.82738	-363.9097	-396.7371
AI 1/U2 [V]	-295.3305	274.5359	569.8665
AI 1/U3 [V]	268.9531	129.3252	-139.6279
AI 1/I1 [A]	17.03334	-20.32411	-37.35745
AI 1/I2 [A]	-211.6932	16.59334	228.2865
AI 1/I3 [A]	196.1057	3.605008	-192.5007
U1_tRMS@POWER/0 [V]	230.8919	286.6622	55.77032
U2_tRMS@POWER/0 [V]	230.9379	242.8780	11.94019
U3_tRMS@POWER/0 [V]	230.7213	242.7065	11.98518
I1_tRMS@POWER/0 [A]	167.2681	8.999678	-158.2684
I2_tRMS@POWER/0 [A]	167.5722	7.298168	-160.2740
I3_tRMS@POWER/0 [A]	167.9962	8.825060	-159.1712
P_t@POWER/0 [W]	116073.9	6176.939	-109897.0
Q_t@POWER/0 [var]	1178.400	2005.434	827.0344
PF_t@POWER/0 []	0.999948	0.951128	-0.048821
U_fundRMS_SYM+@POWER/0 [V]	230.8469	255.4360	24.58908



Time [s]	A	B	Delta
0:10.06613	0:10.09128	0:11.02516	
AI 1/U1 [V]	-319.3302	-239.2872	80.04308
AI 1/U2 [V]	335.3260	-89.42843	-424.7544
AI 1/U3 [V]	4.661083	342.7704	338.1093
AI 1/I1 [A]	-4.334212	-10.20229	-5.868078
AI 1/I2 [A]	10.96833	-2.374888	-13.34322
AI 1/I3 [A]	-7.234097	12.62581	19.85991
U1_tRMS@POWER/0 [V]	286.7079	286.6896	-0.018311
U2_tRMS@POWER/0 [V]	242.9449	242.9021	-0.042816
U3_tRMS@POWER/0 [V]	242.3929	242.6211	0.228134
I1_tRMS@POWER/0 [A]	12.93689	10.00200	-2.934894
I2_tRMS@POWER/0 [A]	5.408334	6.418877	1.010543
I3_tRMS@POWER/0 [A]	10.52150	9.148273	-1.373222
P_t@POWER/0 [W]	7003.253	6283.841	-719.4126
Q_t@POWER/0 [var]	2882.783	2164.535	-718.2476
PF_t@POWER/0 []	0.924720	0.945480	0.020760
U_fundRMS_SYM+@POWER/0 [V]	255.3529	255.4181	0.065201



After dip

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 117 von 153  
Page 117 of 153







Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 119 von 153  
Page 119 of 153



Time [s]	A	B	Delta
	9.99329	0:10.11107	0.11778
AI 1/U1 [V]	-324.2550	-269.3231	54.93188
AI 1/U2 [V]	134.0079	292.0516	158.0436
AI 1/U3 [V]	189.8978	-22.81666	-212.7144
AI 1/I1 [A]	-46.94522	-11.01780	35.92742
AI 1/I2 [A]	19.02616	11.72006	-7.306099
AI 1/I3 [A]	27.90404	-1.831889	-29.73592
U1_tRMS@POWER/0 [V]	230.4671	287.4210	56.95386
U2_tRMS@POWER/0 [V]	230.5539	243.4965	12.94267
U3_tRMS@POWER/0 [V]	230.3796	243.4715	13.09195
I1_tRMS@POWER/0 [A]	33.32893	8.520208	-24.80873
I2_tRMS@POWER/0 [A]	33.36409	7.823732	-25.54036
I3_tRMS@POWER/0 [A]	33.42120	8.766411	-24.65479
P_t@POWER/0 [W]	23070.39	6197.849	-16872.54
Q_t@POWER/0 [var]	347.3602	1919.591	1572.231
PF_t@POWER/0 []	0.999887	0.955233	-0.044653
U_fundRMS_SYM+@POWER/0 [V]	230.4651	256.1568	25.69170



Time [s]	A	B	Delta
	0:10.08498	0:10.10785	0.02287
AI 1/U1 [V]	328.4967	8.303881	-320.1928
AI 1/U2 [V]	-17.33351	277.1316	294.4651
AI 1/U3 [V]	-331.8505	-285.8823	45.96830
AI 1/I1 [A]	12.18641	0.062108	-12.12430
AI 1/I2 [A]	-3.372312	6.650329	10.02264
AI 1/I3 [A]	-8.465410	-6.151796	2.313614
U1_tRMS@POWER/0 [V]	287.5146	287.4210	-0.093628
U2_tRMS@POWER/0 [V]	243.4893	243.4965	7.278e-3
U3_tRMS@POWER/0 [V]	243.4457	243.4715	0.025818
I1_tRMS@POWER/0 [A]	8.721050	8.520208	-0.200842
I2_tRMS@POWER/0 [A]	7.392101	7.823732	0.431631
I3_tRMS@POWER/0 [A]	9.022191	8.766411	-0.255780
P_t@POWER/0 [W]	6194.959	6197.849	2.889648
Q_t@POWER/0 [var]	1980.180	1919.591	-60.58936
PF_t@POWER/0 []	0.952523	0.955233	2.711e-3
U_fundRMS_SYM+@POWER/0 [V]	256.1685	256.1568	-0.011719


After dip



Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 120 von 153  
Page 120 of 153






**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**

 Seite 121 von 153  
 Page 121 of 153


Condition						Measurement	
	No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.3	5.4
	1	Date	--	--	yyyy.mm.dd	2022.08 .16	2022.08 .16
	2	Time (start of test)	--	--	hh:mm:ss	09:00:0 0	09:00:0 0
	3	Fault type (phase)	--	--		2 phase	2 phase
	4	Setting voltage depth	Line to neutral	--	p.u.	1.25	1.25
	5	Setting dip duration		--	ms	120	120
	6	Point of fault entry	Total	--	s	9.99347	9.99347
	7	Point of fault clearance	Total	--	s	10.1186 2	10.1186 2
	8	Fault duration in empty load test	Total	--	ms	125.14	125.14
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.250	1.250
10	Pos.			p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.010	0.201
	13	Active power	Total	t1-10s to t1	p.u.	1.009	0.200
	14		Pos.			1.009	0.201
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010	0.003
	16		Pos.			0.010	0.003
	17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.247	1.250
	19	Line current	Phase 1	t1+60ms	p.u.	0.078	0.080
	20		Phase 2			0.033	0.072
	21		Phase 3			0.063	0.081
	22	Line current	Phase 1	t1+100ms	p.u.	0.054	0.052
	23		Phase 2			0.044	0.045
	24		Phase 3			0.053	0.054
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.061	0.017
	26		Pos.			0.055	0.017
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.003	0.201
	29		Pos.			1.009	0.194
	30	Active power rising time	Pos.	--	s	0.452	0.088
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A
	32		Pos.			N/A	N/A
	33	Reactive power rising time	Pos.	--	s	N/A	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes







Time [s]	A	B	Delta
	9.98594	0:10.10698	0.12104
AI 1/U1 [V]	-98.82928	-48.87677	49.95251
AI 1/U2 [V]	-220.5560	-254.6175	-34.06143
AI 1/U3 [V]	336.3636	302.3317	-34.03187
AI 1/I1 [A]	-114.5146	-2.414704	112.0999
AI 1/I2 [A]	-116.1826	-13.04054	103.1420
AI 1/I3 [A]	230.6411	15.75983	-214.8813
U1_trMS@POWER/0 [V]	230.8118	242.8126	12.00085
U2_trMS@POWER/0 [V]	230.9458	286.6833	55.73743
U3_trMS@POWER/0 [V]	230.7318	242.6080	11.87616
I1_trMS@POWER/0 [A]	167.2630	8.334314	-158.9287
I2_trMS@POWER/0 [A]	167.5798	9.038194	-158.5416
I3_trMS@POWER/0 [A]	167.9557	7.672824	-160.2828
P_t@POWER/0 [W]	116053.3	6214.108	-109839.2
Q_t@POWER/0 [var]	1321.998	1823.965	501.9664
PF_t@POWER/0 []	0.999935	0.999521	-0.040415
U_fundRMS_SYM+@POWER/0 [V]	230.8265	255.3726	24.54605



Time [s]	A	B	Delta
	0:10.07830	0:10.09356	0.01527
AI 1/U1 [V]	-139.5309	299.1300	438.6609
AI 1/U2 [V]	391.6469	-67.29913	-458.9460
AI 1/U3 [V]	-277.4406	-226.7673	50.67325
AI 1/I1 [A]	-0.737309	12.41899	13.15630
AI 1/I2 [A]	10.46538	-4.753351	-15.21874
AI 1/I3 [A]	-9.647608	-7.490993	2.156615
U1_trMS@POWER/0 [V]	242.7404	242.8126	0.072159
U2_trMS@POWER/0 [V]	286.7085	286.6833	-0.025208
U3_trMS@POWER/0 [V]	242.6482	242.6080	-0.040268
I1_trMS@POWER/0 [A]	8.286405	8.334314	0.047910
I2_trMS@POWER/0 [A]	9.993858	9.038194	-0.955665
I3_trMS@POWER/0 [A]	7.309680	7.672824	0.363144
P_t@POWER/0 [W]	6381.010	6214.108	-166.9019
Q_t@POWER/0 [var]	1873.820	1823.965	-49.85486
PF_t@POWER/0 []	0.959485	0.999521	3.517e-5
U_fundRMS_SYM+@POWER/0 [V]	255.3666	255.3726	5.966e-3

After dip



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 125 von 153  
 Page 125 of 153


Condition						Measurement
No.	Parameter	Phase ref.	Time ref.	unit		
General Info.	0	Test number	--	--	--	5.3(D2)
	1	Date	--	--	yyyy.mm.dd	2022.08.16
	2	Time (start of test)	--	--	hh:mm:ss	09:03:38
	3	Fault type (phase)	--	--		2 phase
	4	Setting voltage depth	Line to neutral	--	p.u.	1.25
	5	Setting dip duration		--	ms	120
	6	Point of fault entry	Total	--	s	9.98856
	7	Point of fault clearance	Total	--	s	10.10869
	8	Fault duration in empty load test	Total	--	ms	120.13
	9	Voltage depth/height in empty load test	Total	t1+100ms to t2 and t1-10s to t1	p.u.	1.249
10	Pos.		p.u.		1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.008
	13	Active power	Total	t1-10s to t1	p.u.	1.008
	14		Pos.			1.009
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010
	16		Pos.			0.011
17	Cos $\varphi$	--	t1-10s to t1	--	0.999	
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.247
	19	Line current	Phase 1	t1+60ms	p.u.	0.181
	20		Phase 2			0.175
	21		Phase 3			0.169
	22	Line current	Phase 1	t1+100ms	p.u.	0.049
	23		Phase 2			0.060
	24		Phase 3			0.044
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.016
26	Pos.		0.016			
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.006
	29		Pos.			1.004
	30	Active power rising time	Pos.	--	s	0.484
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A
	32		Pos.			N/A
	33	Reactive power rising time	Pos.	--	s	N/A
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes

Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 126 von 153  
Page 126 of 153

Test No. 6.1 idle test



Test No. 6.1 with PGU  
Before dip




During dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 127 von 153  
Page 127 of 153



Time [s]	A	B	Delta
	0:19.53372	0:24.53586	5.00213
AI 1/U1 [V]	-45.11237	-288.4176	-243.3052
AI 1/U2 [V]	301.2517	372.5200	71.26832
AI 1/U3 [V]	-259.9065	-84.33605	175.5705
AI 1/I1 [A]	-31.15356	-6.055117	25.09844
AI 1/I2 [A]	217.4355	11.38389	-206.0516
AI 1/I3 [A]	-186.3334	-5.229831	181.1036
U1_tRMS@POWER/0 [V]	230.8548	276.4972	45.64244
U2_tRMS@POWER/0 [V]	230.5818	276.2507	45.66891
U3_tRMS@POWER/0 [V]	230.8188	276.5273	45.70842
I1_tRMS@POWER/0 [A]	167.0550	8.348897	-158.7061
I2_tRMS@POWER/0 [A]	166.3853	8.328238	-158.0570
I3_tRMS@POWER/0 [A]	166.6411	8.340902	-158.3002
P_t@POWER/0 [W]	115388.8	6645.165	-108743.6
Q_t@POWER/0 [var]	1173.763	1915.077	741.3141
PF_t@POWER/0 []	0.999948	0.960893	-0.039056
U_fundRMS_SYM+@POWER/0 [V]	230.7477	276.4248	45.67715



Time [s]	A	B	Delta
	0:19.95193	0:24.38169	4.42976
AI 1/U1 [V]	166.1821	-185.4017	-351.5837
AI 1/U2 [V]	223.2523	-205.7314	-428.9837
AI 1/U3 [V]	-389.2546	390.7221	779.9767
AI 1/I1 [A]	7.004619	-8.487464	-15.49208
AI 1/I2 [A]	3.230214	-3.385306	-6.615520
AI 1/I3 [A]	-10.24377	11.85572	22.09950
U1_tRMS@POWER/0 [V]	276.2521	276.4658	0.213654
U2_tRMS@POWER/0 [V]	276.0084	276.2607	0.252258
U3_tRMS@POWER/0 [V]	276.4082	276.5545	0.146301
I1_tRMS@POWER/0 [A]	8.000976	8.348076	0.347100
I2_tRMS@POWER/0 [A]	7.793654	8.344248	0.550593
I3_tRMS@POWER/0 [A]	7.921794	8.394350	0.472556
P_t@POWER/0 [W]	6222.341	6662.601	440.2593
Q_t@POWER/0 [var]	2049.077	1923.275	-125.8016
PF_t@POWER/0 []	0.949824	0.960771	0.010947
U_fundRMS_SYM+@POWER/0 [V]	276.2226	276.4267	0.204102


After dip



Prüfbericht-Nr.:  
Test report no.:


CN224DKW 001 Attachment 1

Seite 128 von 153  
Page 128 of 153







## Test No. 6.2 idle test


 Test No. 6.2 with PGU  
 Before dip


During dip




	A	B	Delta
Time [s]	0:25.58449	0:30.58514	5.00065
AI 1/U1 [V]	-385.1257	-348.3463	36.77941
AI 1/U2 [V]	128.8972	20.34330	-108.5539
AI 1/U3 [V]	256.9308	328.4679	71.53702
AI 1/I1 [A]	50.20404	-12.38823	-62.59227
AI 1/I2 [A]	-15.48994	3.756404	19.24634
AI 1/I3 [A]	-34.78074	8.392692	43.17343
U1_tRMS@POWER/0 [V]	230.5095	276.4921	45.98262
U2_tRMS@POWER/0 [V]	230.3291	276.2622	45.93317
U3_tRMS@POWER/0 [V]	230.5627	276.5859	46.02318
I1_tRMS@POWER/0 [A]	50.11766	8.421359	-41.69630
I2_tRMS@POWER/0 [A]	49.98896	8.386193	-41.60276
I3_tRMS@POWER/0 [A]	50.06823	8.432419	-41.63581
P_t@POWER/0 [W]	34607.98	6709.523	-27898.45
Q_t@POWER/0 [var]	407.0513	1915.209	1508.158
PF_t@POWER/0 []	0.999931	0.961592	-0.038339
U_fundRMS_SYM+@POWER/0 [V]	230.4641	276.4465	45.98245



	A	B	Delta
Time [s]	0:25.74218	0:30.47215	4.72997
AI 1/U1 [V]	-337.6498	348.1903	685.8402
AI 1/U2 [V]	338.6154	-327.6353	-666.2507
AI 1/U3 [V]	-0.632525	-20.96439	-20.33186
AI 1/I1 [A]	-8.946777	9.310127	18.25690
AI 1/I2 [A]	12.10010	-10.80537	-22.90547
AI 1/I3 [A]	-3.042937	1.737714	4.780650
U1_tRMS@POWER/0 [V]	276.2903	276.4859	0.195679
U2_tRMS@POWER/0 [V]	276.1801	276.2573	0.077271
U3_tRMS@POWER/0 [V]	276.5245	276.5705	0.046021
I1_tRMS@POWER/0 [A]	8.427090	8.402516	-0.024573
I2_tRMS@POWER/0 [A]	8.378959	8.400582	0.021624
I3_tRMS@POWER/0 [A]	8.298465	8.396769	0.098304
P_t@POWER/0 [W]	6663.100	6701.579	38.47900
Q_t@POWER/0 [var]	1930.592	1901.778	-28.81433
PF_t@POWER/0 []	0.960495	0.962014	1.519e-3
U_fundRMS_SYM+@POWER/0 [V]	276.3309	276.4377	0.106812

After dip





**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**


 Seite 132 von 153  
 Page 132 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	6.1	6.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .16	2022.08 .16	
	2	Time (start of test)	--	--	hh:mm:ss	09:11:0 0	09:11:0 0	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	1.20	1.20
	5	Setting dip duration		--		ms	5000	5000
	6	Point of fault entry	Total	--		s	9.99303	9.99303
	7	Point of fault clearance	Total	--		s	15.0136 3	15.0136 3
	8	Fault duration in empty load test	Total	--		ms	5072	5072
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	1.197	1.197
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.000	0.301	
	13	Active power	Total	t1-10s to t1	p.u.	1.001	0.301	
	14		Pos.			1.003	0.301	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.011	0.004	
	16		Pos.			0.010	0.004	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.202	1.202	
	19	Line current	Phase 1	t1+60ms	p.u.	0.030	0.054	
	20		Phase 2			0.088	0.062	
	21		Phase 3			0.070	0.036	
	22	Line current	Phase 1	t1+100ms	p.u.	0.045	0.049	
	23		Phase 2			0.053	0.052	
	24		Phase 3			0.048	0.047	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.054	0.017	
	26		Pos.			0.058	0.017	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.995	0.300	
	29		Pos.			0.997	0.299	
	30	Active power rising time	Pos.	--	s	0.438	0.146	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	


## Test No. 6.3 idle test


 Test No. 6.3 with PGU  
 Before dip


During dip




Time [s]	A	B	Delta
AI 1/U1 [V]	-384.1610	-90.47986	293.6812
AI 1/U2 [V]	184.5482	-225.5969	-410.1451
AI 1/U3 [V]	200.6583	315.9321	115.2737
AI 1/I1 [A]	-58.70343	-5.556822	53.14660
AI 1/I2 [A]	22.82393	-6.666303	-29.49023
AI 1/I3 [A]	35.81274	12.35151	-23.46122
U1_tRMS@POWER/0 [V]	230.8370	275.4811	44.64413
U2_tRMS@POWER/0 [V]	230.5891	240.2174	9.628372
U3_tRMS@POWER/0 [V]	230.8402	240.4808	9.640625
I1_tRMS@POWER/0 [A]	167.0867	8.324073	-158.7626
I2_tRMS@POWER/0 [A]	166.4093	8.169434	-158.2399
I3_tRMS@POWER/0 [A]	166.7206	8.459362	-158.2612
P_t@POWER/0 [W]	115421.7	6051.085	-109370.6
Q_t@POWER/0 [var]	1186.123	1716.667	530.5449
PF_t@POWER/0 []	0.999947	0.962035	-0.037912
U_fundRMS_SYM+@POWER/0 [V]	230.7513	251.4420	20.69063




Time [s]	A	B	Delta
AI 1/U1 [V]	-364.4366	-387.1703	-22.73369
AI 1/U2 [V]	278.4012	223.7952	-54.60596
AI 1/U3 [V]	87.42738	164.2597	76.83230
AI 1/I1 [A]	-9.522200	-10.82194	-1.299739
AI 1/I2 [A]	9.830714	7.975102	-1.855612
AI 1/I3 [A]	-0.053048	3.017307	3.070355
U1_tRMS@POWER/0 [V]	274.5955	275.4804	0.884949
U2_tRMS@POWER/0 [V]	239.5184	240.2144	0.696045
U3_tRMS@POWER/0 [V]	239.8932	240.4820	0.588806
I1_tRMS@POWER/0 [A]	8.389889	8.325805	-0.064084
I2_tRMS@POWER/0 [A]	8.034066	8.139540	0.105474
I3_tRMS@POWER/0 [A]	8.510057	8.459631	-0.050426
P_t@POWER/0 [W]	6036.799	6046.923	10.12451
Q_t@POWER/0 [var]	1692.752	1706.917	14.16504
PF_t@POWER/0 []	0.962863	0.962393	-4.700e-4
U_fundRMS_SYM+@POWER/0 [V]	250.7167	251.4410	0.724319

After dip






Time [s]	A	B	Delta
	0:32.82288	0:33.26771	0.44484
AI 1/U1 [V]	248.2901	218.2930	-29.99711
AI 1/U2 [V]	-306.8464	102.1667	409.0131
AI 1/U3 [V]	58.36082	-319.8202	-378.1810
AI 1/I1 [A]	11.01101	154.9878	143.9768
AI 1/I2 [A]	-14.69421	73.23838	87.93259
AI 1/I3 [A]	3.528357	-228.0125	-231.5408
U1_tRMS@POWER/0 [V]	275.2034	231.1171	-44.08623
U2_tRMS@POWER/0 [V]	240.3971	230.8596	-9.537460
U3_tRMS@POWER/0 [V]	240.6124	231.1140	-9.498383
I1_tRMS@POWER/0 [A]	8.336161	166.4694	158.1332
I2_tRMS@POWER/0 [A]	8.108081	165.6622	157.5541
I3_tRMS@POWER/0 [A]	8.481449	166.0262	157.5448
P_t@POWER/0 [W]	6042.926	115081.6	109038.7
Q_t@POWER/0 [var]	1724.007	1359.057	-364.9508
PF_t@POWER/0 []	0.961631	0.999930	0.038300
U_fundRMS_SYM+@POWER/0 [V]	251.4668	231.0259	-20.44090




Time [s]	A	B	Delta
	0:35.81948	0:42.84854	7.02907
AI 1/U1 [V]	-56.41151	126.5788	182.9903
AI 1/U2 [V]	-249.6462	197.0165	446.6627
AI 1/U3 [V]	306.5653	-323.8239	-630.3893
AI 1/I1 [A]	-39.85715	89.81431	129.6715
AI 1/I2 [A]	-180.8553	143.6523	324.5076
AI 1/I3 [A]	220.8852	-233.5551	-454.4403
U1_tRMS@POWER/0 [V]	230.8514	230.8775	0.026169
U2_tRMS@POWER/0 [V]	230.5813	230.5813	1.526e-5
U3_tRMS@POWER/0 [V]	230.8108	230.8321	0.021240
I1_tRMS@POWER/0 [A]	166.4649	166.5640	0.099121
I2_tRMS@POWER/0 [A]	165.7424	165.8022	0.059845
I3_tRMS@POWER/0 [A]	165.9582	166.1592	0.201004
P_t@POWER/0 [W]	114941.3	115035.5	94.15625
Q_t@POWER/0 [var]	1465.772	1189.861	-275.9110
PF_t@POWER/0 []	0.999919	0.999947	2.784e-5
U_fundRMS_SYM+@POWER/0 [V]	230.7437	230.7593	0.015625



## Test No. 6.4 idle test




Time [s]	A	B	Delta
AI 1/U1 [V]	-58.96187	-341.2845	-282.3227
AI 1/U2 [V]	-250.3212	302.1183	552.4395
AI 1/U3 [V]	306.8860	30.83396	-276.0520
AI 1/I1 [A]	-1.237512	0.638604	1.876116
AI 1/I2 [A]	0.782847	0.448346	-0.334501
AI 1/I3 [A]	0.425100	-1.117468	-1.542568
U1_tRMS@POWER/0 [V]	230.3167	275.3420	45.02530
U2_tRMS@POWER/0 [V]	230.4267	240.4433	10.01653
U3_tRMS@POWER/0 [V]	230.2500	240.2623	10.01236
U_fundRMS_SYM+@POWER/0 [V]	230.3311	251.6289	21.29781
U_fundRMS_SYM-@POWER/0 [V]	0.055219	21.49427	21.43905


 Test No. 6.4 with PGU  
 Before dip


Time [s]	A	B	Delta
AI 1/U1 [V]	-121.8410	319.6688	441.5097
AI 1/U2 [V]	322.2547	-214.9935	-537.2482
AI 1/U3 [V]	-200.6576	-105.8636	94.79404
AI 1/I1 [A]	-26.98553	69.92817	96.91370
AI 1/I2 [A]	69.54587	-46.32402	-115.8699
AI 1/I3 [A]	-42.92012	-23.70393	19.21618
U1_tRMS@POWER/0 [V]	230.5422	230.5563	0.014114
U2_tRMS@POWER/0 [V]	230.3047	230.3318	0.027176
U3_tRMS@POWER/0 [V]	230.5541	230.5610	6.973e-3
I1_tRMS@POWER/0 [A]	50.05975	50.08228	0.022537
I2_tRMS@POWER/0 [A]	49.95975	49.99368	0.033932
I3_tRMS@POWER/0 [A]	50.02121	50.02526	4.051e-3
P_t@POWER/0 [W]	34577.02	34593.06	16.03516
Q_t@POWER/0 [var]	408.6949	435.1125	26.41766
PF_t@POWER/0 []	0.999930	0.999921	-9.239e-6
U_fundRMS_SYM+@POWER/0 [V]	230.4640	230.4801	0.016068

During dip




Time [s]	A	B	Delta
AI 1/U1 [V]	0:49.14647	0:54.16296	5.01649
AI 1/U2 [V]	-258.9390	-301.4362	-42.49716
AI 1/U3 [V]	-47.55950	259.5253	307.0848
AI 1/I1 [A]	301.1987	42.64426	-258.5545
AI 1/I2 [A]	-55.69387	-15.42616	40.26771
AI 1/I3 [A]	-9.790421	13.91018	23.70060
AI 1/I3 [A]	64.98111	0.586987	-64.39412
U1_tRMS@POWER/0 [V]	230.5563	275.4875	44.93121
U2_tRMS@POWER/0 [V]	230.3318	240.2242	9.892349
U3_tRMS@POWER/0 [V]	230.5610	240.4699	9.908875
I1_tRMS@POWER/0 [A]	50.08228	8.359995	-41.72229
I2_tRMS@POWER/0 [A]	49.99368	8.181250	-41.81243
I3_tRMS@POWER/0 [A]	50.02526	8.543894	-41.48137
P_t@POWER/0 [W]	34593.06	6088.917	-28504.14
Q_t@POWER/0 [var]	435.1125	1704.370	1269.258
PF_t@POWER/0 []	0.999921	0.962986	-0.036935
U_fundRMS_SYM+@POWER/0 [V]	230.4801	251.4413	20.96123



Time [s]	A	B	Delta
AI 1/U1 [V]	0:49.26473	0:54.08127	4.81654
AI 1/U2 [V]	-386.4093	-232.7616	153.6477
AI 1/U3 [V]	162.4894	339.3460	176.8565
AI 1/I1 [A]	225.1563	-106.2410	-331.3973
AI 1/I2 [A]	-12.13586	-4.506231	7.629633
AI 1/I2 [A]	8.018852	11.67452	3.655672
AI 1/I3 [A]	4.040718	-7.273436	-11.31415
U1_tRMS@POWER/0 [V]	275.3444	275.4945	0.150116
U2_tRMS@POWER/0 [V]	240.2030	240.2301	0.027100
U3_tRMS@POWER/0 [V]	240.5294	240.4651	-0.064301
I1_tRMS@POWER/0 [A]	8.417765	8.364469	-0.053296
I2_tRMS@POWER/0 [A]	8.098846	8.191457	0.092610
I3_tRMS@POWER/0 [A]	8.468520	8.542813	0.074293
P_t@POWER/0 [W]	6074.806	6090.871	16.06494
Q_t@POWER/0 [var]	1669.652	1710.334	40.68188
PF_t@POWER/0 []	0.964243	0.962763	-1.480e-3
U_fundRMS_SYM+@POWER/0 [V]	251.4060	251.4453	0.039322

After dip



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**


 Seite 139 von 153  
 Page 139 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	6.3	6.4	
	1	Date	--	--	yyyy.mm.dd	2022.08 .16	2022.08 .16	
	2	Time (start of test)	--	--	hh:mm:ss	09:26:0 0	09:26:0 0	
	3	Fault type (phase)	--	--		2 phase	2 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	1.20	1.20
	5	Setting dip duration		--		ms	5000	5000
	6	Point of fault entry	Total	--		s	9.99446	9.99446
	7	Point of fault clearance	Total	--		s	15.0081 1	15.0081 1
	8	Fault duration in empty load test	Total	--		ms	5013.65	5013.65
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	1.197	1.197
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.001	0.301	
	13	Active power	Total	t1-10s to t1	p.u.	1.002	0.301	
	14		Pos.			1.004	0.301	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.011	0.004	
	16		Pos.			0.010	0.004	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.198	1.198	
	19	Line current	Phase 1	t1+60ms	p.u.	0.062	0.175	
	20		Phase 2			0.040	0.169	
	21		Phase 3			0.051	0.114	
	22	Line current	Phase 1	t1+100ms	p.u.	0.052	0.052	
	23		Phase 2			0.048	0.048	
	24		Phase 3			0.051	0.051	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.052	0.053	
	26		Pos.			0.053	0.053	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.999	0.299	
	29		Pos.			1.000	0.300	
	30	Active power rising time	Pos.	--	s	0.445	0.162	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	


**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 140 von 153  
 Page 140 of 153

**Test No. 7.1 idle test**


Time [s]	A	B	Delta
9.99405	1:10.00521	1:00.01116	
AI 1/U1 [V]	34.37305	-344.4631	-378.8362
AI 1/U2 [V]	-298.1024	297.9179	596.0203
AI 1/U3 [V]	262.9771	46.50855	-216.4686
AI 1/I1 [A]	-1.057744	0.478268	1.536012
AI 1/I2 [A]	0.411987	0.714183	0.302196
AI 1/I3 [A]	0.616908	-1.217365	-1.834273
U1_tRMS@POWER/0 [V]	230.2256	264.3449	34.11935
U2_tRMS@POWER/0 [V]	230.4647	264.4821	34.01735
U3_tRMS@POWER/0 [V]	230.2802	264.2937	34.01350
U_fundRMS_SYM+@POWER/0 [V]	230.3233	264.3735	34.05020
U_fundRMS_SYM-@POWER/0 [V]	0.130146	0.072582	-0.057563


**Test No. 7.1 with PGU  
 Before dip**


Time [s]	A	B	Delta
7.8696	9.8654	1.9958	
AI 1/U1 [V]	-326.4938	-93.78386	232.7099
AI 1/U2 [V]	158.6921	317.5516	158.8595
AI 1/U3 [V]	167.7733	-223.8410	-391.6142
AI 1/I1 [A]	-237.0029	-69.20362	167.7992
AI 1/I2 [A]	113.6599	230.2470	116.5872
AI 1/I3 [A]	123.2966	-161.2156	-284.5122
U1_tRMS@POWER/0 [V]	230.8399	230.8241	-0.015808
U2_tRMS@POWER/0 [V]	230.9361	230.9301	-6.027e-3
U3_tRMS@POWER/0 [V]	230.7732	230.8040	0.030777
I1_tRMS@POWER/0 [A]	167.2811	167.2835	2.441e-3
I2_tRMS@POWER/0 [A]	167.6432	167.6658	0.022568
I3_tRMS@POWER/0 [A]	168.0804	168.0333	-0.047119
P_t@POWER/0 [W]	116113.2	116108.6	-4.523438
Q_t@POWER/0 [var]	1111.618	1206.059	94.44128
PF_t@POWER/0 []	0.999954	0.999946	-8.106e-6
U_fundRMS_SYM+@POWER/0 [V]	230.8465	230.8495	2.930e-3

During dip


**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 141 von 153  
 Page 141 of 153




**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**


 Seite 142 von 153  
 Page 142 of 153





## Test No. 7.2 idle test


 Test No. 7.2 with PGU  
 Before dip


During dip




Time [s]	A	B	Delta
	9.99438	1:10.00066	1:00.00628
AI 1/U1 [V]	-29.97041	198.0195	227.9899
AI 1/U2 [V]	-303.5004	176.5776	480.0780
AI 1/U3 [V]	334.8158	-373.7233	-708.5391
AI 1/I1 [A]	-13.08477	21.23261	34.31738
AI 1/I2 [A]	-11.19101	19.91308	31.10409
AI 1/I3 [A]	24.59049	-41.05211	-65.64260
U1_tRMS@POWER/0 [V]	230.4489	264.4570	34.00807
U2_tRMS@POWER/0 [V]	230.5454	264.5999	34.05447
U3_tRMS@POWER/0 [V]	230.3648	264.4203	34.05557
I1_tRMS@POWER/0 [A]	33.17775	28.87746	-4.300293
I2_tRMS@POWER/0 [A]	33.22657	28.88175	-4.344824
I3_tRMS@POWER/0 [A]	33.26465	28.94184	-4.322807
P_t@POWER/0 [W]	22965.32	22926.58	-38.74805
Q_t@POWER/0 [var]	411.8385	487.8681	76.02966
PF_t@POWER/0 []	0.999839	0.999774	-6.557e-5
U_fundRMS_SYM+@POWER/0 [V]	230.4513	264.4910	34.03975



Time [s]	A	B	Delta
	0:10.12241	1:09.67584	0:59.55343
AI 1/U1 [V]	233.5086	328.2547	94.74612
AI 1/U2 [V]	138.0472	-319.1037	-457.1510
AI 1/U3 [V]	-369.6318	-11.10864	358.5232
AI 1/I1 [A]	26.08431	35.46036	9.376050
AI 1/I2 [A]	13.60548	-34.27696	-47.88244
AI 1/I3 [A]	-39.66916	-1.058817	38.61034
U1_tRMS@POWER/0 [V]	264.4322	264.4358	3.632e-3
U2_tRMS@POWER/0 [V]	264.4880	264.5927	0.104645
U3_tRMS@POWER/0 [V]	264.3717	264.4308	0.059021
I1_tRMS@POWER/0 [A]	28.82138	28.72420	-0.097187
I2_tRMS@POWER/0 [A]	28.87807	28.79623	-0.081839
I3_tRMS@POWER/0 [A]	28.91901	28.62927	-0.289738
P_t@POWER/0 [W]	22884.21	22779.24	-104.9688
Q_t@POWER/0 [var]	965.5944	531.2617	-434.3327
PF_t@POWER/0 []	0.999111	0.999728	6.171e-4
U_fundRMS_SYM+@POWER/0 [V]	264.4293	264.4850	0.055756

After dip





**Prüfbericht-Nr.:**  
**Test report no.:**
**CN224DKW 001 Attachment 1**

 Seite 146 von 153  
 Page 146 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	7.1	7.2	
	1	Date	--	--	yyyy.mm.dd	2022.08 .16	2022.08 .16	
	2	Time (start of test)	--	--	hh:mm:ss	09:33:4 8	09:33:4 8	
	3	Fault type (phase)	--	--		3 phase	3 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	1.15	1.15
	5	Setting dip duration		--		ms	60000	60000
	6	Point of fault entry	Total	--		s	9.99405	9.99405
	7	Point of fault clearance	Total	--		s	70.0052 1	70.0052 1
	8	Fault duration in empty load test	Total	--		ms	60011	60011
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	1.149	1.149
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.010	0.201	
	13	Active power	Total	t1-10s to t1	p.u.	1.010	0.200	
	14		Pos.			1.010	0.200	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.010	0.003	
	16		Pos.			0.010	0.004	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.151	1.150	
	19	Line current	Phase 1	t1+60ms	p.u.	0.723	0.177	
	20		Phase 2			0.588	0.180	
	21		Phase 3			0.722	0.180	
	22	Line current	Phase 1	t1+100ms	p.u.	0.913	0.183	
	23		Phase 2			0.943	0.174	
	24		Phase 3			0.913	0.175	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	1.009	0.198	
	26		Pos.			1.008	0.199	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	1.005	0.200	
	29		Pos.			1.006	0.199	
	30	Active power rising time	Pos.	--	s	0.116	0.040	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	

## Test No. 7.3 idle test



 Test No. 7.3 with PGU  
 Before dip


During dip


Prüfbericht-Nr.:  
Test report no.:

CN224DKW 001 Attachment 1

Seite 148 von 153  
Page 148 of 153




Time [s]	A	B	Delta
AI 1/U1 [V]	9.9926	1:10.0020	100.0094
AI 1/U2 [V]	-169.6100	19.02580	188.6358
AI 1/U3 [V]	-156.9672	271.8530	428.8202
AI 1/I1 [A]	326.1612	-290.5336	-616.6947
AI 1/I2 [A]	-121.7719	8.284212	130.0562
AI 1/I3 [A]	-115.6902	185.5240	301.2142
AI 1/I3 [A]	237.4361	-193.2986	-430.7347
U1_tRMS@POWER/0 [V]	230.7807	264.8269	34.04620
U2_tRMS@POWER/0 [V]	230.9496	239.9393	8.989777
U3_tRMS@POWER/0 [V]	230.7367	239.7539	9.017227
I1_tRMS@POWER/0 [A]	167.1787	155.5001	-11.67867
I2_tRMS@POWER/0 [A]	167.4734	156.8282	-10.64513
I3_tRMS@POWER/0 [A]	167.9502	153.8785	-14.07167
P_t@POWER/0 [W]	116005.5	115509.5	-496.0234
Q_t@POWER/0 [var]	1208.607	6686.546	5477.939
PF_t@POWER/0 []	0.999946	0.998329	-1.617e-3
U_fundRMS_SYM+@POWER/0 [V]	230.8191	247.7903	16.97124





Time [s]	A	B	Delta
AI 1/U1 [V]	0:10.4964	1:09.8162	0:59.3197
AI 1/U2 [V]	226.7904	353.4610	126.6706
AI 1/U3 [V]	-338.5635	-271.3933	67.17015
AI 1/I1 [A]	104.7843	-88.49168	-193.2759
AI 1/I2 [A]	219.8031	210.8116	-8.991480
AI 1/I3 [A]	-191.3825	-168.0036	23.37897
AI 1/I3 [A]	-28.49555	-43.14590	-14.65035
U1_tRMS@POWER/0 [V]	264.4976	264.8341	0.336548
U2_tRMS@POWER/0 [V]	239.5615	239.9072	0.345657
U3_tRMS@POWER/0 [V]	239.4461	239.7404	0.294342
I1_tRMS@POWER/0 [A]	169.0194	155.7145	-13.30490
I2_tRMS@POWER/0 [A]	169.5867	156.9590	-12.62762
I3_tRMS@POWER/0 [A]	170.0536	154.0409	-16.01271
P_t@POWER/0 [W]	109636.0	115631.0	5995.000
Q_t@POWER/0 [var]	62198.39	6683.169	-55515.23
PF_t@POWER/0 []	0.869779	0.998334	0.128555
U_fundRMS_SYM+@POWER/0 [V]	247.4415	247.7774	0.335907

After dip







## Test No. 7.4 idle test


 Test No. 7.4 with PGU  
 Before dip


During dip




Time [s]	A	B	Delta
	9.98869	1:10.02242	1:00.03373
AI 1/U1 [V]	-226.0847	-292.7106	-66.62584
AI 1/U2 [V]	-91.76875	271.4977	363.2665
AI 1/U3 [V]	316.5407	26.57652	-289.9642
AI 1/I1 [A]	-32.79805	-46.07928	-13.28123
AI 1/I2 [A]	-13.91220	38.61773	52.52993
AI 1/I3 [A]	47.00125	7.982493	-39.01875
U1_tRMS@POWER/0 [V]	230.3990	264.3749	33.97598
U2_tRMS@POWER/0 [V]	230.5556	239.5849	9.029312
U3_tRMS@POWER/0 [V]	230.3694	239.3882	9.018829
I1_tRMS@POWER/0 [A]	33.29615	30.97024	-2.325907
I2_tRMS@POWER/0 [A]	33.31534	31.26232	-2.053022
I3_tRMS@POWER/0 [A]	33.39322	30.38664	-3.006571
P_t@POWER/0 [W]	23041.97	22905.46	-136.5078
Q_t@POWER/0 [var]	386.5778	1459.913	1073.335
PF_t@POWER/0 []	0.999859	0.997975	-1.884e-3
U_fundRMS_SYM+@POWER/0 [V]	230.4395	247.4054	16.96588



Time [s]	A	B	Delta
	0:10.23042	1:09.47263	0:59.24221
AI 1/U1 [V]	-72.99018	343.5650	416.5552
AI 1/U2 [V]	-237.6359	-284.6220	-46.98611
AI 1/U3 [V]	311.2824	-66.97369	-378.2561
AI 1/I1 [A]	34.55317	42.49025	7.937074
AI 1/I2 [A]	-62.69575	-35.30634	27.38941
AI 1/I3 [A]	28.22554	-6.172419	-34.39796
U1_tRMS@POWER/0 [V]	263.1584	264.4850	1.326660
U2_tRMS@POWER/0 [V]	238.3611	239.5683	1.207230
U3_tRMS@POWER/0 [V]	238.3327	239.3919	1.059265
I1_tRMS@POWER/0 [A]	43.84715	30.92608	-12.92107
I2_tRMS@POWER/0 [A]	44.26197	31.19189	-13.07008
I3_tRMS@POWER/0 [A]	43.42157	30.31813	-13.10345
P_t@POWER/0 [W]	22622.86	22864.34	241.4785
Q_t@POWER/0 [var]	23246.95	1445.516	-21801.43
PF_t@POWER/0 []	0.697422	0.998007	0.300586
U_fundRMS_SYM+@POWER/0 [V]	246.2337	247.4341	1.200378

After dip



**Prüfbericht-Nr.:**  
 Test report no.:

**CN224DKW 001 Attachment 1**

 Seite 153 von 153  
 Page 153 of 153

Condition						Measurement		
	No.	Parameter	Phase ref.	Time ref.	unit			
General Info.	0	Test number	--	--	--	7.3	7.4	
	1	Date	--	--	yyyy.mm.dd	2022.08 .16	2022.08 .16	
	2	Time (start of test)	--	--	hh:mm:ss	09:38:0 0	09:38:0 0	
	3	Fault type (phase)	--	--		2 phase	2 phase	
	4	Setting voltage depth	Line to neutral	--		p.u.	1.15	1.15
	5	Setting dip duration		--		ms	60000	60000
	6	Point of fault entry	Total	--		s	9.9903	9.9903
	7	Point of fault clearance	Total	--		s	70.0242	70.0242
	8	Fault duration in empty load test	Total	--		ms	60034	60034
	9	Voltage depth/height in empty load test	Total		t1+100ms to t2 and t1-10s to t1	p.u.	1.149	1.149
10	Pos.				p.u.	1.001	1.001	
Before dip <t1	11	Voltage	Line to neutral	t1-100s to t1	p.u.	1.003	1.002	
	12	Current	Pos.	t1-500ms to t1-100ms	p.u.	1.010	0.201	
	13	Active power	Total	t1-10s to t1	p.u.	1.008	0.200	
	14		Pos.			1.009	0.200	
	15	Reactive power	Total	t1-10s to t1	p.u.	0.009	0.004	
	16		Pos.			0.010	0.003	
17	Cos $\phi$	--	t1-10s to t1	--	0.999	0.999		
During dip t1 to t2	18	Voltage	Line to neutral	t1+100ms to t2-20ms	p.u.	1.150	1.150	
	19	Line current	Phase 1	t1+60ms	p.u.	0.949	0.191	
	20		Phase 2			0.950	0.181	
	21		Phase 3			0.910	0.181	
	22	Line current	Phase 1	t1+100ms	p.u.	1.036	0.253	
	23		Phase 2			1.042	0.253	
	24		Phase 3			1.048	0.259	
	25	Active power	Total	t1+100ms to t2-20ms	p.u.	0.953	0.197	
	26		Pos.			1.005	0.199	
After dip > t2	27	Voltage	Line to neutral	t2+3s to t2+10s	p.u.	1.003	1.002	
	28	Active power	Total	t2+3s to t2+10s	p.u.	0.958	0.198	
	29		Pos.			1.002	0.199	
	30	Active power rising time	Pos.	--	s	0.109	0.094	
	31	Reactive power	Total	t2+3s to t2+10s	p.u.	N/A	N/A	
	32		Pos.			N/A	N/A	
	33	Reactive power rising time	Pos.	--	s	N/A	N/A	
	34	PGU does not disconnect from grid till 60s after fault	--	t2 to t2+60s	Yes / No	Yes	Yes	



PHOTO DOCUMENTATION

CN224DKW 001 ATTACHMENT 2

for

SOLAR INVERTER

SUN2000-100KTL-M2, SUN2000-115KTL-M2

HUAWEI TECHNOLOGIES CO., LTD.



This documentation consists of 4 pages (excluding this cover page)

**Model:** as cover



Figure 1. Front view



Figure 2. Left view



**Model:** as cover



Figure 3. Right view



Figure 4. Top view



**Model:** as cover



Figure 5. AC Connect view



Figure 6. DC Connect view